S106 Part 1 'Application to connect to a public sewer' Approval Notice



United Utilities Reference Number:					NC4281			
Applicant details								
Applicant name								
Applicant address (including postcode)								
Applicant email				ľ				
Site details: The site / property v	vhich is prop	osed for co	nnection to	the public sewer				
Site address (including postcode)								
APPROVED Your application for connection to the public sewer has been approved, to be made via a new connection:								
To a private drain		You may appoint your contractor and advise your appointed building control body (who should inspect the work). United Utilities should be advised when this work is complete.						
Direct to the public sewer	Further action required You may now appoint an appropriately qualified contractor. Your appointed contractor is responsible for obtaining authorisation to work on a public sewer. (The S106 Part 2 application form 'Request for permission to work on a public sewer' is available on our website; unitedutilities.com).							
Mode of connection approved	New manhole							
Sewer connection type	Foul		×	Surface water		Combined		
This approval is valid for 12 months from the date below. This approval does not grant access to third party land, permission should be sought if required between applicant and land owner If the new connection renders access unsafe or is otherwise detrimental to the manhole or sewer, a new/upgraded manhole will be requested.								
Comments								
Approval granted for a 150mm foul connection via the construction of a new manhole on the combined sewer located within St. Michaels Lane.								
The new manhole must be constructed in line with United Utilities standard details with the appropriate openings, ring size, benching/pipe configuration, channels and landing. Please ensure a plan of your proposals is submitted with your contractors Part 2 application								
Developer Services Inspector								
Contact number								
Date	24/04/2019							

S106 Part 2 'Request for permission to work on a public sewer (MEDIUM / HIGH RISK)' Approval Notice

24/04/2019

Date



United Utilities Reference Nur	mber:		NC4821				
Contractor details							
Contractor/company name							
Contractor email address							
Works Supervisor							
Principal Contractor details (if applicable):							
Company name							
Name of contact for project							
Email address							
Date of proposed works	06/05/2019	Type of connection approved	New Manhole				
Site details: The site / property which is proposed for connection to the public sewer							
Site address (including postcode)							
Your application for permission to work on the public sewer has been approved. THIS PERMIT SHOULD BE AVAILABLE ON SITE FOR INSPECTION This notice constitutes your permit make a connection to the public sewer network as detailed on your application, 'Request for permission to work on a public sewer'. You are now authorised to make the connection to the public sewer based on the agreed method and on the date given.							
Please provide 5 days' notice to the Developer Services Inspector to arrange an inspection of the works. The excavation should not be backfilled until the United Utilities appointed person has inspected the works. United Utilities reserve the right to request a connection to the public sewer be laid open for inspection. United Utilities will also be entitled to recover all costs associated for any excavation, remedial works and repeat visits if these requirements are not met. You must log on and off the sewer network at the beginning and end of each shift when working on the public sewer by calling and quoting the United Utilities reference number at the top of this decision notice. Any gas alarms, residual risks or sewer incidents should also be reported on this number.							
Comments							
Approval granted for a 150mm foul connection via the construction of a new manhole on the combined sewer located within St. Michaels Lane.							
The new manhole must be constructed in line with United Utilities standard details.							
Approved By							
Contact Number							