

Date samples taken: 21 November 2025

Address: [REDACTED]

Parameter	Value	Regulatory Limit	Unit
Total chlorine residual	0.88	No regulatory standard	mg/l
Free chlorine residual	0.81	No regulatory standard	mg/l
Colonies (2 days 37°C)	0	No abnormal change	Number/ml
Colonies (3 days 22°C)	0	No abnormal change	Number/ml
Coliform bacteria	0	0	Number/100ml
<i>Clostridium perfringens</i>	0	0	Number/100ml
<i>E. coli</i>	0	0	Number/100ml
Enterococci	0	0	Number/100ml
pH	7.54	6.5-9.5	pH Unit

mg/l = milligrammes per litre or one part in a million
µg/l = microgrammes per litre or one part in a thousand million
< = less than