

Sample Date	Parameter	Value Qualifier	Value	Unit	Regulatory Limit
14/06/2021	ALKALINITY	<	8.96	mg/l	No regulatory limit
25/06/2021	ALKALINITY		10.5	mg/l	No regulatory limit
07/07/2021	ALKALINITY		9.6	mg/l	No regulatory limit
21/07/2021	ALKALINITY		10.2	mg/l	No regulatory limit
26/07/2021	ALKALINITY		11	mg/l	No regulatory limit
27/08/2021	ALKALINITY		25.1	mg/l	No regulatory limit
29/11/2021	ALKALINITY		9.5	mg/l	No regulatory limit
14/12/2021	ALKALINITY		9.4	mg/l	No regulatory limit
25/01/2022	ALKALINITY		10.3	mg/l	No regulatory limit
01/03/2022	ALKALINITY		7.8	mg/l	No regulatory limit
04/03/2022	ALKALINITY		12.5	mg/l	No regulatory limit
05/04/2022	ALKALINITY		17.4	mg/l	No regulatory limit
28/06/2022	ALKALINITY		10.5	mg/l	No regulatory limit
11/08/2022	ALKALINITY		17	mg/l	No regulatory limit
07/09/2022	ALKALINITY		14.8	mg/l	No regulatory limit
05/12/2022	ALKALINITY		10.7	mg/l	No regulatory limit
10/01/2023	ALKALINITY		8.8	mg/l	No regulatory limit
02/03/2023	ALKALINITY		8.5	mg/l	No regulatory limit
19/04/2023	ALKALINITY		8.6	mg/l	No regulatory limit
19/05/2023	ALKALINITY		10.7	mg/l	No regulatory limit
25/07/2023	ALKALINITY		9.6	mg/l	No regulatory limit
22/09/2023	ALKALINITY		11.7	mg/l	No regulatory limit
14/11/2023	ALKALINITY		9	mg/l	No regulatory limit
16/11/2023	ALKALINITY		8.8	mg/l	No regulatory limit
06/02/2024	ALKALINITY		9.3	mg/l	No regulatory limit
19/02/2024	ALKALINITY		10.9	mg/l	No regulatory limit
01/05/2024	ALKALINITY		12.4	mg/l	No regulatory limit
07/06/2024	ALKALINITY		11.7	mg/l	No regulatory limit
28/08/2024	ALKALINITY		16.1	mg/l	No regulatory limit
26/09/2024	ALKALINITY		12.3	mg/l	No regulatory limit
01/10/2024	ALKALINITY		15.8	mg/l	No regulatory limit
13/11/2024	ALKALINITY		12.7	mg/l	No regulatory limit
03/12/2024	ALKALINITY		12	mg/l	No regulatory limit
18/01/2025	ALKALINITY		15.1	mg/l	No regulatory limit
07/03/2025	ALKALINITY		9.1	mg/l	No regulatory limit
13/05/2025	ALKALINITY		30.6	mg/l	No regulatory limit
18/06/2025	ALKALINITY		15.9	mg/l	No regulatory limit
19/06/2025	ALKALINITY		16.8	mg/l	No regulatory limit
25/07/2025	ALKALINITY		21.1	mg/l	No regulatory limit
10/09/2025	ALKALINITY		20.9	mg/l	No regulatory limit
06/10/2025	ALKALINITY		12.5	mg/l	No regulatory limit
30/01/2026	ALKALINITY		7.8	mg/l	No regulatory limit
03/03/2021	ALUMINIUM	<	2.71	µg/l	200
20/03/2021	ALUMINIUM	<	2.71	µg/l	200
26/03/2021	ALUMINIUM	<	2.71	µg/l	200
30/03/2021	ALUMINIUM	<	2.71	µg/l	200
31/03/2021	ALUMINIUM	<	2.71	µg/l	200

08/04/2021	ALUMINIUM	<	2.71 µg/l	200
09/04/2021	ALUMINIUM		13.3 µg/l	200
10/04/2021	ALUMINIUM	<	2.71 µg/l	200
23/04/2021	ALUMINIUM		12.8 µg/l	200
08/05/2021	ALUMINIUM	<	2.71 µg/l	200
10/05/2021	ALUMINIUM	<	2.71 µg/l	200
17/05/2021	ALUMINIUM		13.3 µg/l	200
27/05/2021	ALUMINIUM	<	2.71 µg/l	200
29/05/2021	ALUMINIUM		5.84 µg/l	200
04/06/2021	ALUMINIUM		2.81 µg/l	200
07/06/2021	ALUMINIUM		5.09 µg/l	200
11/06/2021	ALUMINIUM		9.34 µg/l	200
24/06/2021	ALUMINIUM	<	2.71 µg/l	200
30/06/2021	ALUMINIUM	<	2.71 µg/l	200
08/07/2021	ALUMINIUM	<	2.71 µg/l	200
15/07/2021	ALUMINIUM	<	2.71 µg/l	200
23/07/2021	ALUMINIUM	<	2.71 µg/l	200
03/08/2021	ALUMINIUM	<	2.71 µg/l	200
27/08/2021	ALUMINIUM		3.53 µg/l	200
01/09/2021	ALUMINIUM	<	2.71 µg/l	200
09/09/2021	ALUMINIUM	<	2.71 µg/l	200
24/09/2021	ALUMINIUM	<	2.71 µg/l	200
28/09/2021	ALUMINIUM	<	2.71 µg/l	200
29/09/2021	ALUMINIUM		5.49 µg/l	200
30/09/2021	ALUMINIUM		4.89 µg/l	200
04/10/2021	ALUMINIUM		3.48 µg/l	200
17/10/2021	ALUMINIUM	<	2.71 µg/l	200
20/10/2021	ALUMINIUM	<	2.71 µg/l	200
21/10/2021	ALUMINIUM	<	2.71 µg/l	200
26/10/2021	ALUMINIUM	<	2.71 µg/l	200
03/11/2021	ALUMINIUM	<	2.71 µg/l	200
05/11/2021	ALUMINIUM	<	2.71 µg/l	200
13/11/2021	ALUMINIUM	<	2.71 µg/l	200
16/11/2021	ALUMINIUM		3.38 µg/l	200
18/11/2021	ALUMINIUM	<	2.71 µg/l	200
23/11/2021	ALUMINIUM		2.82 µg/l	200
25/11/2021	ALUMINIUM		11.2 µg/l	200
29/11/2021	ALUMINIUM		3.79 µg/l	200
06/12/2021	ALUMINIUM	<	2.71 µg/l	200
07/12/2021	ALUMINIUM	<	2.71 µg/l	200
09/12/2021	ALUMINIUM	<	2.71 µg/l	200
09/12/2021	ALUMINIUM	<	2.71 µg/l	200
14/12/2021	ALUMINIUM	<	2.71 µg/l	200
15/12/2021	ALUMINIUM	<	2.71 µg/l	200
16/12/2021	ALUMINIUM	<	2.71 µg/l	200
18/12/2021	ALUMINIUM	<	2.71 µg/l	200
21/12/2021	ALUMINIUM	<	2.71 µg/l	200
22/12/2021	ALUMINIUM	<	2.71 µg/l	200

05/01/2022	ALUMINIUM	<	2.71 µg/l	200
14/01/2022	ALUMINIUM	<	2.71 µg/l	200
27/01/2022	ALUMINIUM		3.98 µg/l	200
31/01/2022	ALUMINIUM		4.75 µg/l	200
01/02/2022	ALUMINIUM		6.05 µg/l	200
09/02/2022	ALUMINIUM		4.52 µg/l	200
21/02/2022	ALUMINIUM		5.02 µg/l	200
22/02/2022	ALUMINIUM		5.51 µg/l	200
01/03/2022	ALUMINIUM		3.58 µg/l	200
04/03/2022	ALUMINIUM		18.9 µg/l	200
16/03/2022	ALUMINIUM	<	6.22 µg/l	200
22/03/2022	ALUMINIUM		3.76 µg/l	200
24/03/2022	ALUMINIUM		13.9 µg/l	200
30/03/2022	ALUMINIUM	<	6.22 µg/l	200
05/04/2022	ALUMINIUM		10.2 µg/l	200
11/04/2022	ALUMINIUM	<	6.22 µg/l	200
14/04/2022	ALUMINIUM	<	6.22 µg/l	200
19/04/2022	ALUMINIUM	<	6.22 µg/l	200
20/04/2022	ALUMINIUM	<	6.22 µg/l	200
28/04/2022	ALUMINIUM	<	6.22 µg/l	200
03/05/2022	ALUMINIUM	<	6.22 µg/l	200
10/05/2022	ALUMINIUM	<	6.22 µg/l	200
27/05/2022	ALUMINIUM	<	2.71 µg/l	200
05/06/2022	ALUMINIUM	<	2.71 µg/l	200
09/06/2022	ALUMINIUM	<	6.22 µg/l	200
13/06/2022	ALUMINIUM	<	2.71 µg/l	200
15/06/2022	ALUMINIUM	<	2.71 µg/l	200
17/06/2022	ALUMINIUM	<	6.22 µg/l	200
21/06/2022	ALUMINIUM	<	6.22 µg/l	200
01/07/2022	ALUMINIUM	<	6.22 µg/l	200
07/07/2022	ALUMINIUM	<	6.22 µg/l	200
20/07/2022	ALUMINIUM	<	2.71 µg/l	200
27/07/2022	ALUMINIUM	<	6.22 µg/l	200
09/08/2022	ALUMINIUM	<	6.22 µg/l	200
11/08/2022	ALUMINIUM	<	6.22 µg/l	200
19/08/2022	ALUMINIUM		8.06 µg/l	200
27/08/2022	ALUMINIUM		7.37 µg/l	200
07/09/2022	ALUMINIUM	<	6.22 µg/l	200
08/09/2022	ALUMINIUM	<	6.22 µg/l	200
15/09/2022	ALUMINIUM	<	6.22 µg/l	200
29/09/2022	ALUMINIUM	<	6.22 µg/l	200
04/10/2022	ALUMINIUM		7.74 µg/l	200
17/10/2022	ALUMINIUM	<	2.71 µg/l	200
03/11/2022	ALUMINIUM		8.09 µg/l	200
18/11/2022	ALUMINIUM		9.57 µg/l	200
22/11/2022	ALUMINIUM	<	6.22 µg/l	200
29/11/2022	ALUMINIUM	<	6.22 µg/l	200
30/11/2022	ALUMINIUM		20.9 µg/l	200

06/12/2022	ALUMINIUM	<	6.22 µg/l	200
12/12/2022	ALUMINIUM	<	6.22 µg/l	200
14/12/2022	ALUMINIUM	<	6.22 µg/l	200
16/12/2022	ALUMINIUM	<	6.22 µg/l	200
10/01/2023	ALUMINIUM	<	2.71 µg/l	200
17/01/2023	ALUMINIUM	<	6.22 µg/l	200
24/01/2023	ALUMINIUM	<	6.22 µg/l	200
10/02/2023	ALUMINIUM	<	6.22 µg/l	200
20/02/2023	ALUMINIUM	<	6.22 µg/l	200
22/02/2023	ALUMINIUM	<	6.22 µg/l	200
28/02/2023	ALUMINIUM	<	6.22 µg/l	200
01/03/2023	ALUMINIUM	<	6.22 µg/l	200
08/03/2023	ALUMINIUM	<	6.22 µg/l	200
14/03/2023	ALUMINIUM	<	6.22 µg/l	200
22/03/2023	ALUMINIUM	<	6.22 µg/l	200
31/03/2023	ALUMINIUM	<	6.22 µg/l	200
05/04/2023	ALUMINIUM	<	6.22 µg/l	200
06/04/2023	ALUMINIUM	<	6.22 µg/l	200
11/04/2023	ALUMINIUM	<	6.22 µg/l	200
21/04/2023	ALUMINIUM	<	6.22 µg/l	200
25/04/2023	ALUMINIUM	<	6.22 µg/l	200
05/05/2023	ALUMINIUM	<	6.22 µg/l	200
10/05/2023	ALUMINIUM	<	6.22 µg/l	200
13/05/2023	ALUMINIUM	<	6.22 µg/l	200
20/05/2023	ALUMINIUM		3.41 µg/l	200
30/05/2023	ALUMINIUM		3.44 µg/l	200
07/06/2023	ALUMINIUM	<	6.22 µg/l	200
14/06/2023	ALUMINIUM	<	6.22 µg/l	200
28/06/2023	ALUMINIUM	<	2.71 µg/l	200
05/07/2023	ALUMINIUM	<	6.22 µg/l	200
11/07/2023	ALUMINIUM	<	6.22 µg/l	200
12/07/2023	ALUMINIUM	<	6.22 µg/l	200
17/07/2023	ALUMINIUM		6.57 µg/l	200
28/07/2023	ALUMINIUM	<	6.22 µg/l	200
31/07/2023	ALUMINIUM	<	6.22 µg/l	200
07/08/2023	ALUMINIUM	<	6.22 µg/l	200
10/08/2023	ALUMINIUM	<	6.22 µg/l	200
24/08/2023	ALUMINIUM		4.49 µg/l	200
02/09/2023	ALUMINIUM	<	6.22 µg/l	200
04/09/2023	ALUMINIUM	<	6.22 µg/l	200
14/09/2023	ALUMINIUM		3.08 µg/l	200
22/09/2023	ALUMINIUM	<	6.22 µg/l	200
04/10/2023	ALUMINIUM	<	6.22 µg/l	200
14/10/2023	ALUMINIUM	<	6.22 µg/l	200
20/10/2023	ALUMINIUM		7.7 µg/l	200
04/11/2023	ALUMINIUM		11.3 µg/l	200
06/11/2023	ALUMINIUM		6.82 µg/l	200
14/11/2023	ALUMINIUM		11.7 µg/l	200

15/11/2023	ALUMINIUM	<	6.22 µg/l	200
16/11/2023	ALUMINIUM	<	6.22 µg/l	200
17/11/2023	ALUMINIUM	<	6.22 µg/l	200
23/11/2023	ALUMINIUM	<	6.22 µg/l	200
04/12/2023	ALUMINIUM	<	6.22 µg/l	200
15/12/2023	ALUMINIUM	<	2.71 µg/l	200
18/12/2023	ALUMINIUM	<	2.71 µg/l	200
19/12/2023	ALUMINIUM	<	6.22 µg/l	200
21/12/2023	ALUMINIUM	<	6.22 µg/l	200
22/12/2023	ALUMINIUM	<	6.22 µg/l	200
06/01/2024	ALUMINIUM	<	6.22 µg/l	200
08/01/2024	ALUMINIUM	<	6.22 µg/l	200
11/01/2024	ALUMINIUM	<	2.71 µg/l	200
15/01/2024	ALUMINIUM	<	6.22 µg/l	200
19/01/2024	ALUMINIUM	<	2.71 µg/l	200
27/01/2024	ALUMINIUM	<	6.22 µg/l	200
01/02/2024	ALUMINIUM	<	6.22 µg/l	200
06/02/2024	ALUMINIUM	<	2.71 µg/l	200
12/02/2024	ALUMINIUM	<	2.71 µg/l	200
19/02/2024	ALUMINIUM	<	2.71 µg/l	200
07/03/2024	ALUMINIUM		3.73 µg/l	200
13/03/2024	ALUMINIUM	<	6.22 µg/l	200
15/03/2024	ALUMINIUM	<	2.71 µg/l	200
20/03/2024	ALUMINIUM	<	6.22 µg/l	200
26/03/2024	ALUMINIUM	<	6.22 µg/l	200
04/04/2024	ALUMINIUM	<	2.71 µg/l	200
11/04/2024	ALUMINIUM	<	6.22 µg/l	200
19/04/2024	ALUMINIUM	<	6.22 µg/l	200
26/04/2024	ALUMINIUM	<	6.22 µg/l	200
01/05/2024	ALUMINIUM	<	6.22 µg/l	200
09/05/2024	ALUMINIUM		6.96 µg/l	200
13/05/2024	ALUMINIUM		3.46 µg/l	200
24/05/2024	ALUMINIUM	<	6.22 µg/l	200
28/05/2024	ALUMINIUM	<	6.22 µg/l	200
07/06/2024	ALUMINIUM	<	6.22 µg/l	200
13/06/2024	ALUMINIUM	<	6.22 µg/l	200
18/06/2024	ALUMINIUM	<	6.22 µg/l	200
25/06/2024	ALUMINIUM	<	6.22 µg/l	200
02/07/2024	ALUMINIUM		7.37 µg/l	200
17/07/2024	ALUMINIUM	<	6.22 µg/l	200
24/07/2024	ALUMINIUM	<	6.22 µg/l	200
26/07/2024	ALUMINIUM	<	6.22 µg/l	200
07/08/2024	ALUMINIUM		4.47 µg/l	200
09/08/2024	ALUMINIUM	<	6.22 µg/l	200
16/08/2024	ALUMINIUM	<	6.22 µg/l	200
29/08/2024	ALUMINIUM		3.02 µg/l	200
30/08/2024	ALUMINIUM	<	6.22 µg/l	200
03/09/2024	ALUMINIUM	<	6.22 µg/l	200

04/09/2024	ALUMINIUM	<	6.22 µg/l	200
17/09/2024	ALUMINIUM	<	6.22 µg/l	200
27/09/2024	ALUMINIUM	<	2.71 µg/l	200
10/10/2024	ALUMINIUM	<	6.22 µg/l	200
16/10/2024	ALUMINIUM	<	6.22 µg/l	200
21/10/2024	ALUMINIUM		3.77 µg/l	200
25/10/2024	ALUMINIUM		8.36 µg/l	200
07/11/2024	ALUMINIUM	<	2.71 µg/l	200
15/11/2024	ALUMINIUM	<	2.71 µg/l	200
18/11/2024	ALUMINIUM	<	6.22 µg/l	200
25/11/2024	ALUMINIUM	<	6.22 µg/l	200
28/11/2024	ALUMINIUM		8.12 µg/l	200
03/12/2024	ALUMINIUM	<	6.22 µg/l	200
10/12/2024	ALUMINIUM		8.06 µg/l	200
21/12/2024	ALUMINIUM	<	6.22 µg/l	200
02/01/2025	ALUMINIUM	<	6.22 µg/l	200
22/01/2025	ALUMINIUM	<	6.22 µg/l	200
29/01/2025	ALUMINIUM	<	2.71 µg/l	200
30/01/2025	ALUMINIUM	<	2.71 µg/l	200
04/02/2025	ALUMINIUM	<	6.22 µg/l	200
14/02/2025	ALUMINIUM	<	2.71 µg/l	200
27/02/2025	ALUMINIUM	<	2.71 µg/l	200
17/03/2025	ALUMINIUM	<	6.22 µg/l	200
21/03/2025	ALUMINIUM	<	2.71 µg/l	200
25/03/2025	ALUMINIUM	<	6.22 µg/l	200
05/04/2025	ALUMINIUM	<	6.22 µg/l	200
10/04/2025	ALUMINIUM	<	6.22 µg/l	200
16/04/2025	ALUMINIUM	<	2.71 µg/l	200
24/04/2025	ALUMINIUM	<	6.22 µg/l	200
29/04/2025	ALUMINIUM	<	6.22 µg/l	200
07/05/2025	ALUMINIUM		7.24 µg/l	200
14/05/2025	ALUMINIUM	<	6.22 µg/l	200
17/05/2025	ALUMINIUM		8.3 µg/l	200
05/06/2025	ALUMINIUM	<	6.22 µg/l	200
13/06/2025	ALUMINIUM	<	6.22 µg/l	200
14/06/2025	ALUMINIUM	<	6.22 µg/l	200
15/06/2025	ALUMINIUM	<	6.22 µg/l	200
17/06/2025	ALUMINIUM		3.21 µg/l	200
18/06/2025	ALUMINIUM	<	6.22 µg/l	200
20/06/2025	ALUMINIUM	<	6.22 µg/l	200
27/06/2025	ALUMINIUM		3.86 µg/l	200
04/07/2025	ALUMINIUM	<	6.22 µg/l	200
09/07/2025	ALUMINIUM	<	6.22 µg/l	200
10/07/2025	ALUMINIUM	<	6.22 µg/l	200
23/07/2025	ALUMINIUM	<	6.22 µg/l	200
01/08/2025	ALUMINIUM	<	6.22 µg/l	200
07/08/2025	ALUMINIUM	<	6.22 µg/l	200
08/08/2025	ALUMINIUM	<	6.22 µg/l	200

03/09/2025	ALUMINIUM	<	6.22 µg/l	200
06/09/2025	ALUMINIUM	<	6.22 µg/l	200
12/09/2025	ALUMINIUM		20 µg/l	200
01/10/2025	ALUMINIUM		10.3 µg/l	200
06/10/2025	ALUMINIUM		2.89 µg/l	200
08/10/2025	ALUMINIUM		8.64 µg/l	200
14/10/2025	ALUMINIUM		9.22 µg/l	200
15/10/2025	ALUMINIUM	<	6.22 µg/l	200
22/10/2025	ALUMINIUM		7.29 µg/l	200
23/10/2025	ALUMINIUM	<	6.22 µg/l	200
24/10/2025	ALUMINIUM	<	6.22 µg/l	200
28/10/2025	ALUMINIUM	<	2.71 µg/l	200
05/11/2025	ALUMINIUM	<	6.22 µg/l	200
12/11/2025	ALUMINIUM	<	2.71 µg/l	200
18/11/2025	ALUMINIUM		10.2 µg/l	200
24/11/2025	ALUMINIUM	<	6.22 µg/l	200
03/12/2025	ALUMINIUM		3.02 µg/l	200
09/12/2025	ALUMINIUM		11 µg/l	200
15/12/2025	ALUMINIUM	<	2.71 µg/l	200
09/01/2026	ALUMINIUM	<	6.22 µg/l	200
15/01/2026	ALUMINIUM	<	2.71 µg/l	200
20/01/2026	ALUMINIUM	<	6.22 µg/l	200
29/01/2026	ALUMINIUM	<	6.22 µg/l	200
30/01/2026	ALUMINIUM	<	6.22 µg/l	200
02/02/2026	ALUMINIUM	<	6.22 µg/l	200
11/02/2026	ALUMINIUM	<	6.22 µg/l	200
17/02/2026	ALUMINIUM	<	6.22 µg/l	200
21/03/2021	AMMONIA as N	<	0.012 mg/l	0.5
25/03/2021	AMMONIA as N	<	0.012 mg/l	0.5
01/04/2021	AMMONIA as N	<	0.012 mg/l	0.5
19/05/2021	AMMONIA as N	<	0.037 mg/l	0.5
14/06/2021	AMMONIA as N	<	0.037 mg/l	0.5
08/07/2021	AMMONIA as N	<	0.012 mg/l	0.5
06/08/2021	AMMONIA as N	<	0.012 mg/l	0.5
07/08/2021	AMMONIA as N	<	0.037 mg/l	0.5
25/08/2021	AMMONIA as N	<	0.037 mg/l	0.5
28/09/2021	AMMONIA as N	<	0.012 mg/l	0.5
05/10/2021	AMMONIA as N	<	0.037 mg/l	0.5
13/10/2021	AMMONIA as N	<	0.012 mg/l	0.5
17/10/2021	AMMONIA as N	<	0.037 mg/l	0.5
02/12/2021	AMMONIA as N	<	0.037 mg/l	0.5
09/12/2021	AMMONIA as N	<	0.037 mg/l	0.5
14/12/2021	AMMONIA as N	<	0.037 mg/l	0.5
21/12/2021	AMMONIA as N	<	0.012 mg/l	0.5
11/02/2022	AMMONIA as N	<	0.012 mg/l	0.5
21/03/2022	AMMONIA as N	<	0.012 mg/l	0.5
24/05/2022	AMMONIA as N	<	0.012 mg/l	0.5
14/06/2022	AMMONIA as N	<	0.012 mg/l	0.5

15/06/2022	AMMONIA as N	<	0.012 mg/l	0.5
07/07/2022	AMMONIA as N	<	0.012 mg/l	0.5
29/09/2022	AMMONIA as N	<	0.012 mg/l	0.5
24/11/2022	AMMONIA as N	<	0.012 mg/l	0.5
05/12/2022	AMMONIA as N	<	0.012 mg/l	0.5
02/02/2023	AMMONIA as N	<	0.012 mg/l	0.5
22/02/2023	AMMONIA as N	<	0.012 mg/l	0.5
25/04/2023	AMMONIA as N	<	0.012 mg/l	0.5
19/07/2023	AMMONIA as N	<	0.025 mg/l	0.5
03/08/2023	AMMONIA as N	<	0.025 mg/l	0.5
21/08/2023	AMMONIA as N	<	0.042 mg/l	0.5
04/10/2023	AMMONIA as N	<	0.025 mg/l	0.5
15/12/2023	AMMONIA as N	<	0.042 mg/l	0.5
18/12/2023	AMMONIA as N	<	0.042 mg/l	0.5
22/12/2023	AMMONIA as N	<	0.042 mg/l	0.5
03/01/2024	AMMONIA as N	<	0.042 mg/l	0.5
08/02/2024	AMMONIA as N	<	0.042 mg/l	0.5
13/03/2024	AMMONIA as N	<	0.042 mg/l	0.5
11/04/2024	AMMONIA as N	<	0.042 mg/l	0.5
13/06/2024	AMMONIA as N	<	0.025 mg/l	0.5
30/08/2024	AMMONIA as N	<	0.025 mg/l	0.5
09/10/2024	AMMONIA as N	<	0.042 mg/l	0.5
13/11/2024	AMMONIA as N	<	0.042 mg/l	0.5
28/01/2025	AMMONIA as N	<	0.042 mg/l	0.5
24/02/2025	AMMONIA as N	<	0.025 mg/l	0.5
08/04/2025	AMMONIA as N	<	0.042 mg/l	0.5
17/06/2025	AMMONIA as N	<	0.025 mg/l	0.5
30/07/2025	AMMONIA as N	<	0.042 mg/l	0.5
06/09/2025	AMMONIA as N	<	0.025 mg/l	0.5
09/12/2025	AMMONIA as N	<	0.025 mg/l	0.5
18/12/2025	AMMONIA as N	<	0.042 mg/l	0.5
05/02/2026	AMMONIA as N	<	0.042 mg/l	0.5
26/03/2021	ANTIMONY	<	0.44 µg/l	5
07/04/2021	ANTIMONY	<	0.44 µg/l	5
07/06/2021	ANTIMONY	<	0.44 µg/l	5
08/06/2021	ANTIMONY	<	0.44 µg/l	5
01/07/2021	ANTIMONY	<	0.44 µg/l	5
06/12/2021	ANTIMONY	<	0.44 µg/l	5
14/12/2021	ANTIMONY	<	0.44 µg/l	5
22/12/2021	ANTIMONY	<	0.31 µg/l	5
07/01/2022	ANTIMONY	<	0.44 µg/l	5
04/03/2022	ANTIMONY	<	0.31 µg/l	5
08/04/2022	ANTIMONY	<	0.31 µg/l	5
04/05/2022	ANTIMONY	<	0.31 µg/l	5
28/06/2022	ANTIMONY	<	0.31 µg/l	5
10/08/2022	ANTIMONY	<	0.31 µg/l	5
07/09/2022	ANTIMONY	<	0.31 µg/l	5
10/11/2022	ANTIMONY	<	0.31 µg/l	5

27/01/2023	ANTIMONY	<	0.31 µg/l	5
24/02/2023	ANTIMONY	<	0.31 µg/l	5
10/05/2023	ANTIMONY	<	0.31 µg/l	5
30/05/2023	ANTIMONY	<	0.31 µg/l	5
14/07/2023	ANTIMONY	<	0.31 µg/l	5
31/10/2023	ANTIMONY	<	0.31 µg/l	5
16/11/2023	ANTIMONY	<	0.31 µg/l	5
23/11/2023	ANTIMONY	<	0.31 µg/l	5
05/01/2024	ANTIMONY	<	0.31 µg/l	5
06/02/2024	ANTIMONY	<	0.31 µg/l	5
26/03/2024	ANTIMONY	<	0.31 µg/l	5
15/05/2024	ANTIMONY	<	0.31 µg/l	5
07/08/2024	ANTIMONY	<	0.31 µg/l	5
26/09/2024	ANTIMONY	<	0.31 µg/l	5
09/10/2024	ANTIMONY	<	0.31 µg/l	5
21/11/2024	ANTIMONY	<	0.31 µg/l	5
12/02/2025	ANTIMONY	<	0.31 µg/l	5
21/03/2025	ANTIMONY	<	0.31 µg/l	5
07/05/2025	ANTIMONY	<	0.31 µg/l	5
09/06/2025	ANTIMONY	<	0.31 µg/l	5
29/09/2025	ANTIMONY	<	0.31 µg/l	5
22/10/2025	ANTIMONY	<	0.31 µg/l	5
24/11/2025	ANTIMONY	<	0.33 µg/l	5
22/12/2025	ANTIMONY	<	0.31 µg/l	5
28/01/2026	ANTIMONY	<	0.31 µg/l	5
26/03/2021	ARSENIC	<	0.09 µg/l	10
07/04/2021	ARSENIC	<	0.09 µg/l	10
02/06/2021	ARSENIC		0.17 µg/l	10
14/07/2021	ARSENIC	<	0.09 µg/l	10
21/07/2021	ARSENIC	<	0.09 µg/l	10
25/08/2021	ARSENIC	<	0.48 µg/l	10
14/12/2021	ARSENIC	<	0.09 µg/l	10
22/12/2021	ARSENIC	<	0.48 µg/l	10
07/01/2022	ARSENIC	<	0.09 µg/l	10
04/03/2022	ARSENIC	<	0.48 µg/l	10
08/04/2022	ARSENIC	<	0.48 µg/l	10
04/05/2022	ARSENIC	<	0.48 µg/l	10
28/06/2022	ARSENIC	<	0.48 µg/l	10
10/08/2022	ARSENIC	<	0.48 µg/l	10
07/09/2022	ARSENIC	<	0.48 µg/l	10
10/11/2022	ARSENIC	<	0.48 µg/l	10
27/01/2023	ARSENIC	<	0.48 µg/l	10
24/02/2023	ARSENIC	<	0.48 µg/l	10
10/05/2023	ARSENIC	<	0.48 µg/l	10
30/05/2023	ARSENIC	<	0.48 µg/l	10
14/07/2023	ARSENIC	<	0.48 µg/l	10
31/10/2023	ARSENIC	<	0.48 µg/l	10
16/11/2023	ARSENIC	<	0.48 µg/l	10

23/11/2023	ARSENIC	<	0.48 µg/l	10
05/01/2024	ARSENIC	<	0.48 µg/l	10
06/02/2024	ARSENIC	<	0.48 µg/l	10
26/03/2024	ARSENIC	<	0.48 µg/l	10
15/05/2024	ARSENIC	<	0.48 µg/l	10
07/08/2024	ARSENIC	<	0.48 µg/l	10
26/09/2024	ARSENIC	<	0.48 µg/l	10
09/10/2024	ARSENIC	<	0.48 µg/l	10
21/11/2024	ARSENIC	<	0.48 µg/l	10
12/02/2025	ARSENIC	<	0.48 µg/l	10
21/03/2025	ARSENIC	<	0.48 µg/l	10
07/05/2025	ARSENIC	<	0.48 µg/l	10
09/06/2025	ARSENIC	<	0.48 µg/l	10
29/09/2025	ARSENIC	<	0.48 µg/l	10
22/10/2025	ARSENIC	<	0.48 µg/l	10
24/11/2025	ARSENIC	<	0.48 µg/l	10
22/12/2025	ARSENIC	<	0.48 µg/l	10
28/01/2026	ARSENIC	<	0.48 µg/l	10
09/04/2021	BENZO A PYRENE	<	0.002 µg/l	0.01
18/04/2021	BENZO A PYRENE	<	0.002 µg/l	0.01
21/05/2021	BENZO A PYRENE	<	0.002 µg/l	0.01
07/06/2021	BENZO A PYRENE	<	0.002 µg/l	0.01
15/06/2021	BENZO A PYRENE	<	0.002 µg/l	0.01
31/07/2021	BENZO A PYRENE	<	0.002 µg/l	0.01
27/08/2021	BENZO A PYRENE	<	0.002 µg/l	0.01
09/09/2021	BENZO A PYRENE	<	0.002 µg/l	0.01
08/12/2021	BENZO A PYRENE	<	0.002 µg/l	0.01
31/01/2022	BENZO A PYRENE	<	0.002 µg/l	0.01
18/02/2022	BENZO A PYRENE	<	0.002 µg/l	0.01
02/03/2022	BENZO A PYRENE	<	0.002 µg/l	0.01
10/05/2022	BENZO A PYRENE	<	0.002 µg/l	0.01
09/06/2022	BENZO A PYRENE	<	0.002 µg/l	0.01
29/07/2022	BENZO A PYRENE	<	0.002 µg/l	0.01
08/09/2022	BENZO A PYRENE	<	0.002 µg/l	0.01
15/11/2022	BENZO A PYRENE	<	0.002 µg/l	0.01
10/01/2023	BENZO A PYRENE	<	0.002 µg/l	0.01
02/05/2023	BENZO A PYRENE	<	0.002 µg/l	0.01
01/06/2023	BENZO A PYRENE	<	0.002 µg/l	0.01
17/07/2023	BENZO A PYRENE	<	0.002 µg/l	0.01
14/10/2023	BENZO A PYRENE	<	0.002 µg/l	0.01
10/11/2023	BENZO A PYRENE	<	0.002 µg/l	0.01
17/11/2023	BENZO A PYRENE	<	0.002 µg/l	0.01
28/11/2023	BENZO A PYRENE	<	0.002 µg/l	0.01
03/01/2024	BENZO A PYRENE	<	0.002 µg/l	0.01
23/02/2024	BENZO A PYRENE	<	0.002 µg/l	0.01
26/03/2024	BENZO A PYRENE	<	0.002 µg/l	0.01
04/04/2024	BENZO A PYRENE	<	0.002 µg/l	0.01
27/08/2024	BENZO A PYRENE	<	0.002 µg/l	0.01

24/09/2024	BENZO A PYRENE	<	0.002 µg/l	0.01
03/10/2024	BENZO A PYRENE	<	0.002 µg/l	0.01
11/10/2024	BENZO A PYRENE	<	0.002 µg/l	0.01
12/02/2025	BENZO A PYRENE	<	0.002 µg/l	0.01
01/05/2025	BENZO A PYRENE	<	0.002 µg/l	0.01
12/06/2025	BENZO A PYRENE	<	0.002 µg/l	0.01
14/06/2025	BENZO A PYRENE	<	0.002 µg/l	0.01
07/08/2025	BENZO A PYRENE	<	0.002 µg/l	0.01
01/10/2025	BENZO A PYRENE	<	0.002 µg/l	0.01
11/12/2025	BENZO A PYRENE		0.005 µg/l	0.01
16/12/2025	BENZO A PYRENE	<	0.002 µg/l	0.01
21/01/2026	BENZO A PYRENE	<	0.002 µg/l	0.01
20/03/2021	BROMATE ION		0.24 µg/l	10
26/03/2021	BROMATE ION		0.54 µg/l	10
11/05/2021	BROMATE ION		0.23 µg/l	10
15/06/2021	BROMATE ION		0.32 µg/l	10
23/06/2021	BROMATE ION		0.49 µg/l	10
09/09/2021	BROMATE ION		1.18 µg/l	10
20/10/2021	BROMATE ION	<	0.12 µg/l	10
22/10/2021	BROMATE ION	<	0.12 µg/l	10
25/11/2021	BROMATE ION	<	0.12 µg/l	10
14/01/2022	BROMATE ION	<	0.12 µg/l	10
19/04/2022	BROMATE ION	<	0.12 µg/l	10
25/04/2022	BROMATE ION	<	0.12 µg/l	10
20/06/2022	BROMATE ION		0.15 µg/l	10
06/07/2022	BROMATE ION	<	0.12 µg/l	10
20/09/2022	BROMATE ION	<	0.12 µg/l	10
03/11/2022	BROMATE ION	<	0.12 µg/l	10
28/11/2022	BROMATE ION		0.58 µg/l	10
14/12/2022	BROMATE ION		0.55 µg/l	10
23/12/2022	BROMATE ION	<	0.33 µg/l	10
07/02/2023	BROMATE ION	<	0.34 µg/l	10
20/02/2023	BROMATE ION		0.48 µg/l	10
08/06/2023	BROMATE ION		0.7 µg/l	10
13/07/2023	BROMATE ION		0.36 µg/l	10
17/08/2023	BROMATE ION		0.65 µg/l	10
14/10/2023	BROMATE ION		0.54 µg/l	10
28/10/2023	BROMATE ION	<	0.33 µg/l	10
06/11/2023	BROMATE ION		0.7 µg/l	10
20/11/2023	BROMATE ION	<	0.34 µg/l	10
29/11/2023	BROMATE ION		0.74 µg/l	10
04/01/2024	BROMATE ION		0.42 µg/l	10
05/01/2024	BROMATE ION	<	0.34 µg/l	10
12/03/2024	BROMATE ION		0.44 µg/l	10
26/04/2024	BROMATE ION		0.74 µg/l	10
11/06/2024	BROMATE ION		0.46 µg/l	10
13/08/2024	BROMATE ION		0.43 µg/l	10
28/08/2024	BROMATE ION		0.76 µg/l	10

23/10/2024	BROMATE ION		0.65 µg/l	10
22/01/2025	BROMATE ION		0.66 µg/l	10
12/05/2025	BROMATE ION		0.9 µg/l	10
14/06/2025	BROMATE ION	<	0.64 µg/l	10
09/07/2025	BROMATE ION		1.03 µg/l	10
15/07/2025	BROMATE ION		1.16 µg/l	10
01/10/2025	BROMATE ION	<	0.64 µg/l	10
24/10/2025	BROMATE ION		0.84 µg/l	10
09/12/2025	BROMATE ION	<	0.64 µg/l	10
26/03/2021	CADMIUM	<	0.1 µg/l	5
07/04/2021	CADMIUM	<	0.1 µg/l	5
04/06/2021	CADMIUM	<	0.1 µg/l	5
14/07/2021	CADMIUM	<	0.1 µg/l	5
18/10/2021	CADMIUM	<	0.09 µg/l	5
06/12/2021	CADMIUM	<	0.1 µg/l	5
14/12/2021	CADMIUM	<	0.1 µg/l	5
22/12/2021	CADMIUM	<	0.09 µg/l	5
07/01/2022	CADMIUM	<	0.09 µg/l	5
04/03/2022	CADMIUM	<	0.09 µg/l	5
08/04/2022	CADMIUM	<	0.09 µg/l	5
04/05/2022	CADMIUM	<	0.09 µg/l	5
28/06/2022	CADMIUM	<	0.09 µg/l	5
10/08/2022	CADMIUM	<	0.09 µg/l	5
07/09/2022	CADMIUM	<	0.09 µg/l	5
10/11/2022	CADMIUM	<	0.09 µg/l	5
27/01/2023	CADMIUM	<	0.09 µg/l	5
24/02/2023	CADMIUM	<	0.09 µg/l	5
10/05/2023	CADMIUM	<	0.09 µg/l	5
30/05/2023	CADMIUM	<	0.09 µg/l	5
14/07/2023	CADMIUM	<	0.09 µg/l	5
31/10/2023	CADMIUM	<	0.09 µg/l	5
16/11/2023	CADMIUM	<	0.09 µg/l	5
23/11/2023	CADMIUM	<	0.09 µg/l	5
05/01/2024	CADMIUM	<	0.09 µg/l	5
06/02/2024	CADMIUM	<	0.09 µg/l	5
26/03/2024	CADMIUM	<	0.09 µg/l	5
15/05/2024	CADMIUM	<	0.09 µg/l	5
07/08/2024	CADMIUM		0.13 µg/l	5
26/09/2024	CADMIUM	<	0.09 µg/l	5
09/10/2024	CADMIUM	<	0.09 µg/l	5
21/11/2024	CADMIUM	<	0.09 µg/l	5
12/02/2025	CADMIUM	<	0.09 µg/l	5
21/03/2025	CADMIUM	<	0.09 µg/l	5
07/05/2025	CADMIUM	<	0.09 µg/l	5
09/06/2025	CADMIUM	<	0.09 µg/l	5
29/09/2025	CADMIUM	<	0.09 µg/l	5
22/10/2025	CADMIUM	<	0.09 µg/l	5
24/11/2025	CADMIUM	<	0.09 µg/l	5

22/12/2025	CADMIUM	<	0.09 µg/l		5
28/01/2026	CADMIUM	<	0.09 µg/l		5
03/03/2021	Calcium		7.48 mg/l	No regulatory limit	
20/03/2021	Calcium		6.94 mg/l	No regulatory limit	
26/03/2021	Calcium		7.3 mg/l	No regulatory limit	
30/03/2021	Calcium		7.11 mg/l	No regulatory limit	
31/03/2021	Calcium		7.44 mg/l	No regulatory limit	
08/04/2021	Calcium		7.51 mg/l	No regulatory limit	
09/04/2021	Calcium		7.76 mg/l	No regulatory limit	
10/04/2021	Calcium		7.36 mg/l	No regulatory limit	
23/04/2021	Calcium		9.7 mg/l	No regulatory limit	
08/05/2021	Calcium		8.01 mg/l	No regulatory limit	
11/05/2021	Calcium		8.17 mg/l	No regulatory limit	
29/05/2021	Calcium		8.63 mg/l	No regulatory limit	
30/05/2021	Calcium		8.47 mg/l	No regulatory limit	
04/06/2021	Calcium		8.44 mg/l	No regulatory limit	
07/06/2021	Calcium		9.57 mg/l	No regulatory limit	
09/06/2021	Calcium		8.28 mg/l	No regulatory limit	
01/07/2021	Calcium		10.2 mg/l	No regulatory limit	
02/07/2021	Calcium		8.88 mg/l	No regulatory limit	
06/07/2021	Calcium		8.84 mg/l	No regulatory limit	
12/07/2021	Calcium		8.76 mg/l	No regulatory limit	
22/07/2021	Calcium		9.44 mg/l	No regulatory limit	
26/07/2021	Calcium		10.1 mg/l	No regulatory limit	
03/08/2021	Calcium		9.42 mg/l	No regulatory limit	
06/08/2021	Calcium		10 mg/l	No regulatory limit	
08/08/2021	Calcium		9.83 mg/l	No regulatory limit	
27/08/2021	Calcium		13.9 mg/l	No regulatory limit	
01/09/2021	Calcium		9.9 mg/l	No regulatory limit	
09/09/2021	Calcium		9.76 mg/l	No regulatory limit	
24/09/2021	Calcium		10.4 mg/l	No regulatory limit	
28/09/2021	Calcium		10.4 mg/l	No regulatory limit	
30/09/2021	Calcium		11 mg/l	No regulatory limit	
04/10/2021	Calcium		10.6 mg/l	No regulatory limit	
17/10/2021	Calcium		10 mg/l	No regulatory limit	
21/10/2021	Calcium		10.2 mg/l	No regulatory limit	
26/10/2021	Calcium		10.1 mg/l	No regulatory limit	
03/11/2021	Calcium		9.08 mg/l	No regulatory limit	
05/11/2021	Calcium		9.49 mg/l	No regulatory limit	
13/11/2021	Calcium		10.6 mg/l	No regulatory limit	
16/11/2021	Calcium		10.5 mg/l	No regulatory limit	
18/11/2021	Calcium		9.19 mg/l	No regulatory limit	
23/11/2021	Calcium		9.33 mg/l	No regulatory limit	
25/11/2021	Calcium		10.6 mg/l	No regulatory limit	
29/11/2021	Calcium		9.11 mg/l	No regulatory limit	
06/12/2021	Calcium		9.06 mg/l	No regulatory limit	
07/12/2021	Calcium		9.83 mg/l	No regulatory limit	
09/12/2021	Calcium		8.71 mg/l	No regulatory limit	

09/12/2021	Calcium	9.58 mg/l	No regulatory limit
14/12/2021	Calcium	8.21 mg/l	No regulatory limit
15/12/2021	Calcium	8.63 mg/l	No regulatory limit
16/12/2021	Calcium	8.65 mg/l	No regulatory limit
18/12/2021	Calcium	8.94 mg/l	No regulatory limit
21/12/2021	Calcium	8.9 mg/l	No regulatory limit
22/12/2021	Calcium	8.44 mg/l	No regulatory limit
05/01/2022	Calcium	8.5 mg/l	No regulatory limit
14/01/2022	Calcium	8.32 mg/l	No regulatory limit
27/01/2022	Calcium	8.6 mg/l	No regulatory limit
31/01/2022	Calcium	8.47 mg/l	No regulatory limit
01/02/2022	Calcium	10.7 mg/l	No regulatory limit
09/02/2022	Calcium	8.5 mg/l	No regulatory limit
21/02/2022	Calcium	7.57 mg/l	No regulatory limit
22/02/2022	Calcium	7.36 mg/l	No regulatory limit
01/03/2022	Calcium	7.2 mg/l	No regulatory limit
04/03/2022	Calcium	7.77 mg/l	No regulatory limit
16/03/2022	Calcium	7.68 mg/l	No regulatory limit
22/03/2022	Calcium	8.34 mg/l	No regulatory limit
24/03/2022	Calcium	7.87 mg/l	No regulatory limit
30/03/2022	Calcium	7.46 mg/l	No regulatory limit
05/04/2022	Calcium	10.8 mg/l	No regulatory limit
11/04/2022	Calcium	7.48 mg/l	No regulatory limit
14/04/2022	Calcium	7.96 mg/l	No regulatory limit
19/04/2022	Calcium	7.88 mg/l	No regulatory limit
20/04/2022	Calcium	7.6 mg/l	No regulatory limit
28/04/2022	Calcium	8.05 mg/l	No regulatory limit
03/05/2022	Calcium	8.17 mg/l	No regulatory limit
10/05/2022	Calcium	7.93 mg/l	No regulatory limit
27/05/2022	Calcium	8.37 mg/l	No regulatory limit
05/06/2022	Calcium	8.52 mg/l	No regulatory limit
09/06/2022	Calcium	8.93 mg/l	No regulatory limit
13/06/2022	Calcium	8.83 mg/l	No regulatory limit
15/06/2022	Calcium	9.75 mg/l	No regulatory limit
17/06/2022	Calcium	9.43 mg/l	No regulatory limit
21/06/2022	Calcium	9.28 mg/l	No regulatory limit
01/07/2022	Calcium	11.1 mg/l	No regulatory limit
07/07/2022	Calcium	9.96 mg/l	No regulatory limit
20/07/2022	Calcium	10.8 mg/l	No regulatory limit
27/07/2022	Calcium	10.2 mg/l	No regulatory limit
09/08/2022	Calcium	10.6 mg/l	No regulatory limit
11/08/2022	Calcium	10.8 mg/l	No regulatory limit
19/08/2022	Calcium	10.3 mg/l	No regulatory limit
27/08/2022	Calcium	11.4 mg/l	No regulatory limit
07/09/2022	Calcium	11.7 mg/l	No regulatory limit
08/09/2022	Calcium	9.38 mg/l	No regulatory limit
15/09/2022	Calcium	9.96 mg/l	No regulatory limit
29/09/2022	Calcium	10.9 mg/l	No regulatory limit

04/10/2022	Calcium	13.1 mg/l	No regulatory limit
17/10/2022	Calcium	9.36 mg/l	No regulatory limit
03/11/2022	Calcium	9.56 mg/l	No regulatory limit
18/11/2022	Calcium	11.1 mg/l	No regulatory limit
22/11/2022	Calcium	8.05 mg/l	No regulatory limit
29/11/2022	Calcium	7.7 mg/l	No regulatory limit
30/11/2022	Calcium	11.2 mg/l	No regulatory limit
06/12/2022	Calcium	8.4 mg/l	No regulatory limit
12/12/2022	Calcium	7.89 mg/l	No regulatory limit
14/12/2022	Calcium	10.2 mg/l	No regulatory limit
16/12/2022	Calcium	8.88 mg/l	No regulatory limit
10/01/2023	Calcium	8.53 mg/l	No regulatory limit
17/01/2023	Calcium	7.4 mg/l	No regulatory limit
24/01/2023	Calcium	7.87 mg/l	No regulatory limit
10/02/2023	Calcium	8.46 mg/l	No regulatory limit
20/02/2023	Calcium	8.23 mg/l	No regulatory limit
22/02/2023	Calcium	8.35 mg/l	No regulatory limit
28/02/2023	Calcium	8.04 mg/l	No regulatory limit
01/03/2023	Calcium	7.99 mg/l	No regulatory limit
08/03/2023	Calcium	8.32 mg/l	No regulatory limit
14/03/2023	Calcium	8.33 mg/l	No regulatory limit
22/03/2023	Calcium	8.09 mg/l	No regulatory limit
31/03/2023	Calcium	8.02 mg/l	No regulatory limit
05/04/2023	Calcium	8.23 mg/l	No regulatory limit
11/04/2023	Calcium	7.9 mg/l	No regulatory limit
21/04/2023	Calcium	8.9 mg/l	No regulatory limit
25/04/2023	Calcium	7.78 mg/l	No regulatory limit
05/05/2023	Calcium	8.44 mg/l	No regulatory limit
10/05/2023	Calcium	8.33 mg/l	No regulatory limit
13/05/2023	Calcium	8.24 mg/l	No regulatory limit
20/05/2023	Calcium	8.44 mg/l	No regulatory limit
30/05/2023	Calcium	8.56 mg/l	No regulatory limit
07/06/2023	Calcium	8.95 mg/l	No regulatory limit
14/06/2023	Calcium	9.68 mg/l	No regulatory limit
28/06/2023	Calcium	9.76 mg/l	No regulatory limit
05/07/2023	Calcium	10.4 mg/l	No regulatory limit
11/07/2023	Calcium	9.92 mg/l	No regulatory limit
12/07/2023	Calcium	11.8 mg/l	No regulatory limit
17/07/2023	Calcium	11.9 mg/l	No regulatory limit
28/07/2023	Calcium	9.3 mg/l	No regulatory limit
31/07/2023	Calcium	8.82 mg/l	No regulatory limit
07/08/2023	Calcium	8.68 mg/l	No regulatory limit
10/08/2023	Calcium	8.74 mg/l	No regulatory limit
24/08/2023	Calcium	10.3 mg/l	No regulatory limit
02/09/2023	Calcium	9.41 mg/l	No regulatory limit
04/09/2023	Calcium	9.78 mg/l	No regulatory limit
14/09/2023	Calcium	9.28 mg/l	No regulatory limit
22/09/2023	Calcium	9.72 mg/l	No regulatory limit

04/10/2023	Calcium	9.06 mg/l	No regulatory limit
14/10/2023	Calcium	8.59 mg/l	No regulatory limit
20/10/2023	Calcium	8.33 mg/l	No regulatory limit
04/11/2023	Calcium	7.85 mg/l	No regulatory limit
06/11/2023	Calcium	7.88 mg/l	No regulatory limit
14/11/2023	Calcium	8.38 mg/l	No regulatory limit
15/11/2023	Calcium	8.76 mg/l	No regulatory limit
16/11/2023	Calcium	8.33 mg/l	No regulatory limit
17/11/2023	Calcium	9.33 mg/l	No regulatory limit
23/11/2023	Calcium	7.53 mg/l	No regulatory limit
04/12/2023	Calcium	9.2 mg/l	No regulatory limit
05/12/2023	Calcium	7.77 mg/l	No regulatory limit
15/12/2023	Calcium	7.52 mg/l	No regulatory limit
18/12/2023	Calcium	7.83 mg/l	No regulatory limit
19/12/2023	Calcium	8.15 mg/l	No regulatory limit
21/12/2023	Calcium	7.6 mg/l	No regulatory limit
22/12/2023	Calcium	7.53 mg/l	No regulatory limit
06/01/2024	Calcium	6.74 mg/l	No regulatory limit
08/01/2024	Calcium	7.98 mg/l	No regulatory limit
11/01/2024	Calcium	6.93 mg/l	No regulatory limit
15/01/2024	Calcium	6.82 mg/l	No regulatory limit
19/01/2024	Calcium	7.39 mg/l	No regulatory limit
27/01/2024	Calcium	6.71 mg/l	No regulatory limit
01/02/2024	Calcium	6.78 mg/l	No regulatory limit
06/02/2024	Calcium	7.47 mg/l	No regulatory limit
12/02/2024	Calcium	6.8 mg/l	No regulatory limit
19/02/2024	Calcium	7.28 mg/l	No regulatory limit
07/03/2024	Calcium	6.69 mg/l	No regulatory limit
13/03/2024	Calcium	7 mg/l	No regulatory limit
15/03/2024	Calcium	6.8 mg/l	No regulatory limit
20/03/2024	Calcium	6.79 mg/l	No regulatory limit
26/03/2024	Calcium	6.85 mg/l	No regulatory limit
04/04/2024	Calcium	6.96 mg/l	No regulatory limit
11/04/2024	Calcium	6.67 mg/l	No regulatory limit
19/04/2024	Calcium	6.67 mg/l	No regulatory limit
26/04/2024	Calcium	7.36 mg/l	No regulatory limit
01/05/2024	Calcium	6.92 mg/l	No regulatory limit
09/05/2024	Calcium	7.31 mg/l	No regulatory limit
13/05/2024	Calcium	7.02 mg/l	No regulatory limit
24/05/2024	Calcium	7.3 mg/l	No regulatory limit
28/05/2024	Calcium	7.4 mg/l	No regulatory limit
07/06/2024	Calcium	7.23 mg/l	No regulatory limit
13/06/2024	Calcium	7.6 mg/l	No regulatory limit
18/06/2024	Calcium	7.41 mg/l	No regulatory limit
25/06/2024	Calcium	7.43 mg/l	No regulatory limit
02/07/2024	Calcium	7.94 mg/l	No regulatory limit
17/07/2024	Calcium	8.78 mg/l	No regulatory limit
24/07/2024	Calcium	9.6 mg/l	No regulatory limit

26/07/2024	Calcium	9.13 mg/l	No regulatory limit
07/08/2024	Calcium	8.62 mg/l	No regulatory limit
09/08/2024	Calcium	8.85 mg/l	No regulatory limit
16/08/2024	Calcium	9.18 mg/l	No regulatory limit
29/08/2024	Calcium	10.7 mg/l	No regulatory limit
30/08/2024	Calcium	9.78 mg/l	No regulatory limit
03/09/2024	Calcium	10.3 mg/l	No regulatory limit
04/09/2024	Calcium	10.6 mg/l	No regulatory limit
17/09/2024	Calcium	10.7 mg/l	No regulatory limit
27/09/2024	Calcium	10.3 mg/l	No regulatory limit
10/10/2024	Calcium	10.5 mg/l	No regulatory limit
16/10/2024	Calcium	10.6 mg/l	No regulatory limit
21/10/2024	Calcium	10.8 mg/l	No regulatory limit
25/10/2024	Calcium	9.12 mg/l	No regulatory limit
07/11/2024	Calcium	10.9 mg/l	No regulatory limit
15/11/2024	Calcium	11 mg/l	No regulatory limit
18/11/2024	Calcium	10.9 mg/l	No regulatory limit
25/11/2024	Calcium	10.1 mg/l	No regulatory limit
28/11/2024	Calcium	9.53 mg/l	No regulatory limit
03/12/2024	Calcium	8.87 mg/l	No regulatory limit
10/12/2024	Calcium	9.18 mg/l	No regulatory limit
21/12/2024	Calcium	8.74 mg/l	No regulatory limit
02/01/2025	Calcium	8.47 mg/l	No regulatory limit
22/01/2025	Calcium	8.62 mg/l	No regulatory limit
29/01/2025	Calcium	7.96 mg/l	No regulatory limit
30/01/2025	Calcium	8.49 mg/l	No regulatory limit
04/02/2025	Calcium	7.81 mg/l	No regulatory limit
14/02/2025	Calcium	7.97 mg/l	No regulatory limit
27/02/2025	Calcium	8.21 mg/l	No regulatory limit
17/03/2025	Calcium	8.63 mg/l	No regulatory limit
21/03/2025	Calcium	8.55 mg/l	No regulatory limit
25/03/2025	Calcium	9.08 mg/l	No regulatory limit
05/04/2025	Calcium	9.44 mg/l	No regulatory limit
10/04/2025	Calcium	8.92 mg/l	No regulatory limit
16/04/2025	Calcium	9.04 mg/l	No regulatory limit
24/04/2025	Calcium	9.3 mg/l	No regulatory limit
29/04/2025	Calcium	8.42 mg/l	No regulatory limit
07/05/2025	Calcium	16.7 mg/l	No regulatory limit
14/05/2025	Calcium	8.81 mg/l	No regulatory limit
17/05/2025	Calcium	13.7 mg/l	No regulatory limit
05/06/2025	Calcium	8.56 mg/l	No regulatory limit
13/06/2025	Calcium	8.46 mg/l	No regulatory limit
14/06/2025	Calcium	8.5 mg/l	No regulatory limit
15/06/2025	Calcium	8.23 mg/l	No regulatory limit
17/06/2025	Calcium	9.57 mg/l	No regulatory limit
18/06/2025	Calcium	8.95 mg/l	No regulatory limit
20/06/2025	Calcium	8.91 mg/l	No regulatory limit
27/06/2025	Calcium	8.72 mg/l	No regulatory limit

04/07/2025	Calcium	8.83 mg/l	No regulatory limit
09/07/2025	Calcium	12.1 mg/l	No regulatory limit
10/07/2025	Calcium	9.32 mg/l	No regulatory limit
23/07/2025	Calcium	9.71 mg/l	No regulatory limit
01/08/2025	Calcium	10.3 mg/l	No regulatory limit
07/08/2025	Calcium	10.2 mg/l	No regulatory limit
08/08/2025	Calcium	10.1 mg/l	No regulatory limit
03/09/2025	Calcium	11.7 mg/l	No regulatory limit
06/09/2025	Calcium	12.1 mg/l	No regulatory limit
12/09/2025	Calcium	13.3 mg/l	No regulatory limit
01/10/2025	Calcium	10.1 mg/l	No regulatory limit
06/10/2025	Calcium	8.95 mg/l	No regulatory limit
08/10/2025	Calcium	9.23 mg/l	No regulatory limit
14/10/2025	Calcium	9.59 mg/l	No regulatory limit
15/10/2025	Calcium	9.53 mg/l	No regulatory limit
22/10/2025	Calcium	9.97 mg/l	No regulatory limit
23/10/2025	Calcium	9.26 mg/l	No regulatory limit
24/10/2025	Calcium	11.7 mg/l	No regulatory limit
28/10/2025	Calcium	8.89 mg/l	No regulatory limit
05/11/2025	Calcium	8.32 mg/l	No regulatory limit
12/11/2025	Calcium	8.43 mg/l	No regulatory limit
18/11/2025	Calcium	8.26 mg/l	No regulatory limit
24/11/2025	Calcium	7.11 mg/l	No regulatory limit
03/12/2025	Calcium	9.3 mg/l	No regulatory limit
09/12/2025	Calcium	8.4 mg/l	No regulatory limit
15/12/2025	Calcium	7.74 mg/l	No regulatory limit
09/01/2026	Calcium	8.39 mg/l	No regulatory limit
15/01/2026	Calcium	8.53 mg/l	No regulatory limit
20/01/2026	Calcium	8.97 mg/l	No regulatory limit
29/01/2026	Calcium	8.2 mg/l	No regulatory limit
30/01/2026	Calcium	7.84 mg/l	No regulatory limit
02/02/2026	Calcium	8.01 mg/l	No regulatory limit
11/02/2026	Calcium	8.06 mg/l	No regulatory limit
17/02/2026	Calcium	7.92 mg/l	No regulatory limit
03/03/2021	CHLORINE FREE	1.08 mg/l	No regulatory limit
10/03/2021	CHLORINE FREE	0.89 mg/l	No regulatory limit
11/03/2021	CHLORINE FREE	1.03 mg/l	No regulatory limit
14/03/2021	CHLORINE FREE	0.84 mg/l	No regulatory limit
19/03/2021	CHLORINE FREE	1.15 mg/l	No regulatory limit
20/03/2021	CHLORINE FREE	1.15 mg/l	No regulatory limit
21/03/2021	CHLORINE FREE	0.89 mg/l	No regulatory limit
25/03/2021	CHLORINE FREE	1.2 mg/l	No regulatory limit
26/03/2021	CHLORINE FREE	1.06 mg/l	No regulatory limit
29/03/2021	CHLORINE FREE	1.07 mg/l	No regulatory limit
30/03/2021	CHLORINE FREE	0.96 mg/l	No regulatory limit
31/03/2021	CHLORINE FREE	0.86 mg/l	No regulatory limit
01/04/2021	CHLORINE FREE	0.85 mg/l	No regulatory limit
04/04/2021	CHLORINE FREE	0.76 mg/l	No regulatory limit

07/04/2021	CHLORINE FREE	0.95 mg/l	No regulatory limit
08/04/2021	CHLORINE FREE	0.89 mg/l	No regulatory limit
09/04/2021	CHLORINE FREE	0.69 mg/l	No regulatory limit
10/04/2021	CHLORINE FREE	0.9 mg/l	No regulatory limit
16/04/2021	CHLORINE FREE	0.9 mg/l	No regulatory limit
18/04/2021	CHLORINE FREE	0.75 mg/l	No regulatory limit
19/04/2021	CHLORINE FREE	0.79 mg/l	No regulatory limit
21/04/2021	CHLORINE FREE	0.86 mg/l	No regulatory limit
22/04/2021	CHLORINE FREE	0.97 mg/l	No regulatory limit
23/04/2021	CHLORINE FREE	0.75 mg/l	No regulatory limit
25/04/2021	CHLORINE FREE	0.84 mg/l	No regulatory limit
27/04/2021	CHLORINE FREE	0.71 mg/l	No regulatory limit
06/05/2021	CHLORINE FREE	1 mg/l	No regulatory limit
08/05/2021	CHLORINE FREE	1.09 mg/l	No regulatory limit
10/05/2021	CHLORINE FREE	1.05 mg/l	No regulatory limit
11/05/2021	CHLORINE FREE	0.92 mg/l	No regulatory limit
12/05/2021	CHLORINE FREE	1.04 mg/l	No regulatory limit
14/05/2021	CHLORINE FREE	0.97 mg/l	No regulatory limit
17/05/2021	CHLORINE FREE	0.77 mg/l	No regulatory limit
19/05/2021	CHLORINE FREE	1.01 mg/l	No regulatory limit
20/05/2021	CHLORINE FREE	0.66 mg/l	No regulatory limit
21/05/2021	CHLORINE FREE	1.33 mg/l	No regulatory limit
22/05/2021	CHLORINE FREE	0.88 mg/l	No regulatory limit
25/05/2021	CHLORINE FREE	0.67 mg/l	No regulatory limit
26/05/2021	CHLORINE FREE	0.94 mg/l	No regulatory limit
27/05/2021	CHLORINE FREE	1.15 mg/l	No regulatory limit
28/05/2021	CHLORINE FREE	0.95 mg/l	No regulatory limit
29/05/2021	CHLORINE FREE	1.03 mg/l	No regulatory limit
30/05/2021	CHLORINE FREE	0.92 mg/l	No regulatory limit
02/06/2021	CHLORINE FREE	1.02 mg/l	No regulatory limit
04/06/2021	CHLORINE FREE	0.76 mg/l	No regulatory limit
07/06/2021	CHLORINE FREE	0.99 mg/l	No regulatory limit
08/06/2021	CHLORINE FREE	1.2 mg/l	No regulatory limit
09/06/2021	CHLORINE FREE	0.96 mg/l	No regulatory limit
11/06/2021	CHLORINE FREE	0.78 mg/l	No regulatory limit
14/06/2021	CHLORINE FREE	0.96 mg/l	No regulatory limit
15/06/2021	CHLORINE FREE	0.85 mg/l	No regulatory limit
23/06/2021	CHLORINE FREE	1 mg/l	No regulatory limit
24/06/2021	CHLORINE FREE	1.14 mg/l	No regulatory limit
25/06/2021	CHLORINE FREE	0.95 mg/l	No regulatory limit
29/06/2021	CHLORINE FREE	1.14 mg/l	No regulatory limit
30/06/2021	CHLORINE FREE	1.1 mg/l	No regulatory limit
01/07/2021	CHLORINE FREE	0.56 mg/l	No regulatory limit
02/07/2021	CHLORINE FREE	0.95 mg/l	No regulatory limit
06/07/2021	CHLORINE FREE	0.72 mg/l	No regulatory limit
07/07/2021	CHLORINE FREE	0.35 mg/l	No regulatory limit
08/07/2021	CHLORINE FREE	0.95 mg/l	No regulatory limit
09/07/2021	CHLORINE FREE	1.08 mg/l	No regulatory limit

12/07/2021	CHLORINE FREE	1.03 mg/l	No regulatory limit
14/07/2021	CHLORINE FREE	1.02 mg/l	No regulatory limit
15/07/2021	CHLORINE FREE	1.03 mg/l	No regulatory limit
21/07/2021	CHLORINE FREE	1.29 mg/l	No regulatory limit
22/07/2021	CHLORINE FREE	1.15 mg/l	No regulatory limit
23/07/2021	CHLORINE FREE	1.37 mg/l	No regulatory limit
26/07/2021	CHLORINE FREE	0.84 mg/l	No regulatory limit
03/08/2021	CHLORINE FREE	1.24 mg/l	No regulatory limit
06/08/2021	CHLORINE FREE	1.12 mg/l	No regulatory limit
07/08/2021	CHLORINE FREE	0.79 mg/l	No regulatory limit
08/08/2021	CHLORINE FREE	0.76 mg/l	No regulatory limit
09/08/2021	CHLORINE FREE	1.04 mg/l	No regulatory limit
16/08/2021	CHLORINE FREE	0.2 mg/l	No regulatory limit
25/08/2021	CHLORINE FREE	1.15 mg/l	No regulatory limit
27/08/2021	CHLORINE FREE	0.75 mg/l	No regulatory limit
01/09/2021	CHLORINE FREE	1.32 mg/l	No regulatory limit
06/09/2021	CHLORINE FREE	1.37 mg/l	No regulatory limit
09/09/2021	CHLORINE FREE	1.25 mg/l	No regulatory limit
24/09/2021	CHLORINE FREE	1.05 mg/l	No regulatory limit
28/09/2021	CHLORINE FREE	1 mg/l	No regulatory limit
29/09/2021	CHLORINE FREE	1.3 mg/l	No regulatory limit
30/09/2021	CHLORINE FREE	0.96 mg/l	No regulatory limit
01/10/2021	CHLORINE FREE	1.05 mg/l	No regulatory limit
04/10/2021	CHLORINE FREE	1.29 mg/l	No regulatory limit
05/10/2021	CHLORINE FREE	0.66 mg/l	No regulatory limit
07/10/2021	CHLORINE FREE	1.06 mg/l	No regulatory limit
13/10/2021	CHLORINE FREE	1.19 mg/l	No regulatory limit
14/10/2021	CHLORINE FREE	0.81 mg/l	No regulatory limit
17/10/2021	CHLORINE FREE	0.76 mg/l	No regulatory limit
18/10/2021	CHLORINE FREE	0.53 mg/l	No regulatory limit
19/10/2021	CHLORINE FREE	1.24 mg/l	No regulatory limit
20/10/2021	CHLORINE FREE	1.19 mg/l	No regulatory limit
21/10/2021	CHLORINE FREE	0.62 mg/l	No regulatory limit
22/10/2021	CHLORINE FREE	1 mg/l	No regulatory limit
25/10/2021	CHLORINE FREE	1.34 mg/l	No regulatory limit
26/10/2021	CHLORINE FREE	1.38 mg/l	No regulatory limit
28/10/2021	CHLORINE FREE	0.91 mg/l	No regulatory limit
29/10/2021	CHLORINE FREE	1.2 mg/l	No regulatory limit
30/10/2021	CHLORINE FREE	0.92 mg/l	No regulatory limit
03/11/2021	CHLORINE FREE	1.05 mg/l	No regulatory limit
04/11/2021	CHLORINE FREE	1.06 mg/l	No regulatory limit
05/11/2021	CHLORINE FREE	1.04 mg/l	No regulatory limit
08/11/2021	CHLORINE FREE	1.05 mg/l	No regulatory limit
10/11/2021	CHLORINE FREE	1.24 mg/l	No regulatory limit
11/11/2021	CHLORINE FREE	0.85 mg/l	No regulatory limit
13/11/2021	CHLORINE FREE	0.82 mg/l	No regulatory limit
15/11/2021	CHLORINE FREE	1.04 mg/l	No regulatory limit
18/11/2021	CHLORINE FREE	1.75 mg/l	No regulatory limit

19/11/2021	CHLORINE FREE	0.94 mg/l	No regulatory limit
22/11/2021	CHLORINE FREE	1.12 mg/l	No regulatory limit
23/11/2021	CHLORINE FREE	0.98 mg/l	No regulatory limit
25/11/2021	CHLORINE FREE	0.6 mg/l	No regulatory limit
29/11/2021	CHLORINE FREE	1.14 mg/l	No regulatory limit
30/11/2021	CHLORINE FREE	1.21 mg/l	No regulatory limit
02/12/2021	CHLORINE FREE	1.13 mg/l	No regulatory limit
03/12/2021	CHLORINE FREE	0.82 mg/l	No regulatory limit
04/12/2021	CHLORINE FREE	0.82 mg/l	No regulatory limit
06/12/2021	CHLORINE FREE	1.15 mg/l	No regulatory limit
08/12/2021	CHLORINE FREE	0.97 mg/l	No regulatory limit
09/12/2021	CHLORINE FREE	1.09 mg/l	No regulatory limit
09/12/2021	CHLORINE FREE	0.44 mg/l	No regulatory limit
10/12/2021	CHLORINE FREE	0.83 mg/l	No regulatory limit
10/12/2021	CHLORINE FREE	1.39 mg/l	No regulatory limit
11/12/2021	CHLORINE FREE	1.16 mg/l	No regulatory limit
13/12/2021	CHLORINE FREE	1.1 mg/l	No regulatory limit
14/12/2021	CHLORINE FREE	1.06 mg/l	No regulatory limit
15/12/2021	CHLORINE FREE	1.08 mg/l	No regulatory limit
15/12/2021	CHLORINE FREE	0.98 mg/l	No regulatory limit
17/12/2021	CHLORINE FREE	1.17 mg/l	No regulatory limit
17/12/2021	CHLORINE FREE	1.34 mg/l	No regulatory limit
18/12/2021	CHLORINE FREE	0.98 mg/l	No regulatory limit
19/12/2021	CHLORINE FREE	0.98 mg/l	No regulatory limit
20/12/2021	CHLORINE FREE	1.17 mg/l	No regulatory limit
21/12/2021	CHLORINE FREE	1.24 mg/l	No regulatory limit
21/12/2021	CHLORINE FREE	1.21 mg/l	No regulatory limit
22/12/2021	CHLORINE FREE	0.94 mg/l	No regulatory limit
22/12/2021	CHLORINE FREE	0.94 mg/l	No regulatory limit
23/12/2021	CHLORINE FREE	0.86 mg/l	No regulatory limit
05/01/2022	CHLORINE FREE	0.42 mg/l	No regulatory limit
07/01/2022	CHLORINE FREE	0.96 mg/l	No regulatory limit
12/01/2022	CHLORINE FREE	0.7 mg/l	No regulatory limit
14/01/2022	CHLORINE FREE	0.99 mg/l	No regulatory limit
19/01/2022	CHLORINE FREE	1.28 mg/l	No regulatory limit
24/01/2022	CHLORINE FREE	0.88 mg/l	No regulatory limit
25/01/2022	CHLORINE FREE	1.05 mg/l	No regulatory limit
27/01/2022	CHLORINE FREE	1.41 mg/l	No regulatory limit
28/01/2022	CHLORINE FREE	1.15 mg/l	No regulatory limit
31/01/2022	CHLORINE FREE	1.47 mg/l	No regulatory limit
01/02/2022	CHLORINE FREE	1.1 mg/l	No regulatory limit
04/02/2022	CHLORINE FREE	1.08 mg/l	No regulatory limit
07/02/2022	CHLORINE FREE	1.01 mg/l	No regulatory limit
08/02/2022	CHLORINE FREE	0.95 mg/l	No regulatory limit
09/02/2022	CHLORINE FREE	1.15 mg/l	No regulatory limit
11/02/2022	CHLORINE FREE	0.93 mg/l	No regulatory limit
16/02/2022	CHLORINE FREE	0.82 mg/l	No regulatory limit
18/02/2022	CHLORINE FREE	1.08 mg/l	No regulatory limit

21/02/2022	CHLORINE FREE	1.45 mg/l	No regulatory limit
22/02/2022	CHLORINE FREE	1.06 mg/l	No regulatory limit
25/02/2022	CHLORINE FREE	0.91 mg/l	No regulatory limit
26/02/2022	CHLORINE FREE	0.9 mg/l	No regulatory limit
01/03/2022	CHLORINE FREE	1.34 mg/l	No regulatory limit
01/03/2022	CHLORINE FREE	1.22 mg/l	No regulatory limit
02/03/2022	CHLORINE FREE	1 mg/l	No regulatory limit
03/03/2022	CHLORINE FREE	0.88 mg/l	No regulatory limit
04/03/2022	CHLORINE FREE	0.89 mg/l	No regulatory limit
10/03/2022	CHLORINE FREE	0.83 mg/l	No regulatory limit
15/03/2022	CHLORINE FREE	0.99 mg/l	No regulatory limit
16/03/2022	CHLORINE FREE	1.01 mg/l	No regulatory limit
17/03/2022	CHLORINE FREE	1.11 mg/l	No regulatory limit
21/03/2022	CHLORINE FREE	1.03 mg/l	No regulatory limit
22/03/2022	CHLORINE FREE	1.21 mg/l	No regulatory limit
24/03/2022	CHLORINE FREE	0.96 mg/l	No regulatory limit
28/03/2022	CHLORINE FREE	1.26 mg/l	No regulatory limit
30/03/2022	CHLORINE FREE	0.76 mg/l	No regulatory limit
31/03/2022	CHLORINE FREE	1.07 mg/l	No regulatory limit
05/04/2022	CHLORINE FREE	1.04 mg/l	No regulatory limit
07/04/2022	CHLORINE FREE	1.28 mg/l	No regulatory limit
08/04/2022	CHLORINE FREE	0.79 mg/l	No regulatory limit
11/04/2022	CHLORINE FREE	1 mg/l	No regulatory limit
12/04/2022	CHLORINE FREE	0.89 mg/l	No regulatory limit
13/04/2022	CHLORINE FREE	1.01 mg/l	No regulatory limit
14/04/2022	CHLORINE FREE	1.08 mg/l	No regulatory limit
19/04/2022	CHLORINE FREE	1.08 mg/l	No regulatory limit
20/04/2022	CHLORINE FREE	0.39 mg/l	No regulatory limit
21/04/2022	CHLORINE FREE	1.21 mg/l	No regulatory limit
25/04/2022	CHLORINE FREE	1.2 mg/l	No regulatory limit
28/04/2022	CHLORINE FREE	1.14 mg/l	No regulatory limit
03/05/2022	CHLORINE FREE	1.18 mg/l	No regulatory limit
04/05/2022	CHLORINE FREE	1.09 mg/l	No regulatory limit
05/05/2022	CHLORINE FREE	0.63 mg/l	No regulatory limit
09/05/2022	CHLORINE FREE	1.18 mg/l	No regulatory limit
10/05/2022	CHLORINE FREE	1.1 mg/l	No regulatory limit
12/05/2022	CHLORINE FREE	1.19 mg/l	No regulatory limit
16/05/2022	CHLORINE FREE	1.05 mg/l	No regulatory limit
17/05/2022	CHLORINE FREE	1.22 mg/l	No regulatory limit
18/05/2022	CHLORINE FREE	1.09 mg/l	No regulatory limit
19/05/2022	CHLORINE FREE	0.95 mg/l	No regulatory limit
23/05/2022	CHLORINE FREE	1.22 mg/l	No regulatory limit
24/05/2022	CHLORINE FREE	0.84 mg/l	No regulatory limit
25/05/2022	CHLORINE FREE	1.16 mg/l	No regulatory limit
27/05/2022	CHLORINE FREE	1.18 mg/l	No regulatory limit
01/06/2022	CHLORINE FREE	0.98 mg/l	No regulatory limit
04/06/2022	CHLORINE FREE	1.08 mg/l	No regulatory limit
05/06/2022	CHLORINE FREE	1.13 mg/l	No regulatory limit

07/06/2022	CHLORINE FREE	1.1 mg/l	No regulatory limit
09/06/2022	CHLORINE FREE	1.12 mg/l	No regulatory limit
10/06/2022	CHLORINE FREE	1.1 mg/l	No regulatory limit
13/06/2022	CHLORINE FREE	0.97 mg/l	No regulatory limit
15/06/2022	CHLORINE FREE	1.08 mg/l	No regulatory limit
16/06/2022	CHLORINE FREE	1.04 mg/l	No regulatory limit
17/06/2022	CHLORINE FREE	0.98 mg/l	No regulatory limit
20/06/2022	CHLORINE FREE	1.07 mg/l	No regulatory limit
21/06/2022	CHLORINE FREE	1.06 mg/l	No regulatory limit
24/06/2022	CHLORINE FREE	1.25 mg/l	No regulatory limit
28/06/2022	CHLORINE FREE	0.91 mg/l	No regulatory limit
01/07/2022	CHLORINE FREE	1.03 mg/l	No regulatory limit
06/07/2022	CHLORINE FREE	1.12 mg/l	No regulatory limit
07/07/2022	CHLORINE FREE	1.1 mg/l	No regulatory limit
08/07/2022	CHLORINE FREE	0.77 mg/l	No regulatory limit
11/07/2022	CHLORINE FREE	1.12 mg/l	No regulatory limit
20/07/2022	CHLORINE FREE	0.8 mg/l	No regulatory limit
21/07/2022	CHLORINE FREE	0.85 mg/l	No regulatory limit
26/07/2022	CHLORINE FREE	0.82 mg/l	No regulatory limit
27/07/2022	CHLORINE FREE	0.99 mg/l	No regulatory limit
29/07/2022	CHLORINE FREE	0.89 mg/l	No regulatory limit
05/08/2022	CHLORINE FREE	0.65 mg/l	No regulatory limit
09/08/2022	CHLORINE FREE	0.9 mg/l	No regulatory limit
10/08/2022	CHLORINE FREE	1.05 mg/l	No regulatory limit
11/08/2022	CHLORINE FREE	1.21 mg/l	No regulatory limit
15/08/2022	CHLORINE FREE	0.72 mg/l	No regulatory limit
18/08/2022	CHLORINE FREE	0.96 mg/l	No regulatory limit
19/08/2022	CHLORINE FREE	0.65 mg/l	No regulatory limit
23/08/2022	CHLORINE FREE	0.92 mg/l	No regulatory limit
24/08/2022	CHLORINE FREE	1.18 mg/l	No regulatory limit
27/08/2022	CHLORINE FREE	0.55 mg/l	No regulatory limit
28/08/2022	CHLORINE FREE	0.72 mg/l	No regulatory limit
07/09/2022	CHLORINE FREE	0.77 mg/l	No regulatory limit
08/09/2022	CHLORINE FREE	1.19 mg/l	No regulatory limit
14/09/2022	CHLORINE FREE	1.08 mg/l	No regulatory limit
15/09/2022	CHLORINE FREE	0.94 mg/l	No regulatory limit
20/09/2022	CHLORINE FREE	0.99 mg/l	No regulatory limit
22/09/2022	CHLORINE FREE	0.96 mg/l	No regulatory limit
28/09/2022	CHLORINE FREE	0.69 mg/l	No regulatory limit
29/09/2022	CHLORINE FREE	0.89 mg/l	No regulatory limit
04/10/2022	CHLORINE FREE	0.98 mg/l	No regulatory limit
17/10/2022	CHLORINE FREE	1.23 mg/l	No regulatory limit
20/10/2022	CHLORINE FREE	1.23 mg/l	No regulatory limit
26/10/2022	CHLORINE FREE	1.05 mg/l	No regulatory limit
01/11/2022	CHLORINE FREE	1.01 mg/l	No regulatory limit
03/11/2022	CHLORINE FREE	0.67 mg/l	No regulatory limit
08/11/2022	CHLORINE FREE	1.02 mg/l	No regulatory limit
10/11/2022	CHLORINE FREE	0.8 mg/l	No regulatory limit

14/11/2022	CHLORINE FREE	1.07 mg/l	No regulatory limit
15/11/2022	CHLORINE FREE	1.16 mg/l	No regulatory limit
16/11/2022	CHLORINE FREE	0.85 mg/l	No regulatory limit
18/11/2022	CHLORINE FREE	1.15 mg/l	No regulatory limit
19/11/2022	CHLORINE FREE	1.06 mg/l	No regulatory limit
22/11/2022	CHLORINE FREE	0.95 mg/l	No regulatory limit
24/11/2022	CHLORINE FREE	1.25 mg/l	No regulatory limit
28/11/2022	CHLORINE FREE	0.72 mg/l	No regulatory limit
29/11/2022	CHLORINE FREE	0.9 mg/l	No regulatory limit
30/11/2022	CHLORINE FREE	0.72 mg/l	No regulatory limit
05/12/2022	CHLORINE FREE	1.18 mg/l	No regulatory limit
06/12/2022	CHLORINE FREE	0.68 mg/l	No regulatory limit
07/12/2022	CHLORINE FREE	1.24 mg/l	No regulatory limit
09/12/2022	CHLORINE FREE	1.1 mg/l	No regulatory limit
12/12/2022	CHLORINE FREE	0.91 mg/l	No regulatory limit
14/12/2022	CHLORINE FREE	0.99 mg/l	No regulatory limit
16/12/2022	CHLORINE FREE	1 mg/l	No regulatory limit
17/12/2022	CHLORINE FREE	1.16 mg/l	No regulatory limit
03/01/2023	CHLORINE FREE	1.01 mg/l	No regulatory limit
10/01/2023	CHLORINE FREE	1.19 mg/l	No regulatory limit
11/01/2023	CHLORINE FREE	1.08 mg/l	No regulatory limit
16/01/2023	CHLORINE FREE	0.89 mg/l	No regulatory limit
17/01/2023	CHLORINE FREE	0.92 mg/l	No regulatory limit
18/01/2023	CHLORINE FREE	0.9 mg/l	No regulatory limit
24/01/2023	CHLORINE FREE	0.56 mg/l	No regulatory limit
27/01/2023	CHLORINE FREE	1.19 mg/l	No regulatory limit
01/02/2023	CHLORINE FREE	1.24 mg/l	No regulatory limit
02/02/2023	CHLORINE FREE	1.03 mg/l	No regulatory limit
07/02/2023	CHLORINE FREE	1.1 mg/l	No regulatory limit
09/02/2023	CHLORINE FREE	1.09 mg/l	No regulatory limit
10/02/2023	CHLORINE FREE	0.4 mg/l	No regulatory limit
11/02/2023	CHLORINE FREE	1.27 mg/l	No regulatory limit
20/02/2023	CHLORINE FREE	0.93 mg/l	No regulatory limit
22/02/2023	CHLORINE FREE	0.87 mg/l	No regulatory limit
24/02/2023	CHLORINE FREE	0.59 mg/l	No regulatory limit
27/02/2023	CHLORINE FREE	1.02 mg/l	No regulatory limit
28/02/2023	CHLORINE FREE	1.09 mg/l	No regulatory limit
01/03/2023	CHLORINE FREE	1 mg/l	No regulatory limit
02/03/2023	CHLORINE FREE	0.84 mg/l	No regulatory limit
06/03/2023	CHLORINE FREE	0.96 mg/l	No regulatory limit
08/03/2023	CHLORINE FREE	1.17 mg/l	No regulatory limit
14/03/2023	CHLORINE FREE	1.05 mg/l	No regulatory limit
20/03/2023	CHLORINE FREE	1.05 mg/l	No regulatory limit
22/03/2023	CHLORINE FREE	1.01 mg/l	No regulatory limit
24/03/2023	CHLORINE FREE	0.91 mg/l	No regulatory limit
29/03/2023	CHLORINE FREE	1.11 mg/l	No regulatory limit
04/04/2023	CHLORINE FREE	0.95 mg/l	No regulatory limit
05/04/2023	CHLORINE FREE	1.08 mg/l	No regulatory limit

06/04/2023	CHLORINE FREE	0.9 mg/l	No regulatory limit
08/04/2023	CHLORINE FREE	1.08 mg/l	No regulatory limit
11/04/2023	CHLORINE FREE	0.95 mg/l	No regulatory limit
18/04/2023	CHLORINE FREE	0.83 mg/l	No regulatory limit
19/04/2023	CHLORINE FREE	1.02 mg/l	No regulatory limit
21/04/2023	CHLORINE FREE	1.16 mg/l	No regulatory limit
25/04/2023	CHLORINE FREE	0.96 mg/l	No regulatory limit
26/04/2023	CHLORINE FREE	0.9 mg/l	No regulatory limit
27/04/2023	CHLORINE FREE	1.12 mg/l	No regulatory limit
02/05/2023	CHLORINE FREE	1.38 mg/l	No regulatory limit
05/05/2023	CHLORINE FREE	1.16 mg/l	No regulatory limit
09/05/2023	CHLORINE FREE	1.22 mg/l	No regulatory limit
10/05/2023	CHLORINE FREE	1.06 mg/l	No regulatory limit
13/05/2023	CHLORINE FREE	1.01 mg/l	No regulatory limit
15/05/2023	CHLORINE FREE	0.48 mg/l	No regulatory limit
17/05/2023	CHLORINE FREE	0.95 mg/l	No regulatory limit
19/05/2023	CHLORINE FREE	1.17 mg/l	No regulatory limit
20/05/2023	CHLORINE FREE	1.06 mg/l	No regulatory limit
24/05/2023	CHLORINE FREE	1.08 mg/l	No regulatory limit
30/05/2023	CHLORINE FREE	1.27 mg/l	No regulatory limit
01/06/2023	CHLORINE FREE	1.01 mg/l	No regulatory limit
06/06/2023	CHLORINE FREE	0.86 mg/l	No regulatory limit
07/06/2023	CHLORINE FREE	0.96 mg/l	No regulatory limit
08/06/2023	CHLORINE FREE	0.61 mg/l	No regulatory limit
09/06/2023	CHLORINE FREE	0.94 mg/l	No regulatory limit
12/06/2023	CHLORINE FREE	0.97 mg/l	No regulatory limit
14/06/2023	CHLORINE FREE	0.97 mg/l	No regulatory limit
15/06/2023	CHLORINE FREE	0.9 mg/l	No regulatory limit
19/06/2023	CHLORINE FREE	0.87 mg/l	No regulatory limit
28/06/2023	CHLORINE FREE	1.1 mg/l	No regulatory limit
29/06/2023	CHLORINE FREE	0.77 mg/l	No regulatory limit
30/06/2023	CHLORINE FREE	0.63 mg/l	No regulatory limit
04/07/2023	CHLORINE FREE	1.14 mg/l	No regulatory limit
05/07/2023	CHLORINE FREE	1.1 mg/l	No regulatory limit
07/07/2023	CHLORINE FREE	1.03 mg/l	No regulatory limit
11/07/2023	CHLORINE FREE	0.95 mg/l	No regulatory limit
12/07/2023	CHLORINE FREE	1.03 mg/l	No regulatory limit
13/07/2023	CHLORINE FREE	0.76 mg/l	No regulatory limit
17/07/2023	CHLORINE FREE	0.8 mg/l	No regulatory limit
18/07/2023	CHLORINE FREE	0.86 mg/l	No regulatory limit
19/07/2023	CHLORINE FREE	1.23 mg/l	No regulatory limit
25/07/2023	CHLORINE FREE	0.96 mg/l	No regulatory limit
27/07/2023	CHLORINE FREE	1 mg/l	No regulatory limit
28/07/2023	CHLORINE FREE	0.7 mg/l	No regulatory limit
28/07/2023	CHLORINE FREE	0.62 mg/l	No regulatory limit
31/07/2023	CHLORINE FREE	0.96 mg/l	No regulatory limit
01/08/2023	CHLORINE FREE	0.79 mg/l	No regulatory limit
02/08/2023	CHLORINE FREE	0.95 mg/l	No regulatory limit

03/08/2023	CHLORINE FREE	0.45 mg/l	No regulatory limit
05/08/2023	CHLORINE FREE	0.8 mg/l	No regulatory limit
07/08/2023	CHLORINE FREE	1.12 mg/l	No regulatory limit
08/08/2023	CHLORINE FREE	0.92 mg/l	No regulatory limit
10/08/2023	CHLORINE FREE	1 mg/l	No regulatory limit
11/08/2023	CHLORINE FREE	0.93 mg/l	No regulatory limit
16/08/2023	CHLORINE FREE	0.89 mg/l	No regulatory limit
17/08/2023	CHLORINE FREE	0.95 mg/l	No regulatory limit
19/08/2023	CHLORINE FREE	0.86 mg/l	No regulatory limit
21/08/2023	CHLORINE FREE	1.12 mg/l	No regulatory limit
24/08/2023	CHLORINE FREE	0.95 mg/l	No regulatory limit
30/08/2023	CHLORINE FREE	0.9 mg/l	No regulatory limit
02/09/2023	CHLORINE FREE	0.85 mg/l	No regulatory limit
04/09/2023	CHLORINE FREE	0.87 mg/l	No regulatory limit
12/09/2023	CHLORINE FREE	0.62 mg/l	No regulatory limit
14/09/2023	CHLORINE FREE	1.15 mg/l	No regulatory limit
22/09/2023	CHLORINE FREE	0.76 mg/l	No regulatory limit
28/09/2023	CHLORINE FREE	0.89 mg/l	No regulatory limit
04/10/2023	CHLORINE FREE	0.99 mg/l	No regulatory limit
06/10/2023	CHLORINE FREE	1.02 mg/l	No regulatory limit
14/10/2023	CHLORINE FREE	1.07 mg/l	No regulatory limit
17/10/2023	CHLORINE FREE	0.63 mg/l	No regulatory limit
20/10/2023	CHLORINE FREE	0.65 mg/l	No regulatory limit
27/10/2023	CHLORINE FREE	0.84 mg/l	No regulatory limit
28/10/2023	CHLORINE FREE	0.71 mg/l	No regulatory limit
31/10/2023	CHLORINE FREE	1.11 mg/l	No regulatory limit
04/11/2023	CHLORINE FREE	0.97 mg/l	No regulatory limit
06/11/2023	CHLORINE FREE	1.21 mg/l	No regulatory limit
08/11/2023	CHLORINE FREE	0.92 mg/l	No regulatory limit
10/11/2023	CHLORINE FREE	0.89 mg/l	No regulatory limit
14/11/2023	CHLORINE FREE	0.91 mg/l	No regulatory limit
14/11/2023	CHLORINE FREE	1.02 mg/l	No regulatory limit
14/11/2023	CHLORINE FREE	0.98 mg/l	No regulatory limit
15/11/2023	CHLORINE FREE	0.84 mg/l	No regulatory limit
15/11/2023	CHLORINE FREE	1.03 mg/l	No regulatory limit
16/11/2023	CHLORINE FREE	1.02 mg/l	No regulatory limit
17/11/2023	CHLORINE FREE	0.9 mg/l	No regulatory limit
20/11/2023	CHLORINE FREE	0.72 mg/l	No regulatory limit
22/11/2023	CHLORINE FREE	0.85 mg/l	No regulatory limit
22/11/2023	CHLORINE FREE	0.94 mg/l	No regulatory limit
23/11/2023	CHLORINE FREE	0.89 mg/l	No regulatory limit
27/11/2023	CHLORINE FREE	1.16 mg/l	No regulatory limit
28/11/2023	CHLORINE FREE	1.01 mg/l	No regulatory limit
29/11/2023	CHLORINE FREE	1.18 mg/l	No regulatory limit
04/12/2023	CHLORINE FREE	0.95 mg/l	No regulatory limit
05/12/2023	CHLORINE FREE	1.25 mg/l	No regulatory limit
06/12/2023	CHLORINE FREE	0.84 mg/l	No regulatory limit
08/12/2023	CHLORINE FREE	1.08 mg/l	No regulatory limit

13/12/2023	CHLORINE FREE	0.87 mg/l	No regulatory limit
15/12/2023	CHLORINE FREE	0.95 mg/l	No regulatory limit
18/12/2023	CHLORINE FREE	1.09 mg/l	No regulatory limit
19/12/2023	CHLORINE FREE	1.01 mg/l	No regulatory limit
21/12/2023	CHLORINE FREE	1.25 mg/l	No regulatory limit
22/12/2023	CHLORINE FREE	1.23 mg/l	No regulatory limit
03/01/2024	CHLORINE FREE	1.05 mg/l	No regulatory limit
04/01/2024	CHLORINE FREE	1.22 mg/l	No regulatory limit
05/01/2024	CHLORINE FREE	0.97 mg/l	No regulatory limit
06/01/2024	CHLORINE FREE	1.43 mg/l	No regulatory limit
08/01/2024	CHLORINE FREE	1.05 mg/l	No regulatory limit
09/01/2024	CHLORINE FREE	1.43 mg/l	No regulatory limit
11/01/2024	CHLORINE FREE	1.13 mg/l	No regulatory limit
12/01/2024	CHLORINE FREE	1.04 mg/l	No regulatory limit
15/01/2024	CHLORINE FREE	1.29 mg/l	No regulatory limit
17/01/2024	CHLORINE FREE	1.06 mg/l	No regulatory limit
19/01/2024	CHLORINE FREE	1.09 mg/l	No regulatory limit
23/01/2024	CHLORINE FREE	1.08 mg/l	No regulatory limit
24/01/2024	CHLORINE FREE	1.15 mg/l	No regulatory limit
26/01/2024	CHLORINE FREE	1.19 mg/l	No regulatory limit
27/01/2024	CHLORINE FREE	1.27 mg/l	No regulatory limit
30/01/2024	CHLORINE FREE	1.04 mg/l	No regulatory limit
31/01/2024	CHLORINE FREE	1.3 mg/l	No regulatory limit
01/02/2024	CHLORINE FREE	1.44 mg/l	No regulatory limit
06/02/2024	CHLORINE FREE	1.01 mg/l	No regulatory limit
08/02/2024	CHLORINE FREE	1.01 mg/l	No regulatory limit
12/02/2024	CHLORINE FREE	0.89 mg/l	No regulatory limit
13/02/2024	CHLORINE FREE	0.98 mg/l	No regulatory limit
19/02/2024	CHLORINE FREE	0.95 mg/l	No regulatory limit
20/02/2024	CHLORINE FREE	1.12 mg/l	No regulatory limit
22/02/2024	CHLORINE FREE	1.37 mg/l	No regulatory limit
23/02/2024	CHLORINE FREE	0.95 mg/l	No regulatory limit
27/02/2024	CHLORINE FREE	0.99 mg/l	No regulatory limit
28/02/2024	CHLORINE FREE	1.21 mg/l	No regulatory limit
05/03/2024	CHLORINE FREE	1.1 mg/l	No regulatory limit
07/03/2024	CHLORINE FREE	1.08 mg/l	No regulatory limit
08/03/2024	CHLORINE FREE	0.96 mg/l	No regulatory limit
12/03/2024	CHLORINE FREE	1.24 mg/l	No regulatory limit
13/03/2024	CHLORINE FREE	1.01 mg/l	No regulatory limit
15/03/2024	CHLORINE FREE	1.49 mg/l	No regulatory limit
19/03/2024	CHLORINE FREE	1.19 mg/l	No regulatory limit
20/03/2024	CHLORINE FREE	1.17 mg/l	No regulatory limit
22/03/2024	CHLORINE FREE	1.43 mg/l	No regulatory limit
26/03/2024	CHLORINE FREE	1.24 mg/l	No regulatory limit
04/04/2024	CHLORINE FREE	1.26 mg/l	No regulatory limit
08/04/2024	CHLORINE FREE	1.21 mg/l	No regulatory limit
10/04/2024	CHLORINE FREE	1.47 mg/l	No regulatory limit
11/04/2024	CHLORINE FREE	1.32 mg/l	No regulatory limit

18/04/2024	CHLORINE FREE	1.15 mg/l	No regulatory limit
19/04/2024	CHLORINE FREE	1.21 mg/l	No regulatory limit
23/04/2024	CHLORINE FREE	1.12 mg/l	No regulatory limit
26/04/2024	CHLORINE FREE	0.9 mg/l	No regulatory limit
01/05/2024	CHLORINE FREE	1.5 mg/l	No regulatory limit
03/05/2024	CHLORINE FREE	1.53 mg/l	No regulatory limit
08/05/2024	CHLORINE FREE	0.2 mg/l	No regulatory limit
09/05/2024	CHLORINE FREE	1.31 mg/l	No regulatory limit
13/05/2024	CHLORINE FREE	1.21 mg/l	No regulatory limit
14/05/2024	CHLORINE FREE	1.36 mg/l	No regulatory limit
15/05/2024	CHLORINE FREE	1.09 mg/l	No regulatory limit
16/05/2024	CHLORINE FREE	1.08 mg/l	No regulatory limit
21/05/2024	CHLORINE FREE	1.18 mg/l	No regulatory limit
23/05/2024	CHLORINE FREE	1.36 mg/l	No regulatory limit
24/05/2024	CHLORINE FREE	1.24 mg/l	No regulatory limit
28/05/2024	CHLORINE FREE	1.13 mg/l	No regulatory limit
07/06/2024	CHLORINE FREE	1.12 mg/l	No regulatory limit
11/06/2024	CHLORINE FREE	1.5 mg/l	No regulatory limit
13/06/2024	CHLORINE FREE	1.11 mg/l	No regulatory limit
14/06/2024	CHLORINE FREE	1.3 mg/l	No regulatory limit
18/06/2024	CHLORINE FREE	1.35 mg/l	No regulatory limit
20/06/2024	CHLORINE FREE	1.23 mg/l	No regulatory limit
25/06/2024	CHLORINE FREE	1.16 mg/l	No regulatory limit
26/06/2024	CHLORINE FREE	1.12 mg/l	No regulatory limit
27/06/2024	CHLORINE FREE	1.07 mg/l	No regulatory limit
28/06/2024	CHLORINE FREE	1.31 mg/l	No regulatory limit
02/07/2024	CHLORINE FREE	1.14 mg/l	No regulatory limit
03/07/2024	CHLORINE FREE	1.05 mg/l	No regulatory limit
08/07/2024	CHLORINE FREE	0.95 mg/l	No regulatory limit
16/07/2024	CHLORINE FREE	1.11 mg/l	No regulatory limit
17/07/2024	CHLORINE FREE	1.29 mg/l	No regulatory limit
19/07/2024	CHLORINE FREE	1.17 mg/l	No regulatory limit
22/07/2024	CHLORINE FREE	1.42 mg/l	No regulatory limit
24/07/2024	CHLORINE FREE	1.31 mg/l	No regulatory limit
26/07/2024	CHLORINE FREE	1.44 mg/l	No regulatory limit
31/07/2024	CHLORINE FREE	1.46 mg/l	No regulatory limit
07/08/2024	CHLORINE FREE	1.25 mg/l	No regulatory limit
08/08/2024	CHLORINE FREE	0.9 mg/l	No regulatory limit
09/08/2024	CHLORINE FREE	1.17 mg/l	No regulatory limit
13/08/2024	CHLORINE FREE	0.63 mg/l	No regulatory limit
14/08/2024	CHLORINE FREE	1.06 mg/l	No regulatory limit
16/08/2024	CHLORINE FREE	1.2 mg/l	No regulatory limit
23/08/2024	CHLORINE FREE	0.45 mg/l	No regulatory limit
27/08/2024	CHLORINE FREE	1.01 mg/l	No regulatory limit
28/08/2024	CHLORINE FREE	1.26 mg/l	No regulatory limit
29/08/2024	CHLORINE FREE	0.99 mg/l	No regulatory limit
30/08/2024	CHLORINE FREE	1.06 mg/l	No regulatory limit
02/09/2024	CHLORINE FREE	1.04 mg/l	No regulatory limit

03/09/2024	CHLORINE FREE	1.16 mg/l	No regulatory limit
04/09/2024	CHLORINE FREE	0.96 mg/l	No regulatory limit
06/09/2024	CHLORINE FREE	0.88 mg/l	No regulatory limit
10/09/2024	CHLORINE FREE	0.95 mg/l	No regulatory limit
17/09/2024	CHLORINE FREE	1.09 mg/l	No regulatory limit
24/09/2024	CHLORINE FREE	1.16 mg/l	No regulatory limit
26/09/2024	CHLORINE FREE	1.1 mg/l	No regulatory limit
27/09/2024	CHLORINE FREE	1.25 mg/l	No regulatory limit
01/10/2024	CHLORINE FREE	0.58 mg/l	No regulatory limit
02/10/2024	CHLORINE FREE	1.22 mg/l	No regulatory limit
03/10/2024	CHLORINE FREE	1.34 mg/l	No regulatory limit
04/10/2024	CHLORINE FREE	1.12 mg/l	No regulatory limit
08/10/2024	CHLORINE FREE	1.02 mg/l	No regulatory limit
09/10/2024	CHLORINE FREE	0.99 mg/l	No regulatory limit
10/10/2024	CHLORINE FREE	1.36 mg/l	No regulatory limit
11/10/2024	CHLORINE FREE	0.64 mg/l	No regulatory limit
14/10/2024	CHLORINE FREE	0.96 mg/l	No regulatory limit
15/10/2024	CHLORINE FREE	0.92 mg/l	No regulatory limit
16/10/2024	CHLORINE FREE	0.81 mg/l	No regulatory limit
17/10/2024	CHLORINE FREE	1.1 mg/l	No regulatory limit
21/10/2024	CHLORINE FREE	1.8 mg/l	No regulatory limit
22/10/2024	CHLORINE FREE	0.67 mg/l	No regulatory limit
23/10/2024	CHLORINE FREE	1.33 mg/l	No regulatory limit
25/10/2024	CHLORINE FREE	1.08 mg/l	No regulatory limit
29/10/2024	CHLORINE FREE	1.19 mg/l	No regulatory limit
31/10/2024	CHLORINE FREE	1.19 mg/l	No regulatory limit
05/11/2024	CHLORINE FREE	1.13 mg/l	No regulatory limit
07/11/2024	CHLORINE FREE	1.21 mg/l	No regulatory limit
13/11/2024	CHLORINE FREE	1.02 mg/l	No regulatory limit
13/11/2024	CHLORINE FREE	0.98 mg/l	No regulatory limit
15/11/2024	CHLORINE FREE	1.49 mg/l	No regulatory limit
18/11/2024	CHLORINE FREE	1.38 mg/l	No regulatory limit
19/11/2024	CHLORINE FREE	0.16 mg/l	No regulatory limit
20/11/2024	CHLORINE FREE	1.25 mg/l	No regulatory limit
21/11/2024	CHLORINE FREE	0.84 mg/l	No regulatory limit
22/11/2024	CHLORINE FREE	0.95 mg/l	No regulatory limit
25/11/2024	CHLORINE FREE	1.14 mg/l	No regulatory limit
27/11/2024	CHLORINE FREE	1.06 mg/l	No regulatory limit
28/11/2024	CHLORINE FREE	1.03 mg/l	No regulatory limit
03/12/2024	CHLORINE FREE	1.26 mg/l	No regulatory limit
04/12/2024	CHLORINE FREE	0.67 mg/l	No regulatory limit
06/12/2024	CHLORINE FREE	1.06 mg/l	No regulatory limit
10/12/2024	CHLORINE FREE	0.79 mg/l	No regulatory limit
12/12/2024	CHLORINE FREE	0.89 mg/l	No regulatory limit
18/12/2024	CHLORINE FREE	0.7 mg/l	No regulatory limit
19/12/2024	CHLORINE FREE	0.83 mg/l	No regulatory limit
21/12/2024	CHLORINE FREE	1.04 mg/l	No regulatory limit
02/01/2025	CHLORINE FREE	0.97 mg/l	No regulatory limit

10/01/2025	CHLORINE FREE	0.91 mg/l	No regulatory limit
16/01/2025	CHLORINE FREE	1.16 mg/l	No regulatory limit
18/01/2025	CHLORINE FREE	0.85 mg/l	No regulatory limit
20/01/2025	CHLORINE FREE	1.07 mg/l	No regulatory limit
21/01/2025	CHLORINE FREE	1.07 mg/l	No regulatory limit
22/01/2025	CHLORINE FREE	1.09 mg/l	No regulatory limit
24/01/2025	CHLORINE FREE	1.16 mg/l	No regulatory limit
28/01/2025	CHLORINE FREE	1.1 mg/l	No regulatory limit
29/01/2025	CHLORINE FREE	1.05 mg/l	No regulatory limit
30/01/2025	CHLORINE FREE	1.02 mg/l	No regulatory limit
04/02/2025	CHLORINE FREE	1.06 mg/l	No regulatory limit
05/02/2025	CHLORINE FREE	0.73 mg/l	No regulatory limit
06/02/2025	CHLORINE FREE	1.49 mg/l	No regulatory limit
07/02/2025	CHLORINE FREE	1.09 mg/l	No regulatory limit
11/02/2025	CHLORINE FREE	1.03 mg/l	No regulatory limit
12/02/2025	CHLORINE FREE	0.97 mg/l	No regulatory limit
14/02/2025	CHLORINE FREE	0.94 mg/l	No regulatory limit
24/02/2025	CHLORINE FREE	1.17 mg/l	No regulatory limit
27/02/2025	CHLORINE FREE	0.98 mg/l	No regulatory limit
27/02/2025	CHLORINE FREE	1.01 mg/l	No regulatory limit
05/03/2025	CHLORINE FREE	0.9 mg/l	No regulatory limit
07/03/2025	CHLORINE FREE	0.97 mg/l	No regulatory limit
13/03/2025	CHLORINE FREE	1.15 mg/l	No regulatory limit
17/03/2025	CHLORINE FREE	0.8 mg/l	No regulatory limit
19/03/2025	CHLORINE FREE	1.09 mg/l	No regulatory limit
21/03/2025	CHLORINE FREE	1.23 mg/l	No regulatory limit
25/03/2025	CHLORINE FREE	1.31 mg/l	No regulatory limit
26/03/2025	CHLORINE FREE	1.14 mg/l	No regulatory limit
29/03/2025	CHLORINE FREE	1.08 mg/l	No regulatory limit
03/04/2025	CHLORINE FREE	0.95 mg/l	No regulatory limit
05/04/2025	CHLORINE FREE	1.09 mg/l	No regulatory limit
08/04/2025	CHLORINE FREE	1.13 mg/l	No regulatory limit
10/04/2025	CHLORINE FREE	1.35 mg/l	No regulatory limit
11/04/2025	CHLORINE FREE	1.01 mg/l	No regulatory limit
16/04/2025	CHLORINE FREE	1.39 mg/l	No regulatory limit
24/04/2025	CHLORINE FREE	1.28 mg/l	No regulatory limit
29/04/2025	CHLORINE FREE	1.25 mg/l	No regulatory limit
01/05/2025	CHLORINE FREE	1.08 mg/l	No regulatory limit
06/05/2025	CHLORINE FREE	1.05 mg/l	No regulatory limit
07/05/2025	CHLORINE FREE	0.35 mg/l	No regulatory limit
08/05/2025	CHLORINE FREE	1.01 mg/l	No regulatory limit
12/05/2025	CHLORINE FREE	1.08 mg/l	No regulatory limit
13/05/2025	CHLORINE FREE	0.73 mg/l	No regulatory limit
14/05/2025	CHLORINE FREE	0.84 mg/l	No regulatory limit
16/05/2025	CHLORINE FREE	1.03 mg/l	No regulatory limit
17/05/2025	CHLORINE FREE	0.87 mg/l	No regulatory limit
21/05/2025	CHLORINE FREE	1.48 mg/l	No regulatory limit
23/05/2025	CHLORINE FREE	0.97 mg/l	No regulatory limit

28/05/2025	CHLORINE FREE	0.96 mg/l	No regulatory limit
05/06/2025	CHLORINE FREE	0.92 mg/l	No regulatory limit
09/06/2025	CHLORINE FREE	1.13 mg/l	No regulatory limit
11/06/2025	CHLORINE FREE	1.09 mg/l	No regulatory limit
12/06/2025	CHLORINE FREE	0.94 mg/l	No regulatory limit
13/06/2025	CHLORINE FREE	0.65 mg/l	No regulatory limit
14/06/2025	CHLORINE FREE	1.15 mg/l	No regulatory limit
15/06/2025	CHLORINE FREE	1.1 mg/l	No regulatory limit
16/06/2025	CHLORINE FREE	1.14 mg/l	No regulatory limit
17/06/2025	CHLORINE FREE	0.97 mg/l	No regulatory limit
18/06/2025	CHLORINE FREE	1.1 mg/l	No regulatory limit
19/06/2025	CHLORINE FREE	0.97 mg/l	No regulatory limit
20/06/2025	CHLORINE FREE	0.83 mg/l	No regulatory limit
26/06/2025	CHLORINE FREE	0.86 mg/l	No regulatory limit
27/06/2025	CHLORINE FREE	0.64 mg/l	No regulatory limit
01/07/2025	CHLORINE FREE	0.83 mg/l	No regulatory limit
04/07/2025	CHLORINE FREE	0.98 mg/l	No regulatory limit
08/07/2025	CHLORINE FREE	0.68 mg/l	No regulatory limit
09/07/2025	CHLORINE FREE	0.93 mg/l	No regulatory limit
10/07/2025	CHLORINE FREE	0.89 mg/l	No regulatory limit
11/07/2025	CHLORINE FREE	1.02 mg/l	No regulatory limit
15/07/2025	CHLORINE FREE	1.03 mg/l	No regulatory limit
21/07/2025	CHLORINE FREE	1.06 mg/l	No regulatory limit
23/07/2025	CHLORINE FREE	0.95 mg/l	No regulatory limit
24/07/2025	CHLORINE FREE	0.96 mg/l	No regulatory limit
25/07/2025	CHLORINE FREE	0.78 mg/l	No regulatory limit
29/07/2025	CHLORINE FREE	0.84 mg/l	No regulatory limit
30/07/2025	CHLORINE FREE	1.02 mg/l	No regulatory limit
01/08/2025	CHLORINE FREE	0.89 mg/l	No regulatory limit
07/08/2025	CHLORINE FREE	1.3 mg/l	No regulatory limit
08/08/2025	CHLORINE FREE	1.05 mg/l	No regulatory limit
28/08/2025	CHLORINE FREE	0.91 mg/l	No regulatory limit
03/09/2025	CHLORINE FREE	1.02 mg/l	No regulatory limit
05/09/2025	CHLORINE FREE	0.96 mg/l	No regulatory limit
06/09/2025	CHLORINE FREE	1.04 mg/l	No regulatory limit
10/09/2025	CHLORINE FREE	1 mg/l	No regulatory limit
12/09/2025	CHLORINE FREE	0.96 mg/l	No regulatory limit
16/09/2025	CHLORINE FREE	0.95 mg/l	No regulatory limit
17/09/2025	CHLORINE FREE	0.73 mg/l	No regulatory limit
29/09/2025	CHLORINE FREE	0.12 mg/l	No regulatory limit
30/09/2025	CHLORINE FREE	0.75 mg/l	No regulatory limit
01/10/2025	CHLORINE FREE	1.39 mg/l	No regulatory limit
03/10/2025	CHLORINE FREE	0.88 mg/l	No regulatory limit
05/10/2025	CHLORINE FREE	1.21 mg/l	No regulatory limit
06/10/2025	CHLORINE FREE	1.49 mg/l	No regulatory limit
08/10/2025	CHLORINE FREE	0.68 mg/l	No regulatory limit
10/10/2025	CHLORINE FREE	1.27 mg/l	No regulatory limit
14/10/2025	CHLORINE FREE	0.74 mg/l	No regulatory limit

15/10/2025	CHLORINE FREE	0.68 mg/l	No regulatory limit
18/10/2025	CHLORINE FREE	0.91 mg/l	No regulatory limit
20/10/2025	CHLORINE FREE	0.88 mg/l	No regulatory limit
22/10/2025	CHLORINE FREE	1.09 mg/l	No regulatory limit
23/10/2025	CHLORINE FREE	1.05 mg/l	No regulatory limit
24/10/2025	CHLORINE FREE	0.48 mg/l	No regulatory limit
27/10/2025	CHLORINE FREE	0.74 mg/l	No regulatory limit
28/10/2025	CHLORINE FREE	1.09 mg/l	No regulatory limit
29/10/2025	CHLORINE FREE	1.01 mg/l	No regulatory limit
31/10/2025	CHLORINE FREE	0.66 mg/l	No regulatory limit
03/11/2025	CHLORINE FREE	0.95 mg/l	No regulatory limit
05/11/2025	CHLORINE FREE	0.81 mg/l	No regulatory limit
08/11/2025	CHLORINE FREE	0.71 mg/l	No regulatory limit
10/11/2025	CHLORINE FREE	0.64 mg/l	No regulatory limit
12/11/2025	CHLORINE FREE	1.01 mg/l	No regulatory limit
17/11/2025	CHLORINE FREE	0.5 mg/l	No regulatory limit
18/11/2025	CHLORINE FREE	1.15 mg/l	No regulatory limit
19/11/2025	CHLORINE FREE	1.22 mg/l	No regulatory limit
20/11/2025	CHLORINE FREE	1.21 mg/l	No regulatory limit
21/11/2025	CHLORINE FREE	0.95 mg/l	No regulatory limit
24/11/2025	CHLORINE FREE	1 mg/l	No regulatory limit
26/11/2025	CHLORINE FREE	0.83 mg/l	No regulatory limit
27/11/2025	CHLORINE FREE	0.72 mg/l	No regulatory limit
02/12/2025	CHLORINE FREE	1.01 mg/l	No regulatory limit
03/12/2025	CHLORINE FREE	0.56 mg/l	No regulatory limit
05/12/2025	CHLORINE FREE	0.95 mg/l	No regulatory limit
09/12/2025	CHLORINE FREE	1.03 mg/l	No regulatory limit
11/12/2025	CHLORINE FREE	0.91 mg/l	No regulatory limit
12/12/2025	CHLORINE FREE	1.08 mg/l	No regulatory limit
15/12/2025	CHLORINE FREE	1.16 mg/l	No regulatory limit
16/12/2025	CHLORINE FREE	1.22 mg/l	No regulatory limit
18/12/2025	CHLORINE FREE	0.85 mg/l	No regulatory limit
19/12/2025	CHLORINE FREE	1.2 mg/l	No regulatory limit
22/12/2025	CHLORINE FREE	1.2 mg/l	No regulatory limit
23/12/2025	CHLORINE FREE	1.13 mg/l	No regulatory limit
24/12/2025	CHLORINE FREE	0.97 mg/l	No regulatory limit
06/01/2026	CHLORINE FREE	0.52 mg/l	No regulatory limit
08/01/2026	CHLORINE FREE	0.73 mg/l	No regulatory limit
09/01/2026	CHLORINE FREE	1.09 mg/l	No regulatory limit
13/01/2026	CHLORINE FREE	0.82 mg/l	No regulatory limit
14/01/2026	CHLORINE FREE	0.73 mg/l	No regulatory limit
15/01/2026	CHLORINE FREE	1.1 mg/l	No regulatory limit
19/01/2026	CHLORINE FREE	0.81 mg/l	No regulatory limit
20/01/2026	CHLORINE FREE	0.96 mg/l	No regulatory limit
21/01/2026	CHLORINE FREE	1.1 mg/l	No regulatory limit
27/01/2026	CHLORINE FREE	1.16 mg/l	No regulatory limit
28/01/2026	CHLORINE FREE	1.1 mg/l	No regulatory limit
29/01/2026	CHLORINE FREE	1.19 mg/l	No regulatory limit

30/01/2026	CHLORINE FREE	1.19 mg/l	No regulatory limit
02/02/2026	CHLORINE FREE	1.23 mg/l	No regulatory limit
05/02/2026	CHLORINE FREE	1.24 mg/l	No regulatory limit
09/02/2026	CHLORINE FREE	0.97 mg/l	No regulatory limit
10/02/2026	CHLORINE FREE	1.24 mg/l	No regulatory limit
11/02/2026	CHLORINE FREE	1.23 mg/l	No regulatory limit
13/02/2026	CHLORINE FREE	0.98 mg/l	No regulatory limit
17/02/2026	CHLORINE FREE	1.38 mg/l	No regulatory limit
03/03/2021	CHLORINE TOTAL	1.14 mg/l	No regulatory limit
10/03/2021	CHLORINE TOTAL	1.03 mg/l	No regulatory limit
11/03/2021	CHLORINE TOTAL	1.11 mg/l	No regulatory limit
14/03/2021	CHLORINE TOTAL	0.85 mg/l	No regulatory limit
19/03/2021	CHLORINE TOTAL	1.22 mg/l	No regulatory limit
20/03/2021	CHLORINE TOTAL	1.2 mg/l	No regulatory limit
21/03/2021	CHLORINE TOTAL	0.95 mg/l	No regulatory limit
25/03/2021	CHLORINE TOTAL	1.26 mg/l	No regulatory limit
26/03/2021	CHLORINE TOTAL	1.09 mg/l	No regulatory limit
29/03/2021	CHLORINE TOTAL	1.17 mg/l	No regulatory limit
30/03/2021	CHLORINE TOTAL	0.97 mg/l	No regulatory limit
31/03/2021	CHLORINE TOTAL	0.88 mg/l	No regulatory limit
01/04/2021	CHLORINE TOTAL	0.87 mg/l	No regulatory limit
04/04/2021	CHLORINE TOTAL	0.86 mg/l	No regulatory limit
07/04/2021	CHLORINE TOTAL	1.03 mg/l	No regulatory limit
08/04/2021	CHLORINE TOTAL	0.97 mg/l	No regulatory limit
09/04/2021	CHLORINE TOTAL	0.77 mg/l	No regulatory limit
10/04/2021	CHLORINE TOTAL	0.95 mg/l	No regulatory limit
16/04/2021	CHLORINE TOTAL	0.98 mg/l	No regulatory limit
18/04/2021	CHLORINE TOTAL	0.8 mg/l	No regulatory limit
19/04/2021	CHLORINE TOTAL	0.86 mg/l	No regulatory limit
21/04/2021	CHLORINE TOTAL	0.89 mg/l	No regulatory limit
22/04/2021	CHLORINE TOTAL	1.06 mg/l	No regulatory limit
23/04/2021	CHLORINE TOTAL	0.88 mg/l	No regulatory limit
25/04/2021	CHLORINE TOTAL	0.92 mg/l	No regulatory limit
27/04/2021	CHLORINE TOTAL	0.81 mg/l	No regulatory limit
06/05/2021	CHLORINE TOTAL	1.08 mg/l	No regulatory limit
08/05/2021	CHLORINE TOTAL	1.09 mg/l	No regulatory limit
10/05/2021	CHLORINE TOTAL	1.11 mg/l	No regulatory limit
11/05/2021	CHLORINE TOTAL	0.99 mg/l	No regulatory limit
12/05/2021	CHLORINE TOTAL	1.08 mg/l	No regulatory limit
14/05/2021	CHLORINE TOTAL	1.03 mg/l	No regulatory limit
17/05/2021	CHLORINE TOTAL	0.82 mg/l	No regulatory limit
19/05/2021	CHLORINE TOTAL	1.13 mg/l	No regulatory limit
20/05/2021	CHLORINE TOTAL	0.78 mg/l	No regulatory limit
21/05/2021	CHLORINE TOTAL	1.67 mg/l	No regulatory limit
22/05/2021	CHLORINE TOTAL	0.89 mg/l	No regulatory limit
25/05/2021	CHLORINE TOTAL	0.75 mg/l	No regulatory limit
26/05/2021	CHLORINE TOTAL	1 mg/l	No regulatory limit
27/05/2021	CHLORINE TOTAL	1.21 mg/l	No regulatory limit

28/05/2021	CHLORINE TOTAL	1.08 mg/l	No regulatory limit
29/05/2021	CHLORINE TOTAL	1.07 mg/l	No regulatory limit
30/05/2021	CHLORINE TOTAL	0.99 mg/l	No regulatory limit
02/06/2021	CHLORINE TOTAL	1.07 mg/l	No regulatory limit
04/06/2021	CHLORINE TOTAL	0.83 mg/l	No regulatory limit
07/06/2021	CHLORINE TOTAL	1.06 mg/l	No regulatory limit
08/06/2021	CHLORINE TOTAL	1.43 mg/l	No regulatory limit
09/06/2021	CHLORINE TOTAL	1.03 mg/l	No regulatory limit
11/06/2021	CHLORINE TOTAL	0.96 mg/l	No regulatory limit
14/06/2021	CHLORINE TOTAL	1.19 mg/l	No regulatory limit
15/06/2021	CHLORINE TOTAL	0.9 mg/l	No regulatory limit
23/06/2021	CHLORINE TOTAL	1.05 mg/l	No regulatory limit
24/06/2021	CHLORINE TOTAL	1.17 mg/l	No regulatory limit
25/06/2021	CHLORINE TOTAL	1.32 mg/l	No regulatory limit
29/06/2021	CHLORINE TOTAL	1.21 mg/l	No regulatory limit
30/06/2021	CHLORINE TOTAL	1.18 mg/l	No regulatory limit
01/07/2021	CHLORINE TOTAL	0.64 mg/l	No regulatory limit
02/07/2021	CHLORINE TOTAL	1.03 mg/l	No regulatory limit
06/07/2021	CHLORINE TOTAL	0.8 mg/l	No regulatory limit
07/07/2021	CHLORINE TOTAL	0.38 mg/l	No regulatory limit
08/07/2021	CHLORINE TOTAL	1.02 mg/l	No regulatory limit
09/07/2021	CHLORINE TOTAL	1.13 mg/l	No regulatory limit
12/07/2021	CHLORINE TOTAL	1.08 mg/l	No regulatory limit
14/07/2021	CHLORINE TOTAL	1.1 mg/l	No regulatory limit
15/07/2021	CHLORINE TOTAL	1.08 mg/l	No regulatory limit
21/07/2021	CHLORINE TOTAL	1.35 mg/l	No regulatory limit
22/07/2021	CHLORINE TOTAL	1.18 mg/l	No regulatory limit
23/07/2021	CHLORINE TOTAL	1.41 mg/l	No regulatory limit
26/07/2021	CHLORINE TOTAL	0.96 mg/l	No regulatory limit
03/08/2021	CHLORINE TOTAL	1.3 mg/l	No regulatory limit
06/08/2021	CHLORINE TOTAL	1.19 mg/l	No regulatory limit
07/08/2021	CHLORINE TOTAL	0.86 mg/l	No regulatory limit
08/08/2021	CHLORINE TOTAL	0.84 mg/l	No regulatory limit
09/08/2021	CHLORINE TOTAL	1.11 mg/l	No regulatory limit
16/08/2021	CHLORINE TOTAL	0.28 mg/l	No regulatory limit
25/08/2021	CHLORINE TOTAL	1.17 mg/l	No regulatory limit
27/08/2021	CHLORINE TOTAL	0.81 mg/l	No regulatory limit
01/09/2021	CHLORINE TOTAL	1.34 mg/l	No regulatory limit
06/09/2021	CHLORINE TOTAL	1.42 mg/l	No regulatory limit
09/09/2021	CHLORINE TOTAL	1.26 mg/l	No regulatory limit
24/09/2021	CHLORINE TOTAL	1.13 mg/l	No regulatory limit
28/09/2021	CHLORINE TOTAL	1.08 mg/l	No regulatory limit
29/09/2021	CHLORINE TOTAL	1.36 mg/l	No regulatory limit
30/09/2021	CHLORINE TOTAL	1.06 mg/l	No regulatory limit
01/10/2021	CHLORINE TOTAL	1.06 mg/l	No regulatory limit
04/10/2021	CHLORINE TOTAL	1.41 mg/l	No regulatory limit
05/10/2021	CHLORINE TOTAL	0.67 mg/l	No regulatory limit
07/10/2021	CHLORINE TOTAL	1.12 mg/l	No regulatory limit

13/10/2021	CHLORINE TOTAL	1.32 mg/l	No regulatory limit
14/10/2021	CHLORINE TOTAL	0.86 mg/l	No regulatory limit
17/10/2021	CHLORINE TOTAL	0.87 mg/l	No regulatory limit
18/10/2021	CHLORINE TOTAL	0.56 mg/l	No regulatory limit
19/10/2021	CHLORINE TOTAL	1.27 mg/l	No regulatory limit
20/10/2021	CHLORINE TOTAL	1.25 mg/l	No regulatory limit
21/10/2021	CHLORINE TOTAL	0.71 mg/l	No regulatory limit
22/10/2021	CHLORINE TOTAL	1.19 mg/l	No regulatory limit
25/10/2021	CHLORINE TOTAL	1.37 mg/l	No regulatory limit
26/10/2021	CHLORINE TOTAL	1.42 mg/l	No regulatory limit
28/10/2021	CHLORINE TOTAL	0.97 mg/l	No regulatory limit
29/10/2021	CHLORINE TOTAL	1.3 mg/l	No regulatory limit
30/10/2021	CHLORINE TOTAL	0.96 mg/l	No regulatory limit
03/11/2021	CHLORINE TOTAL	1.11 mg/l	No regulatory limit
04/11/2021	CHLORINE TOTAL	1.17 mg/l	No regulatory limit
05/11/2021	CHLORINE TOTAL	1.1 mg/l	No regulatory limit
08/11/2021	CHLORINE TOTAL	1.16 mg/l	No regulatory limit
10/11/2021	CHLORINE TOTAL	1.38 mg/l	No regulatory limit
11/11/2021	CHLORINE TOTAL	0.88 mg/l	No regulatory limit
13/11/2021	CHLORINE TOTAL	0.87 mg/l	No regulatory limit
15/11/2021	CHLORINE TOTAL	1.11 mg/l	No regulatory limit
18/11/2021	CHLORINE TOTAL	1.89 mg/l	No regulatory limit
19/11/2021	CHLORINE TOTAL	1.13 mg/l	No regulatory limit
22/11/2021	CHLORINE TOTAL	1.27 mg/l	No regulatory limit
23/11/2021	CHLORINE TOTAL	1.15 mg/l	No regulatory limit
25/11/2021	CHLORINE TOTAL	0.62 mg/l	No regulatory limit
29/11/2021	CHLORINE TOTAL	1.45 mg/l	No regulatory limit
30/11/2021	CHLORINE TOTAL	1.28 mg/l	No regulatory limit
02/12/2021	CHLORINE TOTAL	1.22 mg/l	No regulatory limit
03/12/2021	CHLORINE TOTAL	0.86 mg/l	No regulatory limit
04/12/2021	CHLORINE TOTAL	0.87 mg/l	No regulatory limit
06/12/2021	CHLORINE TOTAL	1.21 mg/l	No regulatory limit
08/12/2021	CHLORINE TOTAL	1.1 mg/l	No regulatory limit
09/12/2021	CHLORINE TOTAL	1.14 mg/l	No regulatory limit
09/12/2021	CHLORINE TOTAL	0.56 mg/l	No regulatory limit
10/12/2021	CHLORINE TOTAL	0.9 mg/l	No regulatory limit
10/12/2021	CHLORINE TOTAL	1.44 mg/l	No regulatory limit
11/12/2021	CHLORINE TOTAL	1.25 mg/l	No regulatory limit
13/12/2021	CHLORINE TOTAL	1.22 mg/l	No regulatory limit
14/12/2021	CHLORINE TOTAL	1.11 mg/l	No regulatory limit
15/12/2021	CHLORINE TOTAL	1.14 mg/l	No regulatory limit
15/12/2021	CHLORINE TOTAL	1.03 mg/l	No regulatory limit
17/12/2021	CHLORINE TOTAL	1.21 mg/l	No regulatory limit
17/12/2021	CHLORINE TOTAL	1.41 mg/l	No regulatory limit
18/12/2021	CHLORINE TOTAL	1.04 mg/l	No regulatory limit
19/12/2021	CHLORINE TOTAL	1.08 mg/l	No regulatory limit
20/12/2021	CHLORINE TOTAL	1.24 mg/l	No regulatory limit
21/12/2021	CHLORINE TOTAL	1.33 mg/l	No regulatory limit

21/12/2021	CHLORINE TOTAL	1.32 mg/l	No regulatory limit
22/12/2021	CHLORINE TOTAL	0.98 mg/l	No regulatory limit
22/12/2021	CHLORINE TOTAL	1.02 mg/l	No regulatory limit
23/12/2021	CHLORINE TOTAL	0.93 mg/l	No regulatory limit
05/01/2022	CHLORINE TOTAL	0.54 mg/l	No regulatory limit
07/01/2022	CHLORINE TOTAL	1.03 mg/l	No regulatory limit
12/01/2022	CHLORINE TOTAL	0.77 mg/l	No regulatory limit
14/01/2022	CHLORINE TOTAL	1.06 mg/l	No regulatory limit
19/01/2022	CHLORINE TOTAL	1.52 mg/l	No regulatory limit
24/01/2022	CHLORINE TOTAL	0.91 mg/l	No regulatory limit
25/01/2022	CHLORINE TOTAL	1.14 mg/l	No regulatory limit
27/01/2022	CHLORINE TOTAL	1.48 mg/l	No regulatory limit
28/01/2022	CHLORINE TOTAL	1.23 mg/l	No regulatory limit
31/01/2022	CHLORINE TOTAL	1.62 mg/l	No regulatory limit
01/02/2022	CHLORINE TOTAL	1.16 mg/l	No regulatory limit
04/02/2022	CHLORINE TOTAL	1.16 mg/l	No regulatory limit
07/02/2022	CHLORINE TOTAL	1.11 mg/l	No regulatory limit
08/02/2022	CHLORINE TOTAL	1.08 mg/l	No regulatory limit
09/02/2022	CHLORINE TOTAL	1.21 mg/l	No regulatory limit
11/02/2022	CHLORINE TOTAL	1.01 mg/l	No regulatory limit
16/02/2022	CHLORINE TOTAL	0.92 mg/l	No regulatory limit
18/02/2022	CHLORINE TOTAL	1.16 mg/l	No regulatory limit
21/02/2022	CHLORINE TOTAL	1.72 mg/l	No regulatory limit
22/02/2022	CHLORINE TOTAL	1.17 mg/l	No regulatory limit
25/02/2022	CHLORINE TOTAL	1.02 mg/l	No regulatory limit
26/02/2022	CHLORINE TOTAL	0.98 mg/l	No regulatory limit
01/03/2022	CHLORINE TOTAL	1.4 mg/l	No regulatory limit
01/03/2022	CHLORINE TOTAL	1.34 mg/l	No regulatory limit
02/03/2022	CHLORINE TOTAL	1.09 mg/l	No regulatory limit
03/03/2022	CHLORINE TOTAL	0.99 mg/l	No regulatory limit
04/03/2022	CHLORINE TOTAL	0.96 mg/l	No regulatory limit
10/03/2022	CHLORINE TOTAL	0.91 mg/l	No regulatory limit
15/03/2022	CHLORINE TOTAL	1.06 mg/l	No regulatory limit
16/03/2022	CHLORINE TOTAL	1.09 mg/l	No regulatory limit
17/03/2022	CHLORINE TOTAL	1.15 mg/l	No regulatory limit
21/03/2022	CHLORINE TOTAL	1.14 mg/l	No regulatory limit
22/03/2022	CHLORINE TOTAL	1.25 mg/l	No regulatory limit
24/03/2022	CHLORINE TOTAL	1.06 mg/l	No regulatory limit
28/03/2022	CHLORINE TOTAL	1.37 mg/l	No regulatory limit
30/03/2022	CHLORINE TOTAL	0.8 mg/l	No regulatory limit
31/03/2022	CHLORINE TOTAL	1.13 mg/l	No regulatory limit
05/04/2022	CHLORINE TOTAL	1.12 mg/l	No regulatory limit
07/04/2022	CHLORINE TOTAL	1.35 mg/l	No regulatory limit
08/04/2022	CHLORINE TOTAL	0.91 mg/l	No regulatory limit
11/04/2022	CHLORINE TOTAL	1.07 mg/l	No regulatory limit
12/04/2022	CHLORINE TOTAL	0.96 mg/l	No regulatory limit
13/04/2022	CHLORINE TOTAL	1.11 mg/l	No regulatory limit
14/04/2022	CHLORINE TOTAL	1.17 mg/l	No regulatory limit

19/04/2022	CHLORINE TOTAL	1.29 mg/l	No regulatory limit
20/04/2022	CHLORINE TOTAL	0.46 mg/l	No regulatory limit
21/04/2022	CHLORINE TOTAL	1.34 mg/l	No regulatory limit
25/04/2022	CHLORINE TOTAL	1.28 mg/l	No regulatory limit
28/04/2022	CHLORINE TOTAL	1.31 mg/l	No regulatory limit
03/05/2022	CHLORINE TOTAL	1.26 mg/l	No regulatory limit
04/05/2022	CHLORINE TOTAL	1.6 mg/l	No regulatory limit
05/05/2022	CHLORINE TOTAL	0.7 mg/l	No regulatory limit
09/05/2022	CHLORINE TOTAL	1.25 mg/l	No regulatory limit
10/05/2022	CHLORINE TOTAL	1.18 mg/l	No regulatory limit
12/05/2022	CHLORINE TOTAL	1.23 mg/l	No regulatory limit
16/05/2022	CHLORINE TOTAL	1.13 mg/l	No regulatory limit
17/05/2022	CHLORINE TOTAL	1.29 mg/l	No regulatory limit
18/05/2022	CHLORINE TOTAL	1.13 mg/l	No regulatory limit
19/05/2022	CHLORINE TOTAL	1.05 mg/l	No regulatory limit
23/05/2022	CHLORINE TOTAL	1.28 mg/l	No regulatory limit
24/05/2022	CHLORINE TOTAL	0.92 mg/l	No regulatory limit
25/05/2022	CHLORINE TOTAL	1.22 mg/l	No regulatory limit
27/05/2022	CHLORINE TOTAL	1.26 mg/l	No regulatory limit
01/06/2022	CHLORINE TOTAL	1.05 mg/l	No regulatory limit
04/06/2022	CHLORINE TOTAL	1.15 mg/l	No regulatory limit
05/06/2022	CHLORINE TOTAL	1.18 mg/l	No regulatory limit
07/06/2022	CHLORINE TOTAL	1.21 mg/l	No regulatory limit
09/06/2022	CHLORINE TOTAL	1.15 mg/l	No regulatory limit
10/06/2022	CHLORINE TOTAL	1.18 mg/l	No regulatory limit
13/06/2022	CHLORINE TOTAL	1.05 mg/l	No regulatory limit
15/06/2022	CHLORINE TOTAL	1.1 mg/l	No regulatory limit
16/06/2022	CHLORINE TOTAL	1.1 mg/l	No regulatory limit
17/06/2022	CHLORINE TOTAL	1.15 mg/l	No regulatory limit
20/06/2022	CHLORINE TOTAL	1.14 mg/l	No regulatory limit
21/06/2022	CHLORINE TOTAL	1.17 mg/l	No regulatory limit
24/06/2022	CHLORINE TOTAL	1.4 mg/l	No regulatory limit
28/06/2022	CHLORINE TOTAL	0.98 mg/l	No regulatory limit
01/07/2022	CHLORINE TOTAL	1.18 mg/l	No regulatory limit
06/07/2022	CHLORINE TOTAL	1.15 mg/l	No regulatory limit
07/07/2022	CHLORINE TOTAL	1.19 mg/l	No regulatory limit
08/07/2022	CHLORINE TOTAL	0.8 mg/l	No regulatory limit
11/07/2022	CHLORINE TOTAL	1.3 mg/l	No regulatory limit
20/07/2022	CHLORINE TOTAL	0.88 mg/l	No regulatory limit
21/07/2022	CHLORINE TOTAL	1.09 mg/l	No regulatory limit
26/07/2022	CHLORINE TOTAL	0.94 mg/l	No regulatory limit
27/07/2022	CHLORINE TOTAL	1.07 mg/l	No regulatory limit
29/07/2022	CHLORINE TOTAL	0.9 mg/l	No regulatory limit
05/08/2022	CHLORINE TOTAL	0.71 mg/l	No regulatory limit
09/08/2022	CHLORINE TOTAL	0.96 mg/l	No regulatory limit
10/08/2022	CHLORINE TOTAL	1.12 mg/l	No regulatory limit
11/08/2022	CHLORINE TOTAL	1.26 mg/l	No regulatory limit
15/08/2022	CHLORINE TOTAL	0.78 mg/l	No regulatory limit

18/08/2022	CHLORINE TOTAL	0.99 mg/l	No regulatory limit
19/08/2022	CHLORINE TOTAL	0.69 mg/l	No regulatory limit
23/08/2022	CHLORINE TOTAL	0.97 mg/l	No regulatory limit
24/08/2022	CHLORINE TOTAL	1.24 mg/l	No regulatory limit
27/08/2022	CHLORINE TOTAL	0.74 mg/l	No regulatory limit
28/08/2022	CHLORINE TOTAL	0.88 mg/l	No regulatory limit
07/09/2022	CHLORINE TOTAL	0.82 mg/l	No regulatory limit
08/09/2022	CHLORINE TOTAL	1.24 mg/l	No regulatory limit
14/09/2022	CHLORINE TOTAL	1.13 mg/l	No regulatory limit
15/09/2022	CHLORINE TOTAL	1.01 mg/l	No regulatory limit
20/09/2022	CHLORINE TOTAL	1.05 mg/l	No regulatory limit
22/09/2022	CHLORINE TOTAL	1.04 mg/l	No regulatory limit
28/09/2022	CHLORINE TOTAL	0.76 mg/l	No regulatory limit
29/09/2022	CHLORINE TOTAL	0.92 mg/l	No regulatory limit
04/10/2022	CHLORINE TOTAL	1.15 mg/l	No regulatory limit
05/10/2022	CHLORINE TOTAL	1.01 mg/l	No regulatory limit
17/10/2022	CHLORINE TOTAL	1.3 mg/l	No regulatory limit
20/10/2022	CHLORINE TOTAL	1.47 mg/l	No regulatory limit
26/10/2022	CHLORINE TOTAL	1.1 mg/l	No regulatory limit
01/11/2022	CHLORINE TOTAL	1.12 mg/l	No regulatory limit
03/11/2022	CHLORINE TOTAL	0.74 mg/l	No regulatory limit
07/11/2022	CHLORINE TOTAL	1.17 mg/l	No regulatory limit
08/11/2022	CHLORINE TOTAL	1.06 mg/l	No regulatory limit
10/11/2022	CHLORINE TOTAL	0.88 mg/l	No regulatory limit
14/11/2022	CHLORINE TOTAL	1.14 mg/l	No regulatory limit
15/11/2022	CHLORINE TOTAL	1.28 mg/l	No regulatory limit
16/11/2022	CHLORINE TOTAL	0.9 mg/l	No regulatory limit
18/11/2022	CHLORINE TOTAL	1.33 mg/l	No regulatory limit
19/11/2022	CHLORINE TOTAL	1.11 mg/l	No regulatory limit
22/11/2022	CHLORINE TOTAL	1.09 mg/l	No regulatory limit
24/11/2022	CHLORINE TOTAL	1.4 mg/l	No regulatory limit
28/11/2022	CHLORINE TOTAL	0.89 mg/l	No regulatory limit
29/11/2022	CHLORINE TOTAL	1.24 mg/l	No regulatory limit
30/11/2022	CHLORINE TOTAL	0.79 mg/l	No regulatory limit
05/12/2022	CHLORINE TOTAL	1.2 mg/l	No regulatory limit
06/12/2022	CHLORINE TOTAL	0.79 mg/l	No regulatory limit
07/12/2022	CHLORINE TOTAL	1.58 mg/l	No regulatory limit
09/12/2022	CHLORINE TOTAL	1.14 mg/l	No regulatory limit
12/12/2022	CHLORINE TOTAL	0.97 mg/l	No regulatory limit
14/12/2022	CHLORINE TOTAL	1.03 mg/l	No regulatory limit
16/12/2022	CHLORINE TOTAL	1.05 mg/l	No regulatory limit
17/12/2022	CHLORINE TOTAL	1.34 mg/l	No regulatory limit
03/01/2023	CHLORINE TOTAL	1.11 mg/l	No regulatory limit
10/01/2023	CHLORINE TOTAL	1.29 mg/l	No regulatory limit
11/01/2023	CHLORINE TOTAL	1.2 mg/l	No regulatory limit
16/01/2023	CHLORINE TOTAL	0.96 mg/l	No regulatory limit
17/01/2023	CHLORINE TOTAL	1.02 mg/l	No regulatory limit
18/01/2023	CHLORINE TOTAL	1.14 mg/l	No regulatory limit

27/01/2023	CHLORINE TOTAL	1.32 mg/l	No regulatory limit
01/02/2023	CHLORINE TOTAL	1.34 mg/l	No regulatory limit
02/02/2023	CHLORINE TOTAL	1.16 mg/l	No regulatory limit
07/02/2023	CHLORINE TOTAL	1.19 mg/l	No regulatory limit
09/02/2023	CHLORINE TOTAL	1.15 mg/l	No regulatory limit
10/02/2023	CHLORINE TOTAL	0.49 mg/l	No regulatory limit
11/02/2023	CHLORINE TOTAL	1.32 mg/l	No regulatory limit
20/02/2023	CHLORINE TOTAL	1.02 mg/l	No regulatory limit
22/02/2023	CHLORINE TOTAL	0.95 mg/l	No regulatory limit
24/02/2023	CHLORINE TOTAL	0.71 mg/l	No regulatory limit
27/02/2023	CHLORINE TOTAL	1.17 mg/l	No regulatory limit
28/02/2023	CHLORINE TOTAL	1.26 mg/l	No regulatory limit
01/03/2023	CHLORINE TOTAL	1.2 mg/l	No regulatory limit
02/03/2023	CHLORINE TOTAL	0.95 mg/l	No regulatory limit
06/03/2023	CHLORINE TOTAL	1.01 mg/l	No regulatory limit
08/03/2023	CHLORINE TOTAL	1.48 mg/l	No regulatory limit
14/03/2023	CHLORINE TOTAL	1.17 mg/l	No regulatory limit
20/03/2023	CHLORINE TOTAL	1.17 mg/l	No regulatory limit
22/03/2023	CHLORINE TOTAL	1.09 mg/l	No regulatory limit
24/03/2023	CHLORINE TOTAL	0.98 mg/l	No regulatory limit
29/03/2023	CHLORINE TOTAL	1.16 mg/l	No regulatory limit
31/03/2023	CHLORINE TOTAL	1.08 mg/l	No regulatory limit
04/04/2023	CHLORINE TOTAL	1.04 mg/l	No regulatory limit
05/04/2023	CHLORINE TOTAL	1.13 mg/l	No regulatory limit
06/04/2023	CHLORINE TOTAL	1.02 mg/l	No regulatory limit
08/04/2023	CHLORINE TOTAL	1.22 mg/l	No regulatory limit
11/04/2023	CHLORINE TOTAL	0.99 mg/l	No regulatory limit
18/04/2023	CHLORINE TOTAL	0.96 mg/l	No regulatory limit
19/04/2023	CHLORINE TOTAL	1.08 mg/l	No regulatory limit
21/04/2023	CHLORINE TOTAL	1.27 mg/l	No regulatory limit
25/04/2023	CHLORINE TOTAL	1.07 mg/l	No regulatory limit
26/04/2023	CHLORINE TOTAL	0.98 mg/l	No regulatory limit
27/04/2023	CHLORINE TOTAL	1.28 mg/l	No regulatory limit
02/05/2023	CHLORINE TOTAL	1.42 mg/l	No regulatory limit
05/05/2023	CHLORINE TOTAL	1.28 mg/l	No regulatory limit
09/05/2023	CHLORINE TOTAL	1.23 mg/l	No regulatory limit
10/05/2023	CHLORINE TOTAL	1.13 mg/l	No regulatory limit
13/05/2023	CHLORINE TOTAL	1.09 mg/l	No regulatory limit
15/05/2023	CHLORINE TOTAL	0.56 mg/l	No regulatory limit
17/05/2023	CHLORINE TOTAL	1.08 mg/l	No regulatory limit
19/05/2023	CHLORINE TOTAL	1.26 mg/l	No regulatory limit
20/05/2023	CHLORINE TOTAL	1.2 mg/l	No regulatory limit
24/05/2023	CHLORINE TOTAL	1.18 mg/l	No regulatory limit
30/05/2023	CHLORINE TOTAL	1.35 mg/l	No regulatory limit
01/06/2023	CHLORINE TOTAL	1.06 mg/l	No regulatory limit
06/06/2023	CHLORINE TOTAL	0.94 mg/l	No regulatory limit
07/06/2023	CHLORINE TOTAL	1.02 mg/l	No regulatory limit
08/06/2023	CHLORINE TOTAL	0.7 mg/l	No regulatory limit

09/06/2023	CHLORINE TOTAL	1 mg/l	No regulatory limit
12/06/2023	CHLORINE TOTAL	1.03 mg/l	No regulatory limit
14/06/2023	CHLORINE TOTAL	1.03 mg/l	No regulatory limit
15/06/2023	CHLORINE TOTAL	0.99 mg/l	No regulatory limit
19/06/2023	CHLORINE TOTAL	0.89 mg/l	No regulatory limit
28/06/2023	CHLORINE TOTAL	1.16 mg/l	No regulatory limit
29/06/2023	CHLORINE TOTAL	0.82 mg/l	No regulatory limit
30/06/2023	CHLORINE TOTAL	0.71 mg/l	No regulatory limit
04/07/2023	CHLORINE TOTAL	1.2 mg/l	No regulatory limit
05/07/2023	CHLORINE TOTAL	1.2 mg/l	No regulatory limit
07/07/2023	CHLORINE TOTAL	1.19 mg/l	No regulatory limit
11/07/2023	CHLORINE TOTAL	1.03 mg/l	No regulatory limit
12/07/2023	CHLORINE TOTAL	1.09 mg/l	No regulatory limit
13/07/2023	CHLORINE TOTAL	0.83 mg/l	No regulatory limit
14/07/2023	CHLORINE TOTAL	0.86 mg/l	No regulatory limit
17/07/2023	CHLORINE TOTAL	0.82 mg/l	No regulatory limit
18/07/2023	CHLORINE TOTAL	1.01 mg/l	No regulatory limit
19/07/2023	CHLORINE TOTAL	1.42 mg/l	No regulatory limit
25/07/2023	CHLORINE TOTAL	1.05 mg/l	No regulatory limit
27/07/2023	CHLORINE TOTAL	1.09 mg/l	No regulatory limit
28/07/2023	CHLORINE TOTAL	0.8 mg/l	No regulatory limit
28/07/2023	CHLORINE TOTAL	0.74 mg/l	No regulatory limit
31/07/2023	CHLORINE TOTAL	0.97 mg/l	No regulatory limit
01/08/2023	CHLORINE TOTAL	0.85 mg/l	No regulatory limit
02/08/2023	CHLORINE TOTAL	1.03 mg/l	No regulatory limit
03/08/2023	CHLORINE TOTAL	0.5 mg/l	No regulatory limit
05/08/2023	CHLORINE TOTAL	0.86 mg/l	No regulatory limit
07/08/2023	CHLORINE TOTAL	1.27 mg/l	No regulatory limit
08/08/2023	CHLORINE TOTAL	0.93 mg/l	No regulatory limit
10/08/2023	CHLORINE TOTAL	1.21 mg/l	No regulatory limit
11/08/2023	CHLORINE TOTAL	0.97 mg/l	No regulatory limit
16/08/2023	CHLORINE TOTAL	0.94 mg/l	No regulatory limit
17/08/2023	CHLORINE TOTAL	1.08 mg/l	No regulatory limit
19/08/2023	CHLORINE TOTAL	0.94 mg/l	No regulatory limit
21/08/2023	CHLORINE TOTAL	1.17 mg/l	No regulatory limit
24/08/2023	CHLORINE TOTAL	0.98 mg/l	No regulatory limit
30/08/2023	CHLORINE TOTAL	0.93 mg/l	No regulatory limit
02/09/2023	CHLORINE TOTAL	0.9 mg/l	No regulatory limit
04/09/2023	CHLORINE TOTAL	0.99 mg/l	No regulatory limit
12/09/2023	CHLORINE TOTAL	0.65 mg/l	No regulatory limit
14/09/2023	CHLORINE TOTAL	1.36 mg/l	No regulatory limit
22/09/2023	CHLORINE TOTAL	0.81 mg/l	No regulatory limit
28/09/2023	CHLORINE TOTAL	0.99 mg/l	No regulatory limit
04/10/2023	CHLORINE TOTAL	1.07 mg/l	No regulatory limit
06/10/2023	CHLORINE TOTAL	1.13 mg/l	No regulatory limit
14/10/2023	CHLORINE TOTAL	1.16 mg/l	No regulatory limit
17/10/2023	CHLORINE TOTAL	0.77 mg/l	No regulatory limit
20/10/2023	CHLORINE TOTAL	0.78 mg/l	No regulatory limit

27/10/2023	CHLORINE TOTAL	0.9 mg/l	No regulatory limit
28/10/2023	CHLORINE TOTAL	0.78 mg/l	No regulatory limit
31/10/2023	CHLORINE TOTAL	1.21 mg/l	No regulatory limit
04/11/2023	CHLORINE TOTAL	1.04 mg/l	No regulatory limit
06/11/2023	CHLORINE TOTAL	1.28 mg/l	No regulatory limit
08/11/2023	CHLORINE TOTAL	1.02 mg/l	No regulatory limit
10/11/2023	CHLORINE TOTAL	1.04 mg/l	No regulatory limit
14/11/2023	CHLORINE TOTAL	0.97 mg/l	No regulatory limit
14/11/2023	CHLORINE TOTAL	1.1 mg/l	No regulatory limit
14/11/2023	CHLORINE TOTAL	1.1 mg/l	No regulatory limit
15/11/2023	CHLORINE TOTAL	0.95 mg/l	No regulatory limit
15/11/2023	CHLORINE TOTAL	1.25 mg/l	No regulatory limit
16/11/2023	CHLORINE TOTAL	1.06 mg/l	No regulatory limit
17/11/2023	CHLORINE TOTAL	0.95 mg/l	No regulatory limit
20/11/2023	CHLORINE TOTAL	0.8 mg/l	No regulatory limit
22/11/2023	CHLORINE TOTAL	1.09 mg/l	No regulatory limit
22/11/2023	CHLORINE TOTAL	1.02 mg/l	No regulatory limit
23/11/2023	CHLORINE TOTAL	1.08 mg/l	No regulatory limit
27/11/2023	CHLORINE TOTAL	1.24 mg/l	No regulatory limit
28/11/2023	CHLORINE TOTAL	1.13 mg/l	No regulatory limit
29/11/2023	CHLORINE TOTAL	1.26 mg/l	No regulatory limit
04/12/2023	CHLORINE TOTAL	1.03 mg/l	No regulatory limit
05/12/2023	CHLORINE TOTAL	1.35 mg/l	No regulatory limit
06/12/2023	CHLORINE TOTAL	0.95 mg/l	No regulatory limit
08/12/2023	CHLORINE TOTAL	1.17 mg/l	No regulatory limit
13/12/2023	CHLORINE TOTAL	0.99 mg/l	No regulatory limit
15/12/2023	CHLORINE TOTAL	1.1 mg/l	No regulatory limit
18/12/2023	CHLORINE TOTAL	1.14 mg/l	No regulatory limit
19/12/2023	CHLORINE TOTAL	1.07 mg/l	No regulatory limit
21/12/2023	CHLORINE TOTAL	1.48 mg/l	No regulatory limit
22/12/2023	CHLORINE TOTAL	1.3 mg/l	No regulatory limit
03/01/2024	CHLORINE TOTAL	1.1 mg/l	No regulatory limit
04/01/2024	CHLORINE TOTAL	1.37 mg/l	No regulatory limit
05/01/2024	CHLORINE TOTAL	1.1 mg/l	No regulatory limit
06/01/2024	CHLORINE TOTAL	1.55 mg/l	No regulatory limit
08/01/2024	CHLORINE TOTAL	1.2 mg/l	No regulatory limit
09/01/2024	CHLORINE TOTAL	1.54 mg/l	No regulatory limit
11/01/2024	CHLORINE TOTAL	1.32 mg/l	No regulatory limit
12/01/2024	CHLORINE TOTAL	1.18 mg/l	No regulatory limit
15/01/2024	CHLORINE TOTAL	1.36 mg/l	No regulatory limit
17/01/2024	CHLORINE TOTAL	1.1 mg/l	No regulatory limit
19/01/2024	CHLORINE TOTAL	1.18 mg/l	No regulatory limit
23/01/2024	CHLORINE TOTAL	1.14 mg/l	No regulatory limit
24/01/2024	CHLORINE TOTAL	1.29 mg/l	No regulatory limit
26/01/2024	CHLORINE TOTAL	1.33 mg/l	No regulatory limit
27/01/2024	CHLORINE TOTAL	1.31 mg/l	No regulatory limit
30/01/2024	CHLORINE TOTAL	1.09 mg/l	No regulatory limit
31/01/2024	CHLORINE TOTAL	1.45 mg/l	No regulatory limit

01/02/2024	CHLORINE TOTAL	1.59 mg/l	No regulatory limit
06/02/2024	CHLORINE TOTAL	1.23 mg/l	No regulatory limit
08/02/2024	CHLORINE TOTAL	1.12 mg/l	No regulatory limit
12/02/2024	CHLORINE TOTAL	1.01 mg/l	No regulatory limit
13/02/2024	CHLORINE TOTAL	1.06 mg/l	No regulatory limit
19/02/2024	CHLORINE TOTAL	1.03 mg/l	No regulatory limit
20/02/2024	CHLORINE TOTAL	1.19 mg/l	No regulatory limit
22/02/2024	CHLORINE TOTAL	1.56 mg/l	No regulatory limit
23/02/2024	CHLORINE TOTAL	1.27 mg/l	No regulatory limit
27/02/2024	CHLORINE TOTAL	1.12 mg/l	No regulatory limit
28/02/2024	CHLORINE TOTAL	1.34 mg/l	No regulatory limit
05/03/2024	CHLORINE TOTAL	1.19 mg/l	No regulatory limit
07/03/2024	CHLORINE TOTAL	1.15 mg/l	No regulatory limit
08/03/2024	CHLORINE TOTAL	0.98 mg/l	No regulatory limit
12/03/2024	CHLORINE TOTAL	1.34 mg/l	No regulatory limit
13/03/2024	CHLORINE TOTAL	1.27 mg/l	No regulatory limit
15/03/2024	CHLORINE TOTAL	1.66 mg/l	No regulatory limit
19/03/2024	CHLORINE TOTAL	1.27 mg/l	No regulatory limit
20/03/2024	CHLORINE TOTAL	1.27 mg/l	No regulatory limit
22/03/2024	CHLORINE TOTAL	1.51 mg/l	No regulatory limit
26/03/2024	CHLORINE TOTAL	1.53 mg/l	No regulatory limit
04/04/2024	CHLORINE TOTAL	1.41 mg/l	No regulatory limit
08/04/2024	CHLORINE TOTAL	1.42 mg/l	No regulatory limit
10/04/2024	CHLORINE TOTAL	1.72 mg/l	No regulatory limit
11/04/2024	CHLORINE TOTAL	1.43 mg/l	No regulatory limit
18/04/2024	CHLORINE TOTAL	1.22 mg/l	No regulatory limit
19/04/2024	CHLORINE TOTAL	1.28 mg/l	No regulatory limit
23/04/2024	CHLORINE TOTAL	1.2 mg/l	No regulatory limit
26/04/2024	CHLORINE TOTAL	0.98 mg/l	No regulatory limit
01/05/2024	CHLORINE TOTAL	1.53 mg/l	No regulatory limit
03/05/2024	CHLORINE TOTAL	1.59 mg/l	No regulatory limit
08/05/2024	CHLORINE TOTAL	0.22 mg/l	No regulatory limit
09/05/2024	CHLORINE TOTAL	1.4 mg/l	No regulatory limit
13/05/2024	CHLORINE TOTAL	1.26 mg/l	No regulatory limit
14/05/2024	CHLORINE TOTAL	1.4 mg/l	No regulatory limit
15/05/2024	CHLORINE TOTAL	1.18 mg/l	No regulatory limit
16/05/2024	CHLORINE TOTAL	1.14 mg/l	No regulatory limit
21/05/2024	CHLORINE TOTAL	1.27 mg/l	No regulatory limit
23/05/2024	CHLORINE TOTAL	1.44 mg/l	No regulatory limit
24/05/2024	CHLORINE TOTAL	1.32 mg/l	No regulatory limit
28/05/2024	CHLORINE TOTAL	1.24 mg/l	No regulatory limit
07/06/2024	CHLORINE TOTAL	1.22 mg/l	No regulatory limit
11/06/2024	CHLORINE TOTAL	1.61 mg/l	No regulatory limit
13/06/2024	CHLORINE TOTAL	1.27 mg/l	No regulatory limit
14/06/2024	CHLORINE TOTAL	1.37 mg/l	No regulatory limit
18/06/2024	CHLORINE TOTAL	1.75 mg/l	No regulatory limit
20/06/2024	CHLORINE TOTAL	1.3 mg/l	No regulatory limit
25/06/2024	CHLORINE TOTAL	1.24 mg/l	No regulatory limit

26/06/2024	CHLORINE TOTAL	1.13 mg/l	No regulatory limit
27/06/2024	CHLORINE TOTAL	1.15 mg/l	No regulatory limit
28/06/2024	CHLORINE TOTAL	1.43 mg/l	No regulatory limit
02/07/2024	CHLORINE TOTAL	1.21 mg/l	No regulatory limit
03/07/2024	CHLORINE TOTAL	1.1 mg/l	No regulatory limit
08/07/2024	CHLORINE TOTAL	1.08 mg/l	No regulatory limit
16/07/2024	CHLORINE TOTAL	1.19 mg/l	No regulatory limit
17/07/2024	CHLORINE TOTAL	1.31 mg/l	No regulatory limit
19/07/2024	CHLORINE TOTAL	1.23 mg/l	No regulatory limit
22/07/2024	CHLORINE TOTAL	1.63 mg/l	No regulatory limit
26/07/2024	CHLORINE TOTAL	1.53 mg/l	No regulatory limit
31/07/2024	CHLORINE TOTAL	1.51 mg/l	No regulatory limit
07/08/2024	CHLORINE TOTAL	1.32 mg/l	No regulatory limit
08/08/2024	CHLORINE TOTAL	0.97 mg/l	No regulatory limit
09/08/2024	CHLORINE TOTAL	1.21 mg/l	No regulatory limit
13/08/2024	CHLORINE TOTAL	0.73 mg/l	No regulatory limit
14/08/2024	CHLORINE TOTAL	1.24 mg/l	No regulatory limit
16/08/2024	CHLORINE TOTAL	1.25 mg/l	No regulatory limit
23/08/2024	CHLORINE TOTAL	0.69 mg/l	No regulatory limit
27/08/2024	CHLORINE TOTAL	1.09 mg/l	No regulatory limit
28/08/2024	CHLORINE TOTAL	1.54 mg/l	No regulatory limit
29/08/2024	CHLORINE TOTAL	1.07 mg/l	No regulatory limit
30/08/2024	CHLORINE TOTAL	1.15 mg/l	No regulatory limit
02/09/2024	CHLORINE TOTAL	1.08 mg/l	No regulatory limit
03/09/2024	CHLORINE TOTAL	1.23 mg/l	No regulatory limit
04/09/2024	CHLORINE TOTAL	1.04 mg/l	No regulatory limit
06/09/2024	CHLORINE TOTAL	0.95 mg/l	No regulatory limit
10/09/2024	CHLORINE TOTAL	1.01 mg/l	No regulatory limit
17/09/2024	CHLORINE TOTAL	1.11 mg/l	No regulatory limit
24/09/2024	CHLORINE TOTAL	1.19 mg/l	No regulatory limit
26/09/2024	CHLORINE TOTAL	1.14 mg/l	No regulatory limit
27/09/2024	CHLORINE TOTAL	1.31 mg/l	No regulatory limit
01/10/2024	CHLORINE TOTAL	0.63 mg/l	No regulatory limit
02/10/2024	CHLORINE TOTAL	1.26 mg/l	No regulatory limit
03/10/2024	CHLORINE TOTAL	1.42 mg/l	No regulatory limit
04/10/2024	CHLORINE TOTAL	1.2 mg/l	No regulatory limit
08/10/2024	CHLORINE TOTAL	1.13 mg/l	No regulatory limit
09/10/2024	CHLORINE TOTAL	1.08 mg/l	No regulatory limit
10/10/2024	CHLORINE TOTAL	1.47 mg/l	No regulatory limit
11/10/2024	CHLORINE TOTAL	0.73 mg/l	No regulatory limit
14/10/2024	CHLORINE TOTAL	1.04 mg/l	No regulatory limit
15/10/2024	CHLORINE TOTAL	0.99 mg/l	No regulatory limit
16/10/2024	CHLORINE TOTAL	0.9 mg/l	No regulatory limit
17/10/2024	CHLORINE TOTAL	1.15 mg/l	No regulatory limit
21/10/2024	CHLORINE TOTAL	2 mg/l	No regulatory limit
22/10/2024	CHLORINE TOTAL	0.76 mg/l	No regulatory limit
23/10/2024	CHLORINE TOTAL	1.44 mg/l	No regulatory limit
25/10/2024	CHLORINE TOTAL	1.15 mg/l	No regulatory limit

29/10/2024	CHLORINE TOTAL	1.25 mg/l	No regulatory limit
31/10/2024	CHLORINE TOTAL	1.27 mg/l	No regulatory limit
05/11/2024	CHLORINE TOTAL	1.23 mg/l	No regulatory limit
07/11/2024	CHLORINE TOTAL	1.27 mg/l	No regulatory limit
13/11/2024	CHLORINE TOTAL	1.26 mg/l	No regulatory limit
13/11/2024	CHLORINE TOTAL	1.08 mg/l	No regulatory limit
15/11/2024	CHLORINE TOTAL	1.64 mg/l	No regulatory limit
18/11/2024	CHLORINE TOTAL	1.5 mg/l	No regulatory limit
19/11/2024	CHLORINE TOTAL	0.33 mg/l	No regulatory limit
20/11/2024	CHLORINE TOTAL	1.34 mg/l	No regulatory limit
21/11/2024	CHLORINE TOTAL	0.93 mg/l	No regulatory limit
22/11/2024	CHLORINE TOTAL	1.07 mg/l	No regulatory limit
25/11/2024	CHLORINE TOTAL	1.22 mg/l	No regulatory limit
27/11/2024	CHLORINE TOTAL	1.23 mg/l	No regulatory limit
28/11/2024	CHLORINE TOTAL	1.15 mg/l	No regulatory limit
03/12/2024	CHLORINE TOTAL	1.3 mg/l	No regulatory limit
04/12/2024	CHLORINE TOTAL	0.79 mg/l	No regulatory limit
06/12/2024	CHLORINE TOTAL	1.14 mg/l	No regulatory limit
10/12/2024	CHLORINE TOTAL	0.86 mg/l	No regulatory limit
12/12/2024	CHLORINE TOTAL	1.21 mg/l	No regulatory limit
18/12/2024	CHLORINE TOTAL	0.77 mg/l	No regulatory limit
19/12/2024	CHLORINE TOTAL	0.94 mg/l	No regulatory limit
21/12/2024	CHLORINE TOTAL	1.12 mg/l	No regulatory limit
02/01/2025	CHLORINE TOTAL	1 mg/l	No regulatory limit
10/01/2025	CHLORINE TOTAL	0.94 mg/l	No regulatory limit
16/01/2025	CHLORINE TOTAL	1.36 mg/l	No regulatory limit
18/01/2025	CHLORINE TOTAL	0.99 mg/l	No regulatory limit
20/01/2025	CHLORINE TOTAL	1.25 mg/l	No regulatory limit
21/01/2025	CHLORINE TOTAL	1.13 mg/l	No regulatory limit
22/01/2025	CHLORINE TOTAL	1.19 mg/l	No regulatory limit
24/01/2025	CHLORINE TOTAL	1.25 mg/l	No regulatory limit
28/01/2025	CHLORINE TOTAL	1.31 mg/l	No regulatory limit
29/01/2025	CHLORINE TOTAL	1.07 mg/l	No regulatory limit
30/01/2025	CHLORINE TOTAL	1.13 mg/l	No regulatory limit
04/02/2025	CHLORINE TOTAL	1.16 mg/l	No regulatory limit
05/02/2025	CHLORINE TOTAL	0.86 mg/l	No regulatory limit
06/02/2025	CHLORINE TOTAL	1.65 mg/l	No regulatory limit
07/02/2025	CHLORINE TOTAL	1.25 mg/l	No regulatory limit
11/02/2025	CHLORINE TOTAL	1.3 mg/l	No regulatory limit
12/02/2025	CHLORINE TOTAL	1.06 mg/l	No regulatory limit
14/02/2025	CHLORINE TOTAL	1.21 mg/l	No regulatory limit
24/02/2025	CHLORINE TOTAL	1.28 mg/l	No regulatory limit
27/02/2025	CHLORINE TOTAL	1.08 mg/l	No regulatory limit
27/02/2025	CHLORINE TOTAL	1.1 mg/l	No regulatory limit
05/03/2025	CHLORINE TOTAL	1.11 mg/l	No regulatory limit
07/03/2025	CHLORINE TOTAL	1.04 mg/l	No regulatory limit
13/03/2025	CHLORINE TOTAL	1.26 mg/l	No regulatory limit
17/03/2025	CHLORINE TOTAL	0.86 mg/l	No regulatory limit

19/03/2025	CHLORINE TOTAL	1.22 mg/l	No regulatory limit
21/03/2025	CHLORINE TOTAL	1.28 mg/l	No regulatory limit
25/03/2025	CHLORINE TOTAL	1.48 mg/l	No regulatory limit
26/03/2025	CHLORINE TOTAL	1.24 mg/l	No regulatory limit
29/03/2025	CHLORINE TOTAL	1.13 mg/l	No regulatory limit
03/04/2025	CHLORINE TOTAL	1.06 mg/l	No regulatory limit
05/04/2025	CHLORINE TOTAL	1.15 mg/l	No regulatory limit
08/04/2025	CHLORINE TOTAL	1.2 mg/l	No regulatory limit
10/04/2025	CHLORINE TOTAL	1.43 mg/l	No regulatory limit
11/04/2025	CHLORINE TOTAL	1.05 mg/l	No regulatory limit
16/04/2025	CHLORINE TOTAL	1.44 mg/l	No regulatory limit
22/04/2025	CHLORINE TOTAL	1.11 mg/l	No regulatory limit
24/04/2025	CHLORINE TOTAL	1.31 mg/l	No regulatory limit
29/04/2025	CHLORINE TOTAL	1.33 mg/l	No regulatory limit
01/05/2025	CHLORINE TOTAL	1.15 mg/l	No regulatory limit
06/05/2025	CHLORINE TOTAL	1.09 mg/l	No regulatory limit
07/05/2025	CHLORINE TOTAL	0.39 mg/l	No regulatory limit
08/05/2025	CHLORINE TOTAL	1.08 mg/l	No regulatory limit
12/05/2025	CHLORINE TOTAL	1.2 mg/l	No regulatory limit
13/05/2025	CHLORINE TOTAL	0.79 mg/l	No regulatory limit
14/05/2025	CHLORINE TOTAL	0.87 mg/l	No regulatory limit
16/05/2025	CHLORINE TOTAL	1.11 mg/l	No regulatory limit
17/05/2025	CHLORINE TOTAL	0.92 mg/l	No regulatory limit
21/05/2025	CHLORINE TOTAL	2 mg/l	No regulatory limit
23/05/2025	CHLORINE TOTAL	1.06 mg/l	No regulatory limit
28/05/2025	CHLORINE TOTAL	1.04 mg/l	No regulatory limit
05/06/2025	CHLORINE TOTAL	1.04 mg/l	No regulatory limit
09/06/2025	CHLORINE TOTAL	1.25 mg/l	No regulatory limit
11/06/2025	CHLORINE TOTAL	1.14 mg/l	No regulatory limit
12/06/2025	CHLORINE TOTAL	1.07 mg/l	No regulatory limit
13/06/2025	CHLORINE TOTAL	0.72 mg/l	No regulatory limit
14/06/2025	CHLORINE TOTAL	1.21 mg/l	No regulatory limit
15/06/2025	CHLORINE TOTAL	1.16 mg/l	No regulatory limit
16/06/2025	CHLORINE TOTAL	1.22 mg/l	No regulatory limit
17/06/2025	CHLORINE TOTAL	1.06 mg/l	No regulatory limit
18/06/2025	CHLORINE TOTAL	1.15 mg/l	No regulatory limit
19/06/2025	CHLORINE TOTAL	1.08 mg/l	No regulatory limit
20/06/2025	CHLORINE TOTAL	0.96 mg/l	No regulatory limit
26/06/2025	CHLORINE TOTAL	0.93 mg/l	No regulatory limit
27/06/2025	CHLORINE TOTAL	0.78 mg/l	No regulatory limit
01/07/2025	CHLORINE TOTAL	0.91 mg/l	No regulatory limit
04/07/2025	CHLORINE TOTAL	1.07 mg/l	No regulatory limit
08/07/2025	CHLORINE TOTAL	0.79 mg/l	No regulatory limit
09/07/2025	CHLORINE TOTAL	1.05 mg/l	No regulatory limit
10/07/2025	CHLORINE TOTAL	0.97 mg/l	No regulatory limit
11/07/2025	CHLORINE TOTAL	1.12 mg/l	No regulatory limit
15/07/2025	CHLORINE TOTAL	1.1 mg/l	No regulatory limit
21/07/2025	CHLORINE TOTAL	1.16 mg/l	No regulatory limit

23/07/2025	CHLORINE TOTAL	1 mg/l	No regulatory limit
24/07/2025	CHLORINE TOTAL	1.01 mg/l	No regulatory limit
25/07/2025	CHLORINE TOTAL	0.9 mg/l	No regulatory limit
29/07/2025	CHLORINE TOTAL	0.92 mg/l	No regulatory limit
30/07/2025	CHLORINE TOTAL	1.12 mg/l	No regulatory limit
01/08/2025	CHLORINE TOTAL	0.99 mg/l	No regulatory limit
07/08/2025	CHLORINE TOTAL	1.38 mg/l	No regulatory limit
08/08/2025	CHLORINE TOTAL	1.09 mg/l	No regulatory limit
13/08/2025	CHLORINE TOTAL	1.21 mg/l	No regulatory limit
28/08/2025	CHLORINE TOTAL	1.03 mg/l	No regulatory limit
03/09/2025	CHLORINE TOTAL	1.11 mg/l	No regulatory limit
05/09/2025	CHLORINE TOTAL	1.04 mg/l	No regulatory limit
06/09/2025	CHLORINE TOTAL	1.09 mg/l	No regulatory limit
10/09/2025	CHLORINE TOTAL	1.07 mg/l	No regulatory limit
12/09/2025	CHLORINE TOTAL	1.04 mg/l	No regulatory limit
16/09/2025	CHLORINE TOTAL	0.99 mg/l	No regulatory limit
17/09/2025	CHLORINE TOTAL	0.81 mg/l	No regulatory limit
29/09/2025	CHLORINE TOTAL	0.22 mg/l	No regulatory limit
30/09/2025	CHLORINE TOTAL	0.83 mg/l	No regulatory limit
03/10/2025	CHLORINE TOTAL	0.95 mg/l	No regulatory limit
05/10/2025	CHLORINE TOTAL	1.42 mg/l	No regulatory limit
06/10/2025	CHLORINE TOTAL	1.58 mg/l	No regulatory limit
08/10/2025	CHLORINE TOTAL	0.77 mg/l	No regulatory limit
10/10/2025	CHLORINE TOTAL	1.3 mg/l	No regulatory limit
14/10/2025	CHLORINE TOTAL	0.86 mg/l	No regulatory limit
15/10/2025	CHLORINE TOTAL	0.76 mg/l	No regulatory limit
18/10/2025	CHLORINE TOTAL	0.98 mg/l	No regulatory limit
20/10/2025	CHLORINE TOTAL	0.96 mg/l	No regulatory limit
22/10/2025	CHLORINE TOTAL	1.3 mg/l	No regulatory limit
23/10/2025	CHLORINE TOTAL	1.16 mg/l	No regulatory limit
24/10/2025	CHLORINE TOTAL	0.52 mg/l	No regulatory limit
27/10/2025	CHLORINE TOTAL	0.87 mg/l	No regulatory limit
28/10/2025	CHLORINE TOTAL	1.14 mg/l	No regulatory limit
29/10/2025	CHLORINE TOTAL	1.09 mg/l	No regulatory limit
31/10/2025	CHLORINE TOTAL	0.78 mg/l	No regulatory limit
03/11/2025	CHLORINE TOTAL	1.02 mg/l	No regulatory limit
05/11/2025	CHLORINE TOTAL	0.9 mg/l	No regulatory limit
08/11/2025	CHLORINE TOTAL	0.89 mg/l	No regulatory limit
10/11/2025	CHLORINE TOTAL	0.8 mg/l	No regulatory limit
12/11/2025	CHLORINE TOTAL	1.13 mg/l	No regulatory limit
17/11/2025	CHLORINE TOTAL	0.81 mg/l	No regulatory limit
18/11/2025	CHLORINE TOTAL	1.27 mg/l	No regulatory limit
19/11/2025	CHLORINE TOTAL	1.34 mg/l	No regulatory limit
20/11/2025	CHLORINE TOTAL	1.26 mg/l	No regulatory limit
21/11/2025	CHLORINE TOTAL	1.07 mg/l	No regulatory limit
24/11/2025	CHLORINE TOTAL	1.11 mg/l	No regulatory limit
26/11/2025	CHLORINE TOTAL	0.94 mg/l	No regulatory limit
27/11/2025	CHLORINE TOTAL	0.83 mg/l	No regulatory limit

02/12/2025	CHLORINE TOTAL		1.25 mg/l	No regulatory limit
03/12/2025	CHLORINE TOTAL		0.63 mg/l	No regulatory limit
05/12/2025	CHLORINE TOTAL		1.12 mg/l	No regulatory limit
09/12/2025	CHLORINE TOTAL		1.12 mg/l	No regulatory limit
11/12/2025	CHLORINE TOTAL		1 mg/l	No regulatory limit
12/12/2025	CHLORINE TOTAL		1.16 mg/l	No regulatory limit
15/12/2025	CHLORINE TOTAL		1.29 mg/l	No regulatory limit
16/12/2025	CHLORINE TOTAL		1.23 mg/l	No regulatory limit
18/12/2025	CHLORINE TOTAL		0.9 mg/l	No regulatory limit
19/12/2025	CHLORINE TOTAL		1.3 mg/l	No regulatory limit
22/12/2025	CHLORINE TOTAL		1.25 mg/l	No regulatory limit
23/12/2025	CHLORINE TOTAL		1.21 mg/l	No regulatory limit
24/12/2025	CHLORINE TOTAL		1.03 mg/l	No regulatory limit
06/01/2026	CHLORINE TOTAL		0.6 mg/l	No regulatory limit
08/01/2026	CHLORINE TOTAL		0.79 mg/l	No regulatory limit
09/01/2026	CHLORINE TOTAL		1.12 mg/l	No regulatory limit
13/01/2026	CHLORINE TOTAL		1.01 mg/l	No regulatory limit
14/01/2026	CHLORINE TOTAL		0.84 mg/l	No regulatory limit
15/01/2026	CHLORINE TOTAL		1.17 mg/l	No regulatory limit
19/01/2026	CHLORINE TOTAL		0.93 mg/l	No regulatory limit
20/01/2026	CHLORINE TOTAL		1.08 mg/l	No regulatory limit
21/01/2026	CHLORINE TOTAL		1.21 mg/l	No regulatory limit
27/01/2026	CHLORINE TOTAL		1.23 mg/l	No regulatory limit
28/01/2026	CHLORINE TOTAL		1.12 mg/l	No regulatory limit
29/01/2026	CHLORINE TOTAL		1.47 mg/l	No regulatory limit
30/01/2026	CHLORINE TOTAL		1.36 mg/l	No regulatory limit
02/02/2026	CHLORINE TOTAL		1.41 mg/l	No regulatory limit
05/02/2026	CHLORINE TOTAL		1.29 mg/l	No regulatory limit
09/02/2026	CHLORINE TOTAL		1.03 mg/l	No regulatory limit
10/02/2026	CHLORINE TOTAL		1.42 mg/l	No regulatory limit
11/02/2026	CHLORINE TOTAL		1.29 mg/l	No regulatory limit
13/02/2026	CHLORINE TOTAL		1.01 mg/l	No regulatory limit
17/02/2026	CHLORINE TOTAL		1.48 mg/l	No regulatory limit
26/03/2021	CHROMIUM	<	0.16 µg/l	50
07/04/2021	CHROMIUM	<	0.16 µg/l	50
09/06/2021	CHROMIUM	<	0.16 µg/l	50
14/06/2021	CHROMIUM	<	0.16 µg/l	50
09/07/2021	CHROMIUM	<	0.16 µg/l	50
06/12/2021	CHROMIUM	<	0.16 µg/l	50
14/12/2021	CHROMIUM	<	0.16 µg/l	50
22/12/2021	CHROMIUM	<	0.83 µg/l	50
07/01/2022	CHROMIUM		3.04 µg/l	50
04/03/2022	CHROMIUM	<	0.83 µg/l	50
08/04/2022	CHROMIUM	<	0.83 µg/l	50
04/05/2022	CHROMIUM	<	0.83 µg/l	50
28/06/2022	CHROMIUM		2.17 µg/l	50
10/08/2022	CHROMIUM	<	0.83 µg/l	50
07/09/2022	CHROMIUM	<	0.83 µg/l	50

10/11/2022	CHROMIUM	<	0.83 µg/l	50
27/01/2023	CHROMIUM	<	0.83 µg/l	50
24/02/2023	CHROMIUM	<	0.83 µg/l	50
10/05/2023	CHROMIUM	<	0.83 µg/l	50
30/05/2023	CHROMIUM	<	0.83 µg/l	50
14/07/2023	CHROMIUM	<	0.83 µg/l	50
31/10/2023	CHROMIUM	<	0.83 µg/l	50
16/11/2023	CHROMIUM	<	0.83 µg/l	50
23/11/2023	CHROMIUM	<	0.83 µg/l	50
05/01/2024	CHROMIUM	<	0.83 µg/l	50
06/02/2024	CHROMIUM	<	0.83 µg/l	50
26/03/2024	CHROMIUM	<	0.83 µg/l	50
15/05/2024	CHROMIUM	<	0.83 µg/l	50
07/08/2024	CHROMIUM	<	0.83 µg/l	50
26/09/2024	CHROMIUM	<	0.83 µg/l	50
09/10/2024	CHROMIUM	<	0.83 µg/l	50
21/11/2024	CHROMIUM	<	0.83 µg/l	50
12/02/2025	CHROMIUM	<	0.83 µg/l	50
21/03/2025	CHROMIUM	<	0.83 µg/l	50
07/05/2025	CHROMIUM	<	0.83 µg/l	50
09/06/2025	CHROMIUM	<	0.83 µg/l	50
29/09/2025	CHROMIUM	<	0.83 µg/l	50
22/10/2025	CHROMIUM	<	0.83 µg/l	50
24/11/2025	CHROMIUM	<	0.83 µg/l	50
22/12/2025	CHROMIUM	<	0.83 µg/l	50
28/01/2026	CHROMIUM	<	0.83 µg/l	50
21/05/2021	CLOSTRIDIUM PERFRINGENS		0 No/100ml	0
07/06/2021	CLOSTRIDIUM PERFRINGENS		0 No/100ml	0
22/07/2021	CLOSTRIDIUM PERFRINGENS		0 No/100ml	0
23/07/2021	CLOSTRIDIUM PERFRINGENS		0 No/100ml	0
08/08/2021	CLOSTRIDIUM PERFRINGENS		0 No/100ml	0
05/10/2021	CLOSTRIDIUM PERFRINGENS		0 No/100ml	0
05/11/2021	CLOSTRIDIUM PERFRINGENS		0 No/100ml	0
21/12/2021	CLOSTRIDIUM PERFRINGENS		0 No/100ml	0
09/02/2022	CLOSTRIDIUM PERFRINGENS		0 No/100ml	0
18/02/2022	CLOSTRIDIUM PERFRINGENS		0 No/100ml	0
22/03/2022	CLOSTRIDIUM PERFRINGENS		0 No/100ml	0
20/04/2022	CLOSTRIDIUM PERFRINGENS		0 No/100ml	0
01/06/2022	CLOSTRIDIUM PERFRINGENS		0 No/100ml	0
27/07/2022	CLOSTRIDIUM PERFRINGENS		0 No/100ml	0
14/11/2022	CLOSTRIDIUM PERFRINGENS		0 No/100ml	0
14/12/2022	CLOSTRIDIUM PERFRINGENS		0 No/100ml	0
16/12/2022	CLOSTRIDIUM PERFRINGENS		0 No/100ml	0
01/02/2023	CLOSTRIDIUM PERFRINGENS		0 No/100ml	0
31/03/2023	CLOSTRIDIUM PERFRINGENS		0 No/100ml	0
11/04/2023	CLOSTRIDIUM PERFRINGENS		0 No/100ml	0
19/05/2023	CLOSTRIDIUM PERFRINGENS		0 No/100ml	0
14/07/2023	CLOSTRIDIUM PERFRINGENS		0 No/100ml	0

22/09/2023	CLOSTRIDIUM PERFRINGENS	0 No/100ml	0
15/11/2023	CLOSTRIDIUM PERFRINGENS	0 No/100ml	0
17/11/2023	CLOSTRIDIUM PERFRINGENS	0 No/100ml	0
04/12/2023	CLOSTRIDIUM PERFRINGENS	0 No/100ml	0
05/01/2024	CLOSTRIDIUM PERFRINGENS	0 No/100ml	0
09/01/2024	CLOSTRIDIUM PERFRINGENS	0 No/100ml	0
08/03/2024	CLOSTRIDIUM PERFRINGENS	0 No/100ml	0
19/04/2024	CLOSTRIDIUM PERFRINGENS	0 No/100ml	0
19/07/2024	CLOSTRIDIUM PERFRINGENS	0 No/100ml	0
31/07/2024	CLOSTRIDIUM PERFRINGENS	0 No/100ml	0
02/10/2024	CLOSTRIDIUM PERFRINGENS	0 No/100ml	0
09/10/2024	CLOSTRIDIUM PERFRINGENS	0 No/100ml	0
13/11/2024	CLOSTRIDIUM PERFRINGENS	0 No/100ml	0
12/02/2025	CLOSTRIDIUM PERFRINGENS	0 No/100ml	0
21/03/2025	CLOSTRIDIUM PERFRINGENS	0 No/100ml	0
22/04/2025	CLOSTRIDIUM PERFRINGENS	0 No/100ml	0
17/05/2025	CLOSTRIDIUM PERFRINGENS	0 No/100ml	0
01/08/2025	CLOSTRIDIUM PERFRINGENS	0 No/100ml	0
05/09/2025	CLOSTRIDIUM PERFRINGENS	0 No/100ml	0
28/10/2025	CLOSTRIDIUM PERFRINGENS	0 No/100ml	0
03/12/2025	CLOSTRIDIUM PERFRINGENS	0 No/100ml	0
11/02/2026	CLOSTRIDIUM PERFRINGENS	0 No/100ml	0
03/03/2021	COLIFORM BACTERIA	0 No/100ml	0
10/03/2021	COLIFORM BACTERIA	0 No/100ml	0
11/03/2021	COLIFORM BACTERIA	0 No/100ml	0
14/03/2021	COLIFORM BACTERIA	0 No/100ml	0
19/03/2021	COLIFORM BACTERIA	0 No/100ml	0
20/03/2021	COLIFORM BACTERIA	0 No/100ml	0
21/03/2021	COLIFORM BACTERIA	0 No/100ml	0
25/03/2021	COLIFORM BACTERIA	0 No/100ml	0
26/03/2021	COLIFORM BACTERIA	0 No/100ml	0
29/03/2021	COLIFORM BACTERIA	0 No/100ml	0
30/03/2021	COLIFORM BACTERIA	0 No/100ml	0
31/03/2021	COLIFORM BACTERIA	0 No/100ml	0
01/04/2021	COLIFORM BACTERIA	0 No/100ml	0
04/04/2021	COLIFORM BACTERIA	0 No/100ml	0
07/04/2021	COLIFORM BACTERIA	0 No/100ml	0
08/04/2021	COLIFORM BACTERIA	0 No/100ml	0
09/04/2021	COLIFORM BACTERIA	0 No/100ml	0
10/04/2021	COLIFORM BACTERIA	0 No/100ml	0
18/04/2021	COLIFORM BACTERIA	0 No/100ml	0
23/04/2021	COLIFORM BACTERIA	0 No/100ml	0
06/05/2021	COLIFORM BACTERIA	0 No/100ml	0
08/05/2021	COLIFORM BACTERIA	0 No/100ml	0
10/05/2021	COLIFORM BACTERIA	0 No/100ml	0
11/05/2021	COLIFORM BACTERIA	0 No/100ml	0
12/05/2021	COLIFORM BACTERIA	0 No/100ml	0
14/05/2021	COLIFORM BACTERIA	0 No/100ml	0

17/05/2021	COLIFORM BACTERIA	0 No/100ml	0
19/05/2021	COLIFORM BACTERIA	0 No/100ml	0
20/05/2021	COLIFORM BACTERIA	0 No/100ml	0
21/05/2021	COLIFORM BACTERIA	0 No/100ml	0
22/05/2021	COLIFORM BACTERIA	0 No/100ml	0
25/05/2021	COLIFORM BACTERIA	0 No/100ml	0
26/05/2021	COLIFORM BACTERIA	0 No/100ml	0
27/05/2021	COLIFORM BACTERIA	0 No/100ml	0
28/05/2021	COLIFORM BACTERIA	0 No/100ml	0
29/05/2021	COLIFORM BACTERIA	0 No/100ml	0
30/05/2021	COLIFORM BACTERIA	0 No/100ml	0
02/06/2021	COLIFORM BACTERIA	0 No/100ml	0
04/06/2021	COLIFORM BACTERIA	0 No/100ml	0
07/06/2021	COLIFORM BACTERIA	0 No/100ml	0
08/06/2021	COLIFORM BACTERIA	0 No/100ml	0
09/06/2021	COLIFORM BACTERIA	0 No/100ml	0
11/06/2021	COLIFORM BACTERIA	0 No/100ml	0
14/06/2021	COLIFORM BACTERIA	0 No/100ml	0
15/06/2021	COLIFORM BACTERIA	0 No/100ml	0
23/06/2021	COLIFORM BACTERIA	0 No/100ml	0
24/06/2021	COLIFORM BACTERIA	0 No/100ml	0
25/06/2021	COLIFORM BACTERIA	0 No/100ml	0
29/06/2021	COLIFORM BACTERIA	0 No/100ml	0
30/06/2021	COLIFORM BACTERIA	0 No/100ml	0
01/07/2021	COLIFORM BACTERIA	0 No/100ml	0
02/07/2021	COLIFORM BACTERIA	0 No/100ml	0
06/07/2021	COLIFORM BACTERIA	0 No/100ml	0
07/07/2021	COLIFORM BACTERIA	0 No/100ml	0
08/07/2021	COLIFORM BACTERIA	0 No/100ml	0
09/07/2021	COLIFORM BACTERIA	0 No/100ml	0
12/07/2021	COLIFORM BACTERIA	0 No/100ml	0
14/07/2021	COLIFORM BACTERIA	0 No/100ml	0
15/07/2021	COLIFORM BACTERIA	0 No/100ml	0
21/07/2021	COLIFORM BACTERIA	0 No/100ml	0
22/07/2021	COLIFORM BACTERIA	0 No/100ml	0
23/07/2021	COLIFORM BACTERIA	0 No/100ml	0
26/07/2021	COLIFORM BACTERIA	0 No/100ml	0
03/08/2021	COLIFORM BACTERIA	0 No/100ml	0
06/08/2021	COLIFORM BACTERIA	0 No/100ml	0
07/08/2021	COLIFORM BACTERIA	0 No/100ml	0
08/08/2021	COLIFORM BACTERIA	0 No/100ml	0
09/08/2021	COLIFORM BACTERIA	0 No/100ml	0
16/08/2021	COLIFORM BACTERIA	0 No/100ml	0
25/08/2021	COLIFORM BACTERIA	0 No/100ml	0
27/08/2021	COLIFORM BACTERIA	0 No/100ml	0
01/09/2021	COLIFORM BACTERIA	0 No/100ml	0
06/09/2021	COLIFORM BACTERIA	0 No/100ml	0
09/09/2021	COLIFORM BACTERIA	0 No/100ml	0

24/09/2021	COLIFORM BACTERIA	0 No/100ml	0
28/09/2021	COLIFORM BACTERIA	0 No/100ml	0
29/09/2021	COLIFORM BACTERIA	0 No/100ml	0
30/09/2021	COLIFORM BACTERIA	0 No/100ml	0
01/10/2021	COLIFORM BACTERIA	0 No/100ml	0
04/10/2021	COLIFORM BACTERIA	0 No/100ml	0
05/10/2021	COLIFORM BACTERIA	0 No/100ml	0
07/10/2021	COLIFORM BACTERIA	0 No/100ml	0
13/10/2021	COLIFORM BACTERIA	0 No/100ml	0
14/10/2021	COLIFORM BACTERIA	0 No/100ml	0
17/10/2021	COLIFORM BACTERIA	0 No/100ml	0
18/10/2021	COLIFORM BACTERIA	0 No/100ml	0
19/10/2021	COLIFORM BACTERIA	0 No/100ml	0
20/10/2021	COLIFORM BACTERIA	0 No/100ml	0
21/10/2021	COLIFORM BACTERIA	0 No/100ml	0
22/10/2021	COLIFORM BACTERIA	0 No/100ml	0
25/10/2021	COLIFORM BACTERIA	0 No/100ml	0
26/10/2021	COLIFORM BACTERIA	0 No/100ml	0
28/10/2021	COLIFORM BACTERIA	0 No/100ml	0
29/10/2021	COLIFORM BACTERIA	0 No/100ml	0
30/10/2021	COLIFORM BACTERIA	0 No/100ml	0
03/11/2021	COLIFORM BACTERIA	0 No/100ml	0
04/11/2021	COLIFORM BACTERIA	0 No/100ml	0
05/11/2021	COLIFORM BACTERIA	0 No/100ml	0
08/11/2021	COLIFORM BACTERIA	0 No/100ml	0
10/11/2021	COLIFORM BACTERIA	0 No/100ml	0
11/11/2021	COLIFORM BACTERIA	0 No/100ml	0
13/11/2021	COLIFORM BACTERIA	0 No/100ml	0
15/11/2021	COLIFORM BACTERIA	0 No/100ml	0
16/11/2021	COLIFORM BACTERIA	0 No/100ml	0
18/11/2021	COLIFORM BACTERIA	0 No/100ml	0
19/11/2021	COLIFORM BACTERIA	0 No/100ml	0
22/11/2021	COLIFORM BACTERIA	0 No/100ml	0
23/11/2021	COLIFORM BACTERIA	0 No/100ml	0
25/11/2021	COLIFORM BACTERIA	0 No/100ml	0
29/11/2021	COLIFORM BACTERIA	0 No/100ml	0
30/11/2021	COLIFORM BACTERIA	0 No/100ml	0
02/12/2021	COLIFORM BACTERIA	0 No/100ml	0
03/12/2021	COLIFORM BACTERIA	0 No/100ml	0
04/12/2021	COLIFORM BACTERIA	0 No/100ml	0
06/12/2021	COLIFORM BACTERIA	0 No/100ml	0
07/12/2021	COLIFORM BACTERIA	0 No/100ml	0
08/12/2021	COLIFORM BACTERIA	0 No/100ml	0
09/12/2021	COLIFORM BACTERIA	0 No/100ml	0
09/12/2021	COLIFORM BACTERIA	0 No/100ml	0
10/12/2021	COLIFORM BACTERIA	0 No/100ml	0
10/12/2021	COLIFORM BACTERIA	0 No/100ml	0
11/12/2021	COLIFORM BACTERIA	0 No/100ml	0

13/12/2021	COLIFORM BACTERIA	0 No/100ml	0
14/12/2021	COLIFORM BACTERIA	0 No/100ml	0
15/12/2021	COLIFORM BACTERIA	0 No/100ml	0
15/12/2021	COLIFORM BACTERIA	0 No/100ml	0
16/12/2021	COLIFORM BACTERIA	0 No/100ml	0
17/12/2021	COLIFORM BACTERIA	0 No/100ml	0
17/12/2021	COLIFORM BACTERIA	0 No/100ml	0
18/12/2021	COLIFORM BACTERIA	0 No/100ml	0
19/12/2021	COLIFORM BACTERIA	0 No/100ml	0
20/12/2021	COLIFORM BACTERIA	0 No/100ml	0
20/12/2021	COLIFORM BACTERIA	0 No/100ml	0
21/12/2021	COLIFORM BACTERIA	0 No/100ml	0
21/12/2021	COLIFORM BACTERIA	0 No/100ml	0
22/12/2021	COLIFORM BACTERIA	0 No/100ml	0
22/12/2021	COLIFORM BACTERIA	0 No/100ml	0
23/12/2021	COLIFORM BACTERIA	0 No/100ml	0
05/01/2022	COLIFORM BACTERIA	0 No/100ml	0
07/01/2022	COLIFORM BACTERIA	0 No/100ml	0
12/01/2022	COLIFORM BACTERIA	0 No/100ml	0
14/01/2022	COLIFORM BACTERIA	0 No/100ml	0
19/01/2022	COLIFORM BACTERIA	0 No/100ml	0
24/01/2022	COLIFORM BACTERIA	0 No/100ml	0
25/01/2022	COLIFORM BACTERIA	0 No/100ml	0
27/01/2022	COLIFORM BACTERIA	0 No/100ml	0
28/01/2022	COLIFORM BACTERIA	0 No/100ml	0
31/01/2022	COLIFORM BACTERIA	0 No/100ml	0
01/02/2022	COLIFORM BACTERIA	0 No/100ml	0
04/02/2022	COLIFORM BACTERIA	0 No/100ml	0
07/02/2022	COLIFORM BACTERIA	0 No/100ml	0
08/02/2022	COLIFORM BACTERIA	0 No/100ml	0
09/02/2022	COLIFORM BACTERIA	0 No/100ml	0
11/02/2022	COLIFORM BACTERIA	0 No/100ml	0
16/02/2022	COLIFORM BACTERIA	0 No/100ml	0
18/02/2022	COLIFORM BACTERIA	0 No/100ml	0
21/02/2022	COLIFORM BACTERIA	0 No/100ml	0
22/02/2022	COLIFORM BACTERIA	0 No/100ml	0
25/02/2022	COLIFORM BACTERIA	0 No/100ml	0
26/02/2022	COLIFORM BACTERIA	0 No/100ml	0
01/03/2022	COLIFORM BACTERIA	0 No/100ml	0
01/03/2022	COLIFORM BACTERIA	0 No/100ml	0
02/03/2022	COLIFORM BACTERIA	0 No/100ml	0
03/03/2022	COLIFORM BACTERIA	0 No/100ml	0
04/03/2022	COLIFORM BACTERIA	0 No/100ml	0
10/03/2022	COLIFORM BACTERIA	0 No/100ml	0
15/03/2022	COLIFORM BACTERIA	0 No/100ml	0
16/03/2022	COLIFORM BACTERIA	0 No/100ml	0
17/03/2022	COLIFORM BACTERIA	0 No/100ml	0
21/03/2022	COLIFORM BACTERIA	0 No/100ml	0

22/03/2022	COLIFORM BACTERIA	0 No/100ml	0
24/03/2022	COLIFORM BACTERIA	0 No/100ml	0
28/03/2022	COLIFORM BACTERIA	0 No/100ml	0
30/03/2022	COLIFORM BACTERIA	0 No/100ml	0
31/03/2022	COLIFORM BACTERIA	0 No/100ml	0
05/04/2022	COLIFORM BACTERIA	0 No/100ml	0
07/04/2022	COLIFORM BACTERIA	0 No/100ml	0
08/04/2022	COLIFORM BACTERIA	0 No/100ml	0
11/04/2022	COLIFORM BACTERIA	0 No/100ml	0
12/04/2022	COLIFORM BACTERIA	0 No/100ml	0
13/04/2022	COLIFORM BACTERIA	0 No/100ml	0
14/04/2022	COLIFORM BACTERIA	0 No/100ml	0
19/04/2022	COLIFORM BACTERIA	0 No/100ml	0
20/04/2022	COLIFORM BACTERIA	0 No/100ml	0
21/04/2022	COLIFORM BACTERIA	0 No/100ml	0
25/04/2022	COLIFORM BACTERIA	0 No/100ml	0
28/04/2022	COLIFORM BACTERIA	0 No/100ml	0
03/05/2022	COLIFORM BACTERIA	0 No/100ml	0
04/05/2022	COLIFORM BACTERIA	0 No/100ml	0
05/05/2022	COLIFORM BACTERIA	0 No/100ml	0
09/05/2022	COLIFORM BACTERIA	0 No/100ml	0
10/05/2022	COLIFORM BACTERIA	0 No/100ml	0
12/05/2022	COLIFORM BACTERIA	0 No/100ml	0
16/05/2022	COLIFORM BACTERIA	0 No/100ml	0
17/05/2022	COLIFORM BACTERIA	0 No/100ml	0
18/05/2022	COLIFORM BACTERIA	0 No/100ml	0
19/05/2022	COLIFORM BACTERIA	0 No/100ml	0
23/05/2022	COLIFORM BACTERIA	0 No/100ml	0
24/05/2022	COLIFORM BACTERIA	0 No/100ml	0
25/05/2022	COLIFORM BACTERIA	0 No/100ml	0
27/05/2022	COLIFORM BACTERIA	0 No/100ml	0
01/06/2022	COLIFORM BACTERIA	0 No/100ml	0
04/06/2022	COLIFORM BACTERIA	0 No/100ml	0
05/06/2022	COLIFORM BACTERIA	0 No/100ml	0
07/06/2022	COLIFORM BACTERIA	0 No/100ml	0
09/06/2022	COLIFORM BACTERIA	0 No/100ml	0
10/06/2022	COLIFORM BACTERIA	0 No/100ml	0
13/06/2022	COLIFORM BACTERIA	0 No/100ml	0
15/06/2022	COLIFORM BACTERIA	0 No/100ml	0
16/06/2022	COLIFORM BACTERIA	0 No/100ml	0
17/06/2022	COLIFORM BACTERIA	0 No/100ml	0
20/06/2022	COLIFORM BACTERIA	0 No/100ml	0
21/06/2022	COLIFORM BACTERIA	0 No/100ml	0
24/06/2022	COLIFORM BACTERIA	0 No/100ml	0
28/06/2022	COLIFORM BACTERIA	0 No/100ml	0
01/07/2022	COLIFORM BACTERIA	0 No/100ml	0
06/07/2022	COLIFORM BACTERIA	0 No/100ml	0
07/07/2022	COLIFORM BACTERIA	0 No/100ml	0

08/07/2022	COLIFORM BACTERIA	0 No/100ml	0
11/07/2022	COLIFORM BACTERIA	0 No/100ml	0
20/07/2022	COLIFORM BACTERIA	0 No/100ml	0
21/07/2022	COLIFORM BACTERIA	0 No/100ml	0
26/07/2022	COLIFORM BACTERIA	0 No/100ml	0
27/07/2022	COLIFORM BACTERIA	0 No/100ml	0
29/07/2022	COLIFORM BACTERIA	0 No/100ml	0
05/08/2022	COLIFORM BACTERIA	0 No/100ml	0
09/08/2022	COLIFORM BACTERIA	0 No/100ml	0
10/08/2022	COLIFORM BACTERIA	0 No/100ml	0
11/08/2022	COLIFORM BACTERIA	0 No/100ml	0
15/08/2022	COLIFORM BACTERIA	0 No/100ml	0
18/08/2022	COLIFORM BACTERIA	0 No/100ml	0
19/08/2022	COLIFORM BACTERIA	0 No/100ml	0
23/08/2022	COLIFORM BACTERIA	0 No/100ml	0
24/08/2022	COLIFORM BACTERIA	0 No/100ml	0
27/08/2022	COLIFORM BACTERIA	0 No/100ml	0
28/08/2022	COLIFORM BACTERIA	0 No/100ml	0
07/09/2022	COLIFORM BACTERIA	0 No/100ml	0
08/09/2022	COLIFORM BACTERIA	0 No/100ml	0
14/09/2022	COLIFORM BACTERIA	0 No/100ml	0
15/09/2022	COLIFORM BACTERIA	0 No/100ml	0
20/09/2022	COLIFORM BACTERIA	0 No/100ml	0
22/09/2022	COLIFORM BACTERIA	0 No/100ml	0
28/09/2022	COLIFORM BACTERIA	0 No/100ml	0
29/09/2022	COLIFORM BACTERIA	0 No/100ml	0
04/10/2022	COLIFORM BACTERIA	0 No/100ml	0
05/10/2022	COLIFORM BACTERIA	0 No/100ml	0
17/10/2022	COLIFORM BACTERIA	0 No/100ml	0
20/10/2022	COLIFORM BACTERIA	0 No/100ml	0
26/10/2022	COLIFORM BACTERIA	0 No/100ml	0
01/11/2022	COLIFORM BACTERIA	0 No/100ml	0
03/11/2022	COLIFORM BACTERIA	0 No/100ml	0
07/11/2022	COLIFORM BACTERIA	0 No/100ml	0
08/11/2022	COLIFORM BACTERIA	0 No/100ml	0
10/11/2022	COLIFORM BACTERIA	0 No/100ml	0
14/11/2022	COLIFORM BACTERIA	0 No/100ml	0
15/11/2022	COLIFORM BACTERIA	0 No/100ml	0
16/11/2022	COLIFORM BACTERIA	0 No/100ml	0
18/11/2022	COLIFORM BACTERIA	0 No/100ml	0
19/11/2022	COLIFORM BACTERIA	0 No/100ml	0
22/11/2022	COLIFORM BACTERIA	0 No/100ml	0
24/11/2022	COLIFORM BACTERIA	0 No/100ml	0
28/11/2022	COLIFORM BACTERIA	0 No/100ml	0
29/11/2022	COLIFORM BACTERIA	0 No/100ml	0
30/11/2022	COLIFORM BACTERIA	0 No/100ml	0
05/12/2022	COLIFORM BACTERIA	0 No/100ml	0
06/12/2022	COLIFORM BACTERIA	0 No/100ml	0

07/12/2022	COLIFORM BACTERIA	0 No/100ml	0
09/12/2022	COLIFORM BACTERIA	0 No/100ml	0
12/12/2022	COLIFORM BACTERIA	0 No/100ml	0
14/12/2022	COLIFORM BACTERIA	0 No/100ml	0
16/12/2022	COLIFORM BACTERIA	0 No/100ml	0
17/12/2022	COLIFORM BACTERIA	0 No/100ml	0
03/01/2023	COLIFORM BACTERIA	0 No/100ml	0
10/01/2023	COLIFORM BACTERIA	0 No/100ml	0
11/01/2023	COLIFORM BACTERIA	0 No/100ml	0
16/01/2023	COLIFORM BACTERIA	0 No/100ml	0
17/01/2023	COLIFORM BACTERIA	0 No/100ml	0
18/01/2023	COLIFORM BACTERIA	0 No/100ml	0
24/01/2023	COLIFORM BACTERIA	0 No/100ml	0
27/01/2023	COLIFORM BACTERIA	0 No/100ml	0
01/02/2023	COLIFORM BACTERIA	0 No/100ml	0
02/02/2023	COLIFORM BACTERIA	0 No/100ml	0
07/02/2023	COLIFORM BACTERIA	0 No/100ml	0
09/02/2023	COLIFORM BACTERIA	0 No/100ml	0
10/02/2023	COLIFORM BACTERIA	0 No/100ml	0
11/02/2023	COLIFORM BACTERIA	0 No/100ml	0
20/02/2023	COLIFORM BACTERIA	0 No/100ml	0
22/02/2023	COLIFORM BACTERIA	0 No/100ml	0
24/02/2023	COLIFORM BACTERIA	0 No/100ml	0
27/02/2023	COLIFORM BACTERIA	0 No/100ml	0
28/02/2023	COLIFORM BACTERIA	0 No/100ml	0
01/03/2023	COLIFORM BACTERIA	0 No/100ml	0
02/03/2023	COLIFORM BACTERIA	0 No/100ml	0
06/03/2023	COLIFORM BACTERIA	0 No/100ml	0
08/03/2023	COLIFORM BACTERIA	0 No/100ml	0
14/03/2023	COLIFORM BACTERIA	0 No/100ml	0
20/03/2023	COLIFORM BACTERIA	0 No/100ml	0
22/03/2023	COLIFORM BACTERIA	0 No/100ml	0
24/03/2023	COLIFORM BACTERIA	0 No/100ml	0
29/03/2023	COLIFORM BACTERIA	0 No/100ml	0
31/03/2023	COLIFORM BACTERIA	0 No/100ml	0
04/04/2023	COLIFORM BACTERIA	0 No/100ml	0
05/04/2023	COLIFORM BACTERIA	0 No/100ml	0
06/04/2023	COLIFORM BACTERIA	0 No/100ml	0
08/04/2023	COLIFORM BACTERIA	0 No/100ml	0
11/04/2023	COLIFORM BACTERIA	0 No/100ml	0
18/04/2023	COLIFORM BACTERIA	0 No/100ml	0
19/04/2023	COLIFORM BACTERIA	0 No/100ml	0
21/04/2023	COLIFORM BACTERIA	0 No/100ml	0
25/04/2023	COLIFORM BACTERIA	0 No/100ml	0
26/04/2023	COLIFORM BACTERIA	0 No/100ml	0
27/04/2023	COLIFORM BACTERIA	0 No/100ml	0
02/05/2023	COLIFORM BACTERIA	0 No/100ml	0
05/05/2023	COLIFORM BACTERIA	0 No/100ml	0

09/05/2023	COLIFORM BACTERIA	0 No/100ml	0
10/05/2023	COLIFORM BACTERIA	0 No/100ml	0
13/05/2023	COLIFORM BACTERIA	0 No/100ml	0
15/05/2023	COLIFORM BACTERIA	0 No/100ml	0
17/05/2023	COLIFORM BACTERIA	0 No/100ml	0
19/05/2023	COLIFORM BACTERIA	0 No/100ml	0
20/05/2023	COLIFORM BACTERIA	0 No/100ml	0
24/05/2023	COLIFORM BACTERIA	0 No/100ml	0
30/05/2023	COLIFORM BACTERIA	0 No/100ml	0
01/06/2023	COLIFORM BACTERIA	0 No/100ml	0
06/06/2023	COLIFORM BACTERIA	0 No/100ml	0
07/06/2023	COLIFORM BACTERIA	0 No/100ml	0
08/06/2023	COLIFORM BACTERIA	0 No/100ml	0
09/06/2023	COLIFORM BACTERIA	0 No/100ml	0
12/06/2023	COLIFORM BACTERIA	0 No/100ml	0
14/06/2023	COLIFORM BACTERIA	0 No/100ml	0
15/06/2023	COLIFORM BACTERIA	0 No/100ml	0
19/06/2023	COLIFORM BACTERIA	0 No/100ml	0
28/06/2023	COLIFORM BACTERIA	0 No/100ml	0
29/06/2023	COLIFORM BACTERIA	0 No/100ml	0
30/06/2023	COLIFORM BACTERIA	0 No/100ml	0
04/07/2023	COLIFORM BACTERIA	0 No/100ml	0
05/07/2023	COLIFORM BACTERIA	10 No/100ml	0
07/07/2023	COLIFORM BACTERIA	0 No/100ml	0
11/07/2023	COLIFORM BACTERIA	0 No/100ml	0
12/07/2023	COLIFORM BACTERIA	0 No/100ml	0
13/07/2023	COLIFORM BACTERIA	0 No/100ml	0
14/07/2023	COLIFORM BACTERIA	0 No/100ml	0
17/07/2023	COLIFORM BACTERIA	0 No/100ml	0
18/07/2023	COLIFORM BACTERIA	0 No/100ml	0
19/07/2023	COLIFORM BACTERIA	0 No/100ml	0
25/07/2023	COLIFORM BACTERIA	0 No/100ml	0
27/07/2023	COLIFORM BACTERIA	0 No/100ml	0
28/07/2023	COLIFORM BACTERIA	0 No/100ml	0
28/07/2023	COLIFORM BACTERIA	0 No/100ml	0
31/07/2023	COLIFORM BACTERIA	0 No/100ml	0
01/08/2023	COLIFORM BACTERIA	0 No/100ml	0
02/08/2023	COLIFORM BACTERIA	0 No/100ml	0
03/08/2023	COLIFORM BACTERIA	0 No/100ml	0
05/08/2023	COLIFORM BACTERIA	0 No/100ml	0
07/08/2023	COLIFORM BACTERIA	0 No/100ml	0
08/08/2023	COLIFORM BACTERIA	1 No/100ml	0
10/08/2023	COLIFORM BACTERIA	0 No/100ml	0
11/08/2023	COLIFORM BACTERIA	0 No/100ml	0
16/08/2023	COLIFORM BACTERIA	0 No/100ml	0
17/08/2023	COLIFORM BACTERIA	0 No/100ml	0
19/08/2023	COLIFORM BACTERIA	0 No/100ml	0
21/08/2023	COLIFORM BACTERIA	0 No/100ml	0

24/08/2023	COLIFORM BACTERIA	0 No/100ml	0
30/08/2023	COLIFORM BACTERIA	0 No/100ml	0
02/09/2023	COLIFORM BACTERIA	0 No/100ml	0
04/09/2023	COLIFORM BACTERIA	0 No/100ml	0
12/09/2023	COLIFORM BACTERIA	0 No/100ml	0
14/09/2023	COLIFORM BACTERIA	0 No/100ml	0
22/09/2023	COLIFORM BACTERIA	0 No/100ml	0
28/09/2023	COLIFORM BACTERIA	0 No/100ml	0
04/10/2023	COLIFORM BACTERIA	0 No/100ml	0
06/10/2023	COLIFORM BACTERIA	0 No/100ml	0
14/10/2023	COLIFORM BACTERIA	0 No/100ml	0
17/10/2023	COLIFORM BACTERIA	0 No/100ml	0
20/10/2023	COLIFORM BACTERIA	0 No/100ml	0
27/10/2023	COLIFORM BACTERIA	0 No/100ml	0
28/10/2023	COLIFORM BACTERIA	0 No/100ml	0
31/10/2023	COLIFORM BACTERIA	0 No/100ml	0
04/11/2023	COLIFORM BACTERIA	0 No/100ml	0
06/11/2023	COLIFORM BACTERIA	0 No/100ml	0
08/11/2023	COLIFORM BACTERIA	0 No/100ml	0
10/11/2023	COLIFORM BACTERIA	0 No/100ml	0
14/11/2023	COLIFORM BACTERIA	0 No/100ml	0
14/11/2023	COLIFORM BACTERIA	0 No/100ml	0
14/11/2023	COLIFORM BACTERIA	0 No/100ml	0
15/11/2023	COLIFORM BACTERIA	0 No/100ml	0
15/11/2023	COLIFORM BACTERIA	0 No/100ml	0
16/11/2023	COLIFORM BACTERIA	0 No/100ml	0
17/11/2023	COLIFORM BACTERIA	0 No/100ml	0
20/11/2023	COLIFORM BACTERIA	0 No/100ml	0
22/11/2023	COLIFORM BACTERIA	0 No/100ml	0
22/11/2023	COLIFORM BACTERIA	0 No/100ml	0
23/11/2023	COLIFORM BACTERIA	0 No/100ml	0
27/11/2023	COLIFORM BACTERIA	0 No/100ml	0
28/11/2023	COLIFORM BACTERIA	0 No/100ml	0
29/11/2023	COLIFORM BACTERIA	0 No/100ml	0
04/12/2023	COLIFORM BACTERIA	0 No/100ml	0
05/12/2023	COLIFORM BACTERIA	0 No/100ml	0
06/12/2023	COLIFORM BACTERIA	0 No/100ml	0
08/12/2023	COLIFORM BACTERIA	0 No/100ml	0
13/12/2023	COLIFORM BACTERIA	0 No/100ml	0
15/12/2023	COLIFORM BACTERIA	0 No/100ml	0
18/12/2023	COLIFORM BACTERIA	0 No/100ml	0
19/12/2023	COLIFORM BACTERIA	0 No/100ml	0
21/12/2023	COLIFORM BACTERIA	0 No/100ml	0
22/12/2023	COLIFORM BACTERIA	0 No/100ml	0
03/01/2024	COLIFORM BACTERIA	0 No/100ml	0
04/01/2024	COLIFORM BACTERIA	0 No/100ml	0
05/01/2024	COLIFORM BACTERIA	0 No/100ml	0
06/01/2024	COLIFORM BACTERIA	0 No/100ml	0

08/01/2024	COLIFORM BACTERIA	0 No/100ml	0
09/01/2024	COLIFORM BACTERIA	0 No/100ml	0
11/01/2024	COLIFORM BACTERIA	0 No/100ml	0
12/01/2024	COLIFORM BACTERIA	0 No/100ml	0
15/01/2024	COLIFORM BACTERIA	0 No/100ml	0
17/01/2024	COLIFORM BACTERIA	0 No/100ml	0
19/01/2024	COLIFORM BACTERIA	0 No/100ml	0
23/01/2024	COLIFORM BACTERIA	0 No/100ml	0
24/01/2024	COLIFORM BACTERIA	0 No/100ml	0
26/01/2024	COLIFORM BACTERIA	0 No/100ml	0
27/01/2024	COLIFORM BACTERIA	0 No/100ml	0
30/01/2024	COLIFORM BACTERIA	0 No/100ml	0
31/01/2024	COLIFORM BACTERIA	0 No/100ml	0
01/02/2024	COLIFORM BACTERIA	0 No/100ml	0
06/02/2024	COLIFORM BACTERIA	0 No/100ml	0
08/02/2024	COLIFORM BACTERIA	0 No/100ml	0
12/02/2024	COLIFORM BACTERIA	0 No/100ml	0
13/02/2024	COLIFORM BACTERIA	0 No/100ml	0
19/02/2024	COLIFORM BACTERIA	0 No/100ml	0
20/02/2024	COLIFORM BACTERIA	0 No/100ml	0
22/02/2024	COLIFORM BACTERIA	0 No/100ml	0
23/02/2024	COLIFORM BACTERIA	0 No/100ml	0
27/02/2024	COLIFORM BACTERIA	0 No/100ml	0
28/02/2024	COLIFORM BACTERIA	0 No/100ml	0
05/03/2024	COLIFORM BACTERIA	0 No/100ml	0
07/03/2024	COLIFORM BACTERIA	0 No/100ml	0
08/03/2024	COLIFORM BACTERIA	0 No/100ml	0
12/03/2024	COLIFORM BACTERIA	0 No/100ml	0
13/03/2024	COLIFORM BACTERIA	0 No/100ml	0
14/03/2024	COLIFORM BACTERIA	0 No/100ml	0
15/03/2024	COLIFORM BACTERIA	0 No/100ml	0
19/03/2024	COLIFORM BACTERIA	0 No/100ml	0
20/03/2024	COLIFORM BACTERIA	0 No/100ml	0
22/03/2024	COLIFORM BACTERIA	0 No/100ml	0
26/03/2024	COLIFORM BACTERIA	0 No/100ml	0
04/04/2024	COLIFORM BACTERIA	0 No/100ml	0
08/04/2024	COLIFORM BACTERIA	0 No/100ml	0
10/04/2024	COLIFORM BACTERIA	0 No/100ml	0
11/04/2024	COLIFORM BACTERIA	0 No/100ml	0
18/04/2024	COLIFORM BACTERIA	0 No/100ml	0
19/04/2024	COLIFORM BACTERIA	0 No/100ml	0
23/04/2024	COLIFORM BACTERIA	0 No/100ml	0
26/04/2024	COLIFORM BACTERIA	0 No/100ml	0
01/05/2024	COLIFORM BACTERIA	0 No/100ml	0
03/05/2024	COLIFORM BACTERIA	0 No/100ml	0
08/05/2024	COLIFORM BACTERIA	0 No/100ml	0
09/05/2024	COLIFORM BACTERIA	0 No/100ml	0
13/05/2024	COLIFORM BACTERIA	0 No/100ml	0

14/05/2024	COLIFORM BACTERIA	0 No/100ml	0
15/05/2024	COLIFORM BACTERIA	0 No/100ml	0
16/05/2024	COLIFORM BACTERIA	0 No/100ml	0
21/05/2024	COLIFORM BACTERIA	0 No/100ml	0
23/05/2024	COLIFORM BACTERIA	0 No/100ml	0
24/05/2024	COLIFORM BACTERIA	0 No/100ml	0
28/05/2024	COLIFORM BACTERIA	0 No/100ml	0
07/06/2024	COLIFORM BACTERIA	0 No/100ml	0
11/06/2024	COLIFORM BACTERIA	0 No/100ml	0
13/06/2024	COLIFORM BACTERIA	0 No/100ml	0
14/06/2024	COLIFORM BACTERIA	0 No/100ml	0
18/06/2024	COLIFORM BACTERIA	0 No/100ml	0
20/06/2024	COLIFORM BACTERIA	0 No/100ml	0
25/06/2024	COLIFORM BACTERIA	0 No/100ml	0
26/06/2024	COLIFORM BACTERIA	0 No/100ml	0
27/06/2024	COLIFORM BACTERIA	0 No/100ml	0
28/06/2024	COLIFORM BACTERIA	0 No/100ml	0
02/07/2024	COLIFORM BACTERIA	0 No/100ml	0
03/07/2024	COLIFORM BACTERIA	0 No/100ml	0
08/07/2024	COLIFORM BACTERIA	0 No/100ml	0
16/07/2024	COLIFORM BACTERIA	0 No/100ml	0
17/07/2024	COLIFORM BACTERIA	0 No/100ml	0
19/07/2024	COLIFORM BACTERIA	0 No/100ml	0
22/07/2024	COLIFORM BACTERIA	0 No/100ml	0
24/07/2024	COLIFORM BACTERIA	0 No/100ml	0
26/07/2024	COLIFORM BACTERIA	0 No/100ml	0
31/07/2024	COLIFORM BACTERIA	0 No/100ml	0
07/08/2024	COLIFORM BACTERIA	0 No/100ml	0
08/08/2024	COLIFORM BACTERIA	0 No/100ml	0
09/08/2024	COLIFORM BACTERIA	0 No/100ml	0
13/08/2024	COLIFORM BACTERIA	0 No/100ml	0
14/08/2024	COLIFORM BACTERIA	0 No/100ml	0
16/08/2024	COLIFORM BACTERIA	0 No/100ml	0
23/08/2024	COLIFORM BACTERIA	0 No/100ml	0
27/08/2024	COLIFORM BACTERIA	0 No/100ml	0
28/08/2024	COLIFORM BACTERIA	0 No/100ml	0
29/08/2024	COLIFORM BACTERIA	0 No/100ml	0
30/08/2024	COLIFORM BACTERIA	0 No/100ml	0
02/09/2024	COLIFORM BACTERIA	0 No/100ml	0
03/09/2024	COLIFORM BACTERIA	0 No/100ml	0
04/09/2024	COLIFORM BACTERIA	0 No/100ml	0
06/09/2024	COLIFORM BACTERIA	0 No/100ml	0
10/09/2024	COLIFORM BACTERIA	0 No/100ml	0
17/09/2024	COLIFORM BACTERIA	0 No/100ml	0
24/09/2024	COLIFORM BACTERIA	0 No/100ml	0
26/09/2024	COLIFORM BACTERIA	0 No/100ml	0
27/09/2024	COLIFORM BACTERIA	0 No/100ml	0
01/10/2024	COLIFORM BACTERIA	0 No/100ml	0

02/10/2024	COLIFORM BACTERIA	0 No/100ml	0
03/10/2024	COLIFORM BACTERIA	0 No/100ml	0
04/10/2024	COLIFORM BACTERIA	0 No/100ml	0
08/10/2024	COLIFORM BACTERIA	0 No/100ml	0
09/10/2024	COLIFORM BACTERIA	0 No/100ml	0
10/10/2024	COLIFORM BACTERIA	0 No/100ml	0
11/10/2024	COLIFORM BACTERIA	0 No/100ml	0
14/10/2024	COLIFORM BACTERIA	0 No/100ml	0
15/10/2024	COLIFORM BACTERIA	0 No/100ml	0
16/10/2024	COLIFORM BACTERIA	0 No/100ml	0
17/10/2024	COLIFORM BACTERIA	0 No/100ml	0
21/10/2024	COLIFORM BACTERIA	0 No/100ml	0
22/10/2024	COLIFORM BACTERIA	0 No/100ml	0
23/10/2024	COLIFORM BACTERIA	0 No/100ml	0
25/10/2024	COLIFORM BACTERIA	0 No/100ml	0
29/10/2024	COLIFORM BACTERIA	0 No/100ml	0
31/10/2024	COLIFORM BACTERIA	0 No/100ml	0
05/11/2024	COLIFORM BACTERIA	0 No/100ml	0
07/11/2024	COLIFORM BACTERIA	0 No/100ml	0
13/11/2024	COLIFORM BACTERIA	0 No/100ml	0
13/11/2024	COLIFORM BACTERIA	0 No/100ml	0
15/11/2024	COLIFORM BACTERIA	0 No/100ml	0
18/11/2024	COLIFORM BACTERIA	0 No/100ml	0
19/11/2024	COLIFORM BACTERIA	0 No/100ml	0
20/11/2024	COLIFORM BACTERIA	0 No/100ml	0
21/11/2024	COLIFORM BACTERIA	0 No/100ml	0
22/11/2024	COLIFORM BACTERIA	0 No/100ml	0
25/11/2024	COLIFORM BACTERIA	0 No/100ml	0
27/11/2024	COLIFORM BACTERIA	0 No/100ml	0
28/11/2024	COLIFORM BACTERIA	0 No/100ml	0
03/12/2024	COLIFORM BACTERIA	0 No/100ml	0
04/12/2024	COLIFORM BACTERIA	0 No/100ml	0
06/12/2024	COLIFORM BACTERIA	0 No/100ml	0
10/12/2024	COLIFORM BACTERIA	0 No/100ml	0
12/12/2024	COLIFORM BACTERIA	0 No/100ml	0
18/12/2024	COLIFORM BACTERIA	0 No/100ml	0
19/12/2024	COLIFORM BACTERIA	0 No/100ml	0
21/12/2024	COLIFORM BACTERIA	0 No/100ml	0
02/01/2025	COLIFORM BACTERIA	0 No/100ml	0
10/01/2025	COLIFORM BACTERIA	0 No/100ml	0
16/01/2025	COLIFORM BACTERIA	0 No/100ml	0
18/01/2025	COLIFORM BACTERIA	0 No/100ml	0
20/01/2025	COLIFORM BACTERIA	0 No/100ml	0
21/01/2025	COLIFORM BACTERIA	0 No/100ml	0
22/01/2025	COLIFORM BACTERIA	0 No/100ml	0
24/01/2025	COLIFORM BACTERIA	0 No/100ml	0
28/01/2025	COLIFORM BACTERIA	0 No/100ml	0
29/01/2025	COLIFORM BACTERIA	0 No/100ml	0

30/01/2025	COLIFORM BACTERIA	0 No/100ml	0
04/02/2025	COLIFORM BACTERIA	0 No/100ml	0
05/02/2025	COLIFORM BACTERIA	0 No/100ml	0
06/02/2025	COLIFORM BACTERIA	0 No/100ml	0
07/02/2025	COLIFORM BACTERIA	0 No/100ml	0
11/02/2025	COLIFORM BACTERIA	0 No/100ml	0
12/02/2025	COLIFORM BACTERIA	0 No/100ml	0
14/02/2025	COLIFORM BACTERIA	0 No/100ml	0
24/02/2025	COLIFORM BACTERIA	0 No/100ml	0
27/02/2025	COLIFORM BACTERIA	0 No/100ml	0
27/02/2025	COLIFORM BACTERIA	0 No/100ml	0
05/03/2025	COLIFORM BACTERIA	0 No/100ml	0
07/03/2025	COLIFORM BACTERIA	0 No/100ml	0
13/03/2025	COLIFORM BACTERIA	0 No/100ml	0
17/03/2025	COLIFORM BACTERIA	0 No/100ml	0
19/03/2025	COLIFORM BACTERIA	0 No/100ml	0
21/03/2025	COLIFORM BACTERIA	0 No/100ml	0
25/03/2025	COLIFORM BACTERIA	0 No/100ml	0
26/03/2025	COLIFORM BACTERIA	0 No/100ml	0
29/03/2025	COLIFORM BACTERIA	0 No/100ml	0
03/04/2025	COLIFORM BACTERIA	0 No/100ml	0
05/04/2025	COLIFORM BACTERIA	0 No/100ml	0
08/04/2025	COLIFORM BACTERIA	0 No/100ml	0
10/04/2025	COLIFORM BACTERIA	0 No/100ml	0
11/04/2025	COLIFORM BACTERIA	0 No/100ml	0
16/04/2025	COLIFORM BACTERIA	0 No/100ml	0
22/04/2025	COLIFORM BACTERIA	0 No/100ml	0
24/04/2025	COLIFORM BACTERIA	0 No/100ml	0
29/04/2025	COLIFORM BACTERIA	0 No/100ml	0
01/05/2025	COLIFORM BACTERIA	0 No/100ml	0
06/05/2025	COLIFORM BACTERIA	0 No/100ml	0
07/05/2025	COLIFORM BACTERIA	0 No/100ml	0
08/05/2025	COLIFORM BACTERIA	0 No/100ml	0
12/05/2025	COLIFORM BACTERIA	0 No/100ml	0
13/05/2025	COLIFORM BACTERIA	0 No/100ml	0
14/05/2025	COLIFORM BACTERIA	0 No/100ml	0
16/05/2025	COLIFORM BACTERIA	0 No/100ml	0
17/05/2025	COLIFORM BACTERIA	0 No/100ml	0
21/05/2025	COLIFORM BACTERIA	0 No/100ml	0
23/05/2025	COLIFORM BACTERIA	0 No/100ml	0
28/05/2025	COLIFORM BACTERIA	0 No/100ml	0
05/06/2025	COLIFORM BACTERIA	0 No/100ml	0
09/06/2025	COLIFORM BACTERIA	0 No/100ml	0
11/06/2025	COLIFORM BACTERIA	0 No/100ml	0
12/06/2025	COLIFORM BACTERIA	0 No/100ml	0
13/06/2025	COLIFORM BACTERIA	0 No/100ml	0
14/06/2025	COLIFORM BACTERIA	0 No/100ml	0
15/06/2025	COLIFORM BACTERIA	0 No/100ml	0

16/06/2025	COLIFORM BACTERIA	0 No/100ml	0
17/06/2025	COLIFORM BACTERIA	0 No/100ml	0
18/06/2025	COLIFORM BACTERIA	0 No/100ml	0
19/06/2025	COLIFORM BACTERIA	0 No/100ml	0
20/06/2025	COLIFORM BACTERIA	0 No/100ml	0
26/06/2025	COLIFORM BACTERIA	0 No/100ml	0
27/06/2025	COLIFORM BACTERIA	0 No/100ml	0
01/07/2025	COLIFORM BACTERIA	0 No/100ml	0
04/07/2025	COLIFORM BACTERIA	0 No/100ml	0
08/07/2025	COLIFORM BACTERIA	0 No/100ml	0
09/07/2025	COLIFORM BACTERIA	0 No/100ml	0
10/07/2025	COLIFORM BACTERIA	0 No/100ml	0
11/07/2025	COLIFORM BACTERIA	0 No/100ml	0
15/07/2025	COLIFORM BACTERIA	0 No/100ml	0
21/07/2025	COLIFORM BACTERIA	0 No/100ml	0
23/07/2025	COLIFORM BACTERIA	0 No/100ml	0
24/07/2025	COLIFORM BACTERIA	0 No/100ml	0
25/07/2025	COLIFORM BACTERIA	0 No/100ml	0
29/07/2025	COLIFORM BACTERIA	0 No/100ml	0
30/07/2025	COLIFORM BACTERIA	0 No/100ml	0
01/08/2025	COLIFORM BACTERIA	0 No/100ml	0
07/08/2025	COLIFORM BACTERIA	0 No/100ml	0
08/08/2025	COLIFORM BACTERIA	0 No/100ml	0
13/08/2025	COLIFORM BACTERIA	0 No/100ml	0
28/08/2025	COLIFORM BACTERIA	0 No/100ml	0
03/09/2025	COLIFORM BACTERIA	0 No/100ml	0
05/09/2025	COLIFORM BACTERIA	0 No/100ml	0
06/09/2025	COLIFORM BACTERIA	0 No/100ml	0
10/09/2025	COLIFORM BACTERIA	0 No/100ml	0
12/09/2025	COLIFORM BACTERIA	0 No/100ml	0
16/09/2025	COLIFORM BACTERIA	0 No/100ml	0
17/09/2025	COLIFORM BACTERIA	0 No/100ml	0
29/09/2025	COLIFORM BACTERIA	0 No/100ml	0
30/09/2025	COLIFORM BACTERIA	0 No/100ml	0
01/10/2025	COLIFORM BACTERIA	0 No/100ml	0
03/10/2025	COLIFORM BACTERIA	0 No/100ml	0
05/10/2025	COLIFORM BACTERIA	0 No/100ml	0
06/10/2025	COLIFORM BACTERIA	0 No/100ml	0
08/10/2025	COLIFORM BACTERIA	0 No/100ml	0
10/10/2025	COLIFORM BACTERIA	0 No/100ml	0
14/10/2025	COLIFORM BACTERIA	0 No/100ml	0
15/10/2025	COLIFORM BACTERIA	0 No/100ml	0
18/10/2025	COLIFORM BACTERIA	0 No/100ml	0
20/10/2025	COLIFORM BACTERIA	0 No/100ml	0
22/10/2025	COLIFORM BACTERIA	0 No/100ml	0
23/10/2025	COLIFORM BACTERIA	0 No/100ml	0
24/10/2025	COLIFORM BACTERIA	0 No/100ml	0
27/10/2025	COLIFORM BACTERIA	0 No/100ml	0

28/10/2025	COLIFORM BACTERIA	0 No/100ml	0
29/10/2025	COLIFORM BACTERIA	0 No/100ml	0
31/10/2025	COLIFORM BACTERIA	0 No/100ml	0
03/11/2025	COLIFORM BACTERIA	0 No/100ml	0
05/11/2025	COLIFORM BACTERIA	0 No/100ml	0
08/11/2025	COLIFORM BACTERIA	0 No/100ml	0
10/11/2025	COLIFORM BACTERIA	0 No/100ml	0
12/11/2025	COLIFORM BACTERIA	0 No/100ml	0
17/11/2025	COLIFORM BACTERIA	0 No/100ml	0
18/11/2025	COLIFORM BACTERIA	0 No/100ml	0
19/11/2025	COLIFORM BACTERIA	0 No/100ml	0
20/11/2025	COLIFORM BACTERIA	0 No/100ml	0
24/11/2025	COLIFORM BACTERIA	0 No/100ml	0
26/11/2025	COLIFORM BACTERIA	0 No/100ml	0
27/11/2025	COLIFORM BACTERIA	0 No/100ml	0
02/12/2025	COLIFORM BACTERIA	0 No/100ml	0
03/12/2025	COLIFORM BACTERIA	0 No/100ml	0
05/12/2025	COLIFORM BACTERIA	0 No/100ml	0
09/12/2025	COLIFORM BACTERIA	0 No/100ml	0
11/12/2025	COLIFORM BACTERIA	0 No/100ml	0
12/12/2025	COLIFORM BACTERIA	0 No/100ml	0
15/12/2025	COLIFORM BACTERIA	0 No/100ml	0
16/12/2025	COLIFORM BACTERIA	0 No/100ml	0
18/12/2025	COLIFORM BACTERIA	0 No/100ml	0
19/12/2025	COLIFORM BACTERIA	0 No/100ml	0
22/12/2025	COLIFORM BACTERIA	0 No/100ml	0
06/01/2026	COLIFORM BACTERIA	0 No/100ml	0
08/01/2026	COLIFORM BACTERIA	0 No/100ml	0
09/01/2026	COLIFORM BACTERIA	0 No/100ml	0
13/01/2026	COLIFORM BACTERIA	0 No/100ml	0
14/01/2026	COLIFORM BACTERIA	0 No/100ml	0
15/01/2026	COLIFORM BACTERIA	0 No/100ml	0
19/01/2026	COLIFORM BACTERIA	0 No/100ml	0
20/01/2026	COLIFORM BACTERIA	0 No/100ml	0
21/01/2026	COLIFORM BACTERIA	0 No/100ml	0
27/01/2026	COLIFORM BACTERIA	0 No/100ml	0
28/01/2026	COLIFORM BACTERIA	0 No/100ml	0
29/01/2026	COLIFORM BACTERIA	0 No/100ml	0
30/01/2026	COLIFORM BACTERIA	0 No/100ml	0
02/02/2026	COLIFORM BACTERIA	0 No/100ml	0
05/02/2026	COLIFORM BACTERIA	0 No/100ml	0
09/02/2026	COLIFORM BACTERIA	0 No/100ml	0
10/02/2026	COLIFORM BACTERIA	0 No/100ml	0
11/02/2026	COLIFORM BACTERIA	0 No/100ml	0
13/02/2026	COLIFORM BACTERIA	0 No/100ml	0
17/02/2026	COLIFORM BACTERIA	0 No/100ml	0
10/03/2021	COLONIES 3DAYS 22C	0 No/ml	No regulatory limit
11/03/2021	COLONIES 3DAYS 22C	0 No/ml	No regulatory limit

07/08/2023	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
19/08/2023	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
21/08/2023	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
30/08/2023	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
22/09/2023	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
28/09/2023	COLONIES 3DAYS 22C	1	No/ml	No regulatory limit
14/10/2023	COLONIES 3DAYS 22C	2	No/ml	No regulatory limit
17/10/2023	COLONIES 3DAYS 22C	147	No/ml	No regulatory limit
28/10/2023	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
31/10/2023	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
08/11/2023	COLONIES 3DAYS 22C	4	No/ml	No regulatory limit
15/11/2023	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
17/11/2023	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
23/11/2023	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
29/11/2023	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
04/12/2023	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
13/12/2023	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
18/12/2023	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
21/12/2023	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
22/12/2023	COLONIES 3DAYS 22C	1	No/ml	No regulatory limit
05/01/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
06/01/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
09/01/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
17/01/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
27/01/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
31/01/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
01/02/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
08/02/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
12/02/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
19/02/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
08/03/2024	COLONIES 3DAYS 22C	1	No/ml	No regulatory limit
13/03/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
14/03/2024	COLONIES 3DAYS 22C	1	No/ml	No regulatory limit
15/03/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
19/03/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
10/04/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
19/04/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
23/04/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
03/05/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
09/05/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
15/05/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
21/05/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
23/05/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
13/06/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
18/06/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
28/06/2024	COLONIES 3DAYS 22C	1	No/ml	No regulatory limit
16/07/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit
19/07/2024	COLONIES 3DAYS 22C	0	No/ml	No regulatory limit

05/06/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
11/06/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
12/06/2025	COLONIES 3DAYS 22C		2 No/ml	No regulatory limit	
15/06/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
19/06/2025	COLONIES 3DAYS 22C		1 No/ml	No regulatory limit	
26/06/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
01/07/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
08/07/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
10/07/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
24/07/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
25/07/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
01/08/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
07/08/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
13/08/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
05/09/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
10/09/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
12/09/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
17/09/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
01/10/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
03/10/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
05/10/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
10/10/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
28/10/2025	COLONIES 3DAYS 22C		3 No/ml	No regulatory limit	
31/10/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
05/11/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
10/11/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
19/11/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
21/11/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
27/11/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
03/12/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
11/12/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
18/12/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
19/12/2025	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
08/01/2026	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
14/01/2026	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
19/01/2026	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
20/01/2026	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
27/01/2026	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
29/01/2026	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
02/02/2026	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
11/02/2026	COLONIES 3DAYS 22C		0 No/ml	No regulatory limit	
11/03/2021	COLOUR	<	2.16 HAZ		20
19/03/2021	COLOUR	<	2.16 HAZ		20
25/03/2021	COLOUR	<	2.16 HAZ		20
29/03/2021	COLOUR	<	2.16 HAZ		20
30/03/2021	COLOUR	<	1.21 HAZ		20
07/04/2021	COLOUR	<	2.16 HAZ		20
18/04/2021	COLOUR	<	2.16 HAZ		20

23/04/2021 COLOUR	<	2.16 HAZ	20
11/05/2021 COLOUR	<	2.16 HAZ	20
17/05/2021 COLOUR	<	2.16 HAZ	20
22/05/2021 COLOUR	<	2.16 HAZ	20
25/05/2021 COLOUR	<	1.21 HAZ	20
26/05/2021 COLOUR	<	2.16 HAZ	20
29/05/2021 COLOUR	<	2.16 HAZ	20
04/06/2021 COLOUR	<	2.16 HAZ	20
09/06/2021 COLOUR	<	1.21 HAZ	20
14/06/2021 COLOUR	<	1.21 HAZ	20
15/06/2021 COLOUR	<	1.21 HAZ	20
25/06/2021 COLOUR	<	2.16 HAZ	20
30/06/2021 COLOUR	<	1.21 HAZ	20
09/07/2021 COLOUR	<	2.16 HAZ	20
06/08/2021 COLOUR	<	1.21 HAZ	20
09/08/2021 COLOUR	<	1.21 HAZ	20
01/09/2021 COLOUR	<	1.21 HAZ	20
09/09/2021 COLOUR	<	1.21 HAZ	20
24/09/2021 COLOUR	<	2.16 HAZ	20
29/09/2021 COLOUR	<	2.16 HAZ	20
30/09/2021 COLOUR	<	2.16 HAZ	20
01/10/2021 COLOUR	<	2.16 HAZ	20
04/10/2021 COLOUR	<	1.21 HAZ	20
07/10/2021 COLOUR	<	2.16 HAZ	20
13/10/2021 COLOUR	<	2.16 HAZ	20
14/10/2021 COLOUR	<	2.16 HAZ	20
18/10/2021 COLOUR	<	2.16 HAZ	20
22/10/2021 COLOUR	<	1.21 HAZ	20
29/10/2021 COLOUR	<	2.16 HAZ	20
03/11/2021 COLOUR	<	2.16 HAZ	20
04/11/2021 COLOUR	<	1.21 HAZ	20
13/11/2021 COLOUR	<	2.16 HAZ	20
16/11/2021 COLOUR	<	2.16 HAZ	20
25/11/2021 COLOUR	<	2.16 HAZ	20
29/11/2021 COLOUR	<	1.21 HAZ	20
06/12/2021 COLOUR	<	1.21 HAZ	20
07/12/2021 COLOUR	<	2.16 HAZ	20
09/12/2021 COLOUR	<	1.21 HAZ	20
10/12/2021 COLOUR	<	1.21 HAZ	20
14/12/2021 COLOUR	<	1.21 HAZ	20
15/12/2021 COLOUR	<	1.21 HAZ	20
16/12/2021 COLOUR	<	1.21 HAZ	20
17/12/2021 COLOUR	<	2.16 HAZ	20
18/12/2021 COLOUR	<	2.16 HAZ	20
22/12/2021 COLOUR	<	1.21 HAZ	20
05/01/2022 COLOUR	<	1.21 HAZ	20
12/01/2022 COLOUR	<	2.16 HAZ	20
24/01/2022 COLOUR	<	2.16 HAZ	20

01/02/2022 COLOUR	<	1.21 HAZ	20
07/02/2022 COLOUR	<	2.16 HAZ	20
08/02/2022 COLOUR	<	2.16 HAZ	20
16/02/2022 COLOUR	<	2.16 HAZ	20
26/02/2022 COLOUR	<	2.16 HAZ	20
01/03/2022 COLOUR	<	2.16 HAZ	20
01/03/2022 COLOUR	<	2.16 HAZ	20
16/03/2022 COLOUR	<	2.16 HAZ	20
21/03/2022 COLOUR	<	2.16 HAZ	20
07/04/2022 COLOUR	<	2.04 HAZ	20
11/04/2022 COLOUR	<	2.16 HAZ	20
14/04/2022 COLOUR	<	1.21 HAZ	20
21/04/2022 COLOUR	<	2.04 HAZ	20
05/05/2022 COLOUR	<	2.16 HAZ	20
09/05/2022 COLOUR	<	2.16 HAZ	20
10/05/2022 COLOUR	<	2.16 HAZ	20
18/05/2022 COLOUR	<	2.16 HAZ	20
19/05/2022 COLOUR	<	1.21 HAZ	20
23/05/2022 COLOUR	<	1.21 HAZ	20
24/05/2022 COLOUR	<	2.04 HAZ	20
27/05/2022 COLOUR	<	1.21 HAZ	20
04/06/2022 COLOUR	<	2.04 HAZ	20
05/06/2022 COLOUR	<	2.04 HAZ	20
07/06/2022 COLOUR	<	1.21 HAZ	20
16/06/2022 COLOUR	<	2.04 HAZ	20
17/06/2022 COLOUR	<	1.21 HAZ	20
20/06/2022 COLOUR	<	2.16 HAZ	20
28/06/2022 COLOUR	<	1.21 HAZ	20
07/07/2022 COLOUR	<	2.16 HAZ	20
20/07/2022 COLOUR	<	2.16 HAZ	20
29/07/2022 COLOUR	<	2.04 HAZ	20
10/08/2022 COLOUR	<	2.16 HAZ	20
15/08/2022 COLOUR	<	1.21 HAZ	20
23/08/2022 COLOUR	<	1.21 HAZ	20
27/08/2022 COLOUR	<	1.21 HAZ	20
08/09/2022 COLOUR		1.49 HAZ	20
28/09/2022 COLOUR	<	1.21 HAZ	20
05/10/2022 COLOUR	<	1.21 HAZ	20
17/10/2022 COLOUR	<	2.16 HAZ	20
20/10/2022 COLOUR	<	2.16 HAZ	20
26/10/2022 COLOUR	<	2.16 HAZ	20
01/11/2022 COLOUR		3.03 HAZ	20
07/11/2022 COLOUR	<	1.21 HAZ	20
15/11/2022 COLOUR	<	2.04 HAZ	20
19/11/2022 COLOUR	<	2.04 HAZ	20
22/11/2022 COLOUR	<	2.04 HAZ	20
29/11/2022 COLOUR	<	2.04 HAZ	20
30/11/2022 COLOUR	<	2.16 HAZ	20

07/12/2022	COLOUR	<	2.04 HAZ	20
16/12/2022	COLOUR	<	1.21 HAZ	20
10/01/2023	COLOUR	<	2.04 HAZ	20
27/01/2023	COLOUR	<	1.21 HAZ	20
02/02/2023	COLOUR	<	2.16 HAZ	20
07/02/2023	COLOUR	<	2.04 HAZ	20
11/02/2023	COLOUR	<	1.21 HAZ	20
01/03/2023	COLOUR	<	2.16 HAZ	20
02/03/2023	COLOUR	<	2.16 HAZ	20
14/03/2023	COLOUR	<	2.16 HAZ	20
24/03/2023	COLOUR	<	2.16 HAZ	20
29/03/2023	COLOUR	<	1.21 HAZ	20
05/04/2023	COLOUR	<	2.16 HAZ	20
06/04/2023	COLOUR	<	1.21 HAZ	20
19/04/2023	COLOUR	<	1.21 HAZ	20
26/04/2023	COLOUR	<	2.16 HAZ	20
05/05/2023	COLOUR	<	2.16 HAZ	20
09/05/2023	COLOUR	<	2.16 HAZ	20
19/05/2023	COLOUR	<	2.04 HAZ	20
24/05/2023	COLOUR	<	2.16 HAZ	20
01/06/2023	COLOUR	<	2.16 HAZ	20
06/06/2023	COLOUR	<	1.21 HAZ	20
08/06/2023	COLOUR	<	1.21 HAZ	20
09/06/2023	COLOUR	<	1.21 HAZ	20
12/06/2023	COLOUR	<	1.21 HAZ	20
28/06/2023	COLOUR	<	1.21 HAZ	20
30/06/2023	COLOUR	<	1.21 HAZ	20
04/07/2023	COLOUR	<	2.16 HAZ	20
11/07/2023	COLOUR	<	2.16 HAZ	20
12/07/2023	COLOUR	<	2.16 HAZ	20
13/07/2023	COLOUR	<	2.16 HAZ	20
18/07/2023	COLOUR	<	2.04 HAZ	20
27/07/2023	COLOUR	<	1.21 HAZ	20
28/07/2023	COLOUR	<	2.16 HAZ	20
02/08/2023	COLOUR	<	2.04 HAZ	20
05/08/2023	COLOUR	<	2.04 HAZ	20
07/08/2023	COLOUR	<	2.16 HAZ	20
24/08/2023	COLOUR	<	1.21 HAZ	20
30/08/2023	COLOUR	<	1.21 HAZ	20
22/09/2023	COLOUR	<	2.04 HAZ	20
28/09/2023	COLOUR	<	2.16 HAZ	20
04/10/2023	COLOUR	<	1.21 HAZ	20
17/10/2023	COLOUR	<	1.21 HAZ	20
27/10/2023	COLOUR	<	1.21 HAZ	20
28/10/2023	COLOUR	<	2.16 HAZ	20
31/10/2023	COLOUR	<	1.21 HAZ	20
08/11/2023	COLOUR	<	2.16 HAZ	20
14/11/2023	COLOUR	<	2.16 HAZ	20

14/11/2023 COLOUR	<	1.21 HAZ	20
23/11/2023 COLOUR	<	2.16 HAZ	20
06/12/2023 COLOUR	<	2.16 HAZ	20
13/12/2023 COLOUR	<	2.04 HAZ	20
18/12/2023 COLOUR	<	1.21 HAZ	20
19/12/2023 COLOUR	<	1.21 HAZ	20
21/12/2023 COLOUR	<	2.04 HAZ	20
22/12/2023 COLOUR	<	1.21 HAZ	20
05/01/2024 COLOUR	<	2.16 HAZ	20
06/01/2024 COLOUR	<	2.16 HAZ	20
12/01/2024 COLOUR	<	2.04 HAZ	20
17/01/2024 COLOUR	<	1.21 HAZ	20
23/01/2024 COLOUR	<	2.16 HAZ	20
01/02/2024 COLOUR	<	2.16 HAZ	20
06/02/2024 COLOUR	<	1.21 HAZ	20
22/02/2024 COLOUR	<	1.21 HAZ	20
23/02/2024 COLOUR	<	1.21 HAZ	20
28/02/2024 COLOUR	<	1.21 HAZ	20
05/03/2024 COLOUR	<	2.16 HAZ	20
15/03/2024 COLOUR	<	1.21 HAZ	20
22/03/2024 COLOUR	<	1.21 HAZ	20
26/03/2024 COLOUR	<	1.21 HAZ	20
04/04/2024 COLOUR	<	2.16 HAZ	20
10/04/2024 COLOUR	<	2.04 HAZ	20
18/04/2024 COLOUR	<	2.16 HAZ	20
23/04/2024 COLOUR	<	1.21 HAZ	20
09/05/2024 COLOUR	<	1.21 HAZ	20
15/05/2024 COLOUR	<	1.21 HAZ	20
23/05/2024 COLOUR	<	2.04 HAZ	20
24/05/2024 COLOUR	<	1.21 HAZ	20
14/06/2024 COLOUR	<	2.04 HAZ	20
20/06/2024 COLOUR	<	1.21 HAZ	20
25/06/2024 COLOUR	<	1.21 HAZ	20
26/06/2024 COLOUR	<	1.21 HAZ	20
27/06/2024 COLOUR	<	2.04 HAZ	20
02/07/2024 COLOUR	<	2.04 HAZ	20
08/07/2024 COLOUR	<	1.21 HAZ	20
17/07/2024 COLOUR	<	1.21 HAZ	20
22/07/2024 COLOUR	<	1.21 HAZ	20
08/08/2024 COLOUR		1.77 HAZ	20
27/08/2024 COLOUR	<	1.21 HAZ	20
28/08/2024 COLOUR	<	2.04 HAZ	20
03/09/2024 COLOUR	<	1.21 HAZ	20
04/09/2024 COLOUR	<	1.21 HAZ	20
10/09/2024 COLOUR	<	1.21 HAZ	20
24/09/2024 COLOUR	<	2.04 HAZ	20
26/09/2024 COLOUR	<	1.21 HAZ	20
04/10/2024 COLOUR	<	1.21 HAZ	20

08/10/2024 COLOUR	<	2.04 HAZ	20
09/10/2024 COLOUR	<	1.21 HAZ	20
14/10/2024 COLOUR	<	1.21 HAZ	20
16/10/2024 COLOUR	<	1.21 HAZ	20
17/10/2024 COLOUR	<	1.21 HAZ	20
31/10/2024 COLOUR	<	1.21 HAZ	20
07/11/2024 COLOUR	<	2.04 HAZ	20
18/11/2024 COLOUR	<	1.21 HAZ	20
19/11/2024 COLOUR	<	2.04 HAZ	20
21/11/2024 COLOUR	<	2.04 HAZ	20
27/11/2024 COLOUR	<	1.21 HAZ	20
06/12/2024 COLOUR	<	1.21 HAZ	20
12/12/2024 COLOUR	<	1.21 HAZ	20
02/01/2025 COLOUR	<	2.08 HAZ	20
24/01/2025 COLOUR	<	2.08 HAZ	20
29/01/2025 COLOUR	<	2.08 HAZ	20
30/01/2025 COLOUR	<	2.08 HAZ	20
07/02/2025 COLOUR	<	2.08 HAZ	20
11/02/2025 COLOUR	<	2.08 HAZ	20
24/02/2025 COLOUR	<	2.08 HAZ	20
27/02/2025 COLOUR	<	1.75 HAZ	20
13/03/2025 COLOUR	<	2.08 HAZ	20
17/03/2025 COLOUR	<	2.08 HAZ	20
21/03/2025 COLOUR	<	1.75 HAZ	20
25/03/2025 COLOUR	<	1.75 HAZ	20
03/04/2025 COLOUR	<	1.75 HAZ	20
08/04/2025 COLOUR	<	1.75 HAZ	20
16/04/2025 COLOUR	<	2.08 HAZ	20
22/04/2025 COLOUR	<	1.75 HAZ	20
07/05/2025 COLOUR	<	1.75 HAZ	20
12/05/2025 COLOUR	<	2.08 HAZ	20
13/05/2025 COLOUR	<	1.75 HAZ	20
28/05/2025 COLOUR	<	1.75 HAZ	20
05/06/2025 COLOUR	<	1.75 HAZ	20
11/06/2025 COLOUR	<	2.08 HAZ	20
16/06/2025 COLOUR	<	2.08 HAZ	20
18/06/2025 COLOUR	<	2.08 HAZ	20
19/06/2025 COLOUR	<	1.75 HAZ	20
20/06/2025 COLOUR	<	2.08 HAZ	20
01/07/2025 COLOUR	<	1.75 HAZ	20
09/07/2025 COLOUR	<	1.75 HAZ	20
21/07/2025 COLOUR	<	1.75 HAZ	20
01/08/2025 COLOUR		2.57 HAZ	20
07/08/2025 COLOUR	<	2.04 HAZ	20
08/08/2025 COLOUR	<	1.75 HAZ	20
03/09/2025 COLOUR	<	2.04 HAZ	20
06/09/2025 COLOUR	<	1.75 HAZ	20
10/09/2025 COLOUR	<	2.04 HAZ	20

12/09/2025 COLOUR	<	1.75 HAZ	20
30/09/2025 COLOUR	<	2.04 HAZ	20
01/10/2025 COLOUR	<	1.75 HAZ	20
08/10/2025 COLOUR	<	1.75 HAZ	20
10/10/2025 COLOUR	<	2.08 HAZ	20
14/10/2025 COLOUR	<	2.08 HAZ	20
15/10/2025 COLOUR	<	2.08 HAZ	20
20/10/2025 COLOUR	<	2.08 HAZ	20
22/10/2025 COLOUR	<	2.08 HAZ	20
28/10/2025 COLOUR	<	2.04 HAZ	20
08/11/2025 COLOUR	<	1.75 HAZ	20
12/11/2025 COLOUR	<	2.08 HAZ	20
19/11/2025 COLOUR	<	1.75 HAZ	20
26/11/2025 COLOUR	<	2.08 HAZ	20
03/12/2025 COLOUR	<	2.08 HAZ	20
11/12/2025 COLOUR		3.67 HAZ	20
12/12/2025 COLOUR	<	2.08 HAZ	20
08/01/2026 COLOUR	<	2.08 HAZ	20
15/01/2026 COLOUR	<	2.08 HAZ	20
19/01/2026 COLOUR	<	1.75 HAZ	20
20/01/2026 COLOUR	<	2.08 HAZ	20
27/01/2026 COLOUR	<	1.75 HAZ	20
28/01/2026 COLOUR	<	2.08 HAZ	20
05/02/2026 COLOUR	<	1.75 HAZ	20
11/02/2026 COLOUR	<	1.75 HAZ	20
11/03/2021 CONDUCTIVITY		126 µsie/cm	2500
19/03/2021 CONDUCTIVITY		128 µsie/cm	2500
25/03/2021 CONDUCTIVITY		125 µsie/cm	2500
29/03/2021 CONDUCTIVITY		119 µsie/cm	2500
30/03/2021 CONDUCTIVITY		120 µsie/cm	2500
07/04/2021 CONDUCTIVITY		133 µsie/cm	2500
18/04/2021 CONDUCTIVITY		132 µsie/cm	2500
23/04/2021 CONDUCTIVITY		98.6 µsie/cm	2500
12/05/2021 CONDUCTIVITY		138 µsie/cm	2500
17/05/2021 CONDUCTIVITY		92.3 µsie/cm	2500
25/05/2021 CONDUCTIVITY		89.9 µsie/cm	2500
27/05/2021 CONDUCTIVITY		141 µsie/cm	2500
29/05/2021 CONDUCTIVITY		143 µsie/cm	2500
04/06/2021 CONDUCTIVITY		136 µsie/cm	2500
08/06/2021 CONDUCTIVITY		137 µsie/cm	2500
14/06/2021 CONDUCTIVITY		137 µsie/cm	2500
24/06/2021 CONDUCTIVITY		132 µsie/cm	2500
01/07/2021 CONDUCTIVITY		140 µsie/cm	2500
08/07/2021 CONDUCTIVITY		134 µsie/cm	2500
26/07/2021 CONDUCTIVITY		150 µsie/cm	2500
06/08/2021 CONDUCTIVITY		147 µsie/cm	2500
07/08/2021 CONDUCTIVITY		145 µsie/cm	2500
08/08/2021 CONDUCTIVITY		149 µsie/cm	2500

16/08/2021	CONDUCTIVITY	142 μ sie/cm	2500
25/08/2021	CONDUCTIVITY	140 μ sie/cm	2500
01/09/2021	CONDUCTIVITY	144 μ sie/cm	2500
30/09/2021	CONDUCTIVITY	149 μ sie/cm	2500
05/10/2021	CONDUCTIVITY	141 μ sie/cm	2500
07/10/2021	CONDUCTIVITY	151 μ sie/cm	2500
18/10/2021	CONDUCTIVITY	111 μ sie/cm	2500
21/10/2021	CONDUCTIVITY	149 μ sie/cm	2500
28/10/2021	CONDUCTIVITY	148 μ sie/cm	2500
29/10/2021	CONDUCTIVITY	151 μ sie/cm	2500
30/10/2021	CONDUCTIVITY	152 μ sie/cm	2500
04/11/2021	CONDUCTIVITY	140 μ sie/cm	2500
10/11/2021	CONDUCTIVITY	144 μ sie/cm	2500
13/11/2021	CONDUCTIVITY	148 μ sie/cm	2500
15/11/2021	CONDUCTIVITY	139 μ sie/cm	2500
16/11/2021	CONDUCTIVITY	152 μ sie/cm	2500
23/11/2021	CONDUCTIVITY	145 μ sie/cm	2500
02/12/2021	CONDUCTIVITY	144 μ sie/cm	2500
06/12/2021	CONDUCTIVITY	143 μ sie/cm	2500
07/12/2021	CONDUCTIVITY	145 μ sie/cm	2500
08/12/2021	CONDUCTIVITY	143 μ sie/cm	2500
09/12/2021	CONDUCTIVITY	137 μ sie/cm	2500
09/12/2021	CONDUCTIVITY	141 μ sie/cm	2500
11/12/2021	CONDUCTIVITY	134 μ sie/cm	2500
13/12/2021	CONDUCTIVITY	142 μ sie/cm	2500
16/12/2021	CONDUCTIVITY	135 μ sie/cm	2500
17/12/2021	CONDUCTIVITY	142 μ sie/cm	2500
21/12/2021	CONDUCTIVITY	135 μ sie/cm	2500
21/12/2021	CONDUCTIVITY	136 μ sie/cm	2500
22/12/2021	CONDUCTIVITY	138 μ sie/cm	2500
05/01/2022	CONDUCTIVITY	137 μ sie/cm	2500
12/01/2022	CONDUCTIVITY	133 μ sie/cm	2500
24/01/2022	CONDUCTIVITY	141 μ sie/cm	2500
01/02/2022	CONDUCTIVITY	146 μ sie/cm	2500
07/02/2022	CONDUCTIVITY	137 μ sie/cm	2500
08/02/2022	CONDUCTIVITY	140 μ sie/cm	2500
16/02/2022	CONDUCTIVITY	133 μ sie/cm	2500
26/02/2022	CONDUCTIVITY	132 μ sie/cm	2500
01/03/2022	CONDUCTIVITY	125 μ sie/cm	2500
01/03/2022	CONDUCTIVITY	126 μ sie/cm	2500
16/03/2022	CONDUCTIVITY	135 μ sie/cm	2500
21/03/2022	CONDUCTIVITY	134 μ sie/cm	2500
07/04/2022	CONDUCTIVITY	127 μ sie/cm	2500
11/04/2022	CONDUCTIVITY	136 μ sie/cm	2500
14/04/2022	CONDUCTIVITY	137 μ sie/cm	2500
21/04/2022	CONDUCTIVITY	137 μ sie/cm	2500
05/05/2022	CONDUCTIVITY	139 μ sie/cm	2500
09/05/2022	CONDUCTIVITY	138 μ sie/cm	2500

10/05/2022	CONDUCTIVITY	140 μ sie/cm	2500
18/05/2022	CONDUCTIVITY	141 μ sie/cm	2500
19/05/2022	CONDUCTIVITY	79.4 μ sie/cm	2500
23/05/2022	CONDUCTIVITY	139 μ sie/cm	2500
24/05/2022	CONDUCTIVITY	145 μ sie/cm	2500
27/05/2022	CONDUCTIVITY	138 μ sie/cm	2500
04/06/2022	CONDUCTIVITY	139 μ sie/cm	2500
05/06/2022	CONDUCTIVITY	138 μ sie/cm	2500
07/06/2022	CONDUCTIVITY	134 μ sie/cm	2500
16/06/2022	CONDUCTIVITY	144 μ sie/cm	2500
17/06/2022	CONDUCTIVITY	144 μ sie/cm	2500
20/06/2022	CONDUCTIVITY	137 μ sie/cm	2500
28/06/2022	CONDUCTIVITY	136 μ sie/cm	2500
07/07/2022	CONDUCTIVITY	146 μ sie/cm	2500
20/07/2022	CONDUCTIVITY	150 μ sie/cm	2500
29/07/2022	CONDUCTIVITY	157 μ sie/cm	2500
10/08/2022	CONDUCTIVITY	162 μ sie/cm	2500
15/08/2022	CONDUCTIVITY	98.8 μ sie/cm	2500
23/08/2022	CONDUCTIVITY	157 μ sie/cm	2500
27/08/2022	CONDUCTIVITY	114 μ sie/cm	2500
08/09/2022	CONDUCTIVITY	153 μ sie/cm	2500
28/09/2022	CONDUCTIVITY	118 μ sie/cm	2500
05/10/2022	CONDUCTIVITY	153 μ sie/cm	2500
17/10/2022	CONDUCTIVITY	143 μ sie/cm	2500
20/10/2022	CONDUCTIVITY	147 μ sie/cm	2500
26/10/2022	CONDUCTIVITY	145 μ sie/cm	2500
01/11/2022	CONDUCTIVITY	70.7 μ sie/cm	2500
07/11/2022	CONDUCTIVITY	142 μ sie/cm	2500
15/11/2022	CONDUCTIVITY	158 μ sie/cm	2500
19/11/2022	CONDUCTIVITY	106 μ sie/cm	2500
22/11/2022	CONDUCTIVITY	139 μ sie/cm	2500
29/11/2022	CONDUCTIVITY	137 μ sie/cm	2500
30/11/2022	CONDUCTIVITY	101 μ sie/cm	2500
07/12/2022	CONDUCTIVITY	137 μ sie/cm	2500
16/12/2022	CONDUCTIVITY	139 μ sie/cm	2500
10/01/2023	CONDUCTIVITY	134 μ sie/cm	2500
27/01/2023	CONDUCTIVITY	126 μ sie/cm	2500
02/02/2023	CONDUCTIVITY	133 μ sie/cm	2500
07/02/2023	CONDUCTIVITY	138 μ sie/cm	2500
11/02/2023	CONDUCTIVITY	132 μ sie/cm	2500
01/03/2023	CONDUCTIVITY	134 μ sie/cm	2500
02/03/2023	CONDUCTIVITY	133 μ sie/cm	2500
14/03/2023	CONDUCTIVITY	134 μ sie/cm	2500
24/03/2023	CONDUCTIVITY	130 μ sie/cm	2500
29/03/2023	CONDUCTIVITY	130 μ sie/cm	2500
05/04/2023	CONDUCTIVITY	133 μ sie/cm	2500
06/04/2023	CONDUCTIVITY	129 μ sie/cm	2500
19/04/2023	CONDUCTIVITY	134 μ sie/cm	2500

26/04/2023	CONDUCTIVITY	133 μ sie/cm	2500
05/05/2023	CONDUCTIVITY	135 μ sie/cm	2500
09/05/2023	CONDUCTIVITY	137 μ sie/cm	2500
19/05/2023	CONDUCTIVITY	136 μ sie/cm	2500
24/05/2023	CONDUCTIVITY	135 μ sie/cm	2500
01/06/2023	CONDUCTIVITY	140 μ sie/cm	2500
06/06/2023	CONDUCTIVITY	140 μ sie/cm	2500
08/06/2023	CONDUCTIVITY	143 μ sie/cm	2500
09/06/2023	CONDUCTIVITY	141 μ sie/cm	2500
12/06/2023	CONDUCTIVITY	144 μ sie/cm	2500
28/06/2023	CONDUCTIVITY	149 μ sie/cm	2500
30/06/2023	CONDUCTIVITY	148 μ sie/cm	2500
04/07/2023	CONDUCTIVITY	152 μ sie/cm	2500
11/07/2023	CONDUCTIVITY	153 μ sie/cm	2500
12/07/2023	CONDUCTIVITY	162 μ sie/cm	2500
13/07/2023	CONDUCTIVITY	140 μ sie/cm	2500
18/07/2023	CONDUCTIVITY	144 μ sie/cm	2500
27/07/2023	CONDUCTIVITY	144 μ sie/cm	2500
28/07/2023	CONDUCTIVITY	114 μ sie/cm	2500
02/08/2023	CONDUCTIVITY	132 μ sie/cm	2500
05/08/2023	CONDUCTIVITY	134 μ sie/cm	2500
07/08/2023	CONDUCTIVITY	139 μ sie/cm	2500
24/08/2023	CONDUCTIVITY	145 μ sie/cm	2500
30/08/2023	CONDUCTIVITY	140 μ sie/cm	2500
22/09/2023	CONDUCTIVITY	141 μ sie/cm	2500
28/09/2023	CONDUCTIVITY	88.3 μ sie/cm	2500
04/10/2023	CONDUCTIVITY	137 μ sie/cm	2500
17/10/2023	CONDUCTIVITY	140 μ sie/cm	2500
27/10/2023	CONDUCTIVITY	76.5 μ sie/cm	2500
28/10/2023	CONDUCTIVITY	74.6 μ sie/cm	2500
31/10/2023	CONDUCTIVITY	136 μ sie/cm	2500
08/11/2023	CONDUCTIVITY	130 μ sie/cm	2500
14/11/2023	CONDUCTIVITY	76.1 μ sie/cm	2500
14/11/2023	CONDUCTIVITY	132 μ sie/cm	2500
23/11/2023	CONDUCTIVITY	131 μ sie/cm	2500
06/12/2023	CONDUCTIVITY	129 μ sie/cm	2500
13/12/2023	CONDUCTIVITY	129 μ sie/cm	2500
18/12/2023	CONDUCTIVITY	124 μ sie/cm	2500
19/12/2023	CONDUCTIVITY	122 μ sie/cm	2500
21/12/2023	CONDUCTIVITY	121 μ sie/cm	2500
22/12/2023	CONDUCTIVITY	121 μ sie/cm	2500
05/01/2024	CONDUCTIVITY	119 μ sie/cm	2500
06/01/2024	CONDUCTIVITY	116 μ sie/cm	2500
12/01/2024	CONDUCTIVITY	116 μ sie/cm	2500
17/01/2024	CONDUCTIVITY	121 μ sie/cm	2500
23/01/2024	CONDUCTIVITY	119 μ sie/cm	2500
01/02/2024	CONDUCTIVITY	117 μ sie/cm	2500
06/02/2024	CONDUCTIVITY	122 μ sie/cm	2500

22/02/2024	CONDUCTIVITY	118 μ sie/cm	2500
23/02/2024	CONDUCTIVITY	95.8 μ sie/cm	2500
28/02/2024	CONDUCTIVITY	119 μ sie/cm	2500
05/03/2024	CONDUCTIVITY	119 μ sie/cm	2500
15/03/2024	CONDUCTIVITY	119 μ sie/cm	2500
22/03/2024	CONDUCTIVITY	120 μ sie/cm	2500
26/03/2024	CONDUCTIVITY	121 μ sie/cm	2500
04/04/2024	CONDUCTIVITY	122 μ sie/cm	2500
10/04/2024	CONDUCTIVITY	124 μ sie/cm	2500
18/04/2024	CONDUCTIVITY	122 μ sie/cm	2500
23/04/2024	CONDUCTIVITY	134 μ sie/cm	2500
09/05/2024	CONDUCTIVITY	124 μ sie/cm	2500
15/05/2024	CONDUCTIVITY	127 μ sie/cm	2500
23/05/2024	CONDUCTIVITY	125 μ sie/cm	2500
24/05/2024	CONDUCTIVITY	130 μ sie/cm	2500
14/06/2024	CONDUCTIVITY	138 μ sie/cm	2500
20/06/2024	CONDUCTIVITY	134 μ sie/cm	2500
25/06/2024	CONDUCTIVITY	136 μ sie/cm	2500
26/06/2024	CONDUCTIVITY	142 μ sie/cm	2500
27/06/2024	CONDUCTIVITY	138 μ sie/cm	2500
02/07/2024	CONDUCTIVITY	127 μ sie/cm	2500
08/07/2024	CONDUCTIVITY	143 μ sie/cm	2500
17/07/2024	CONDUCTIVITY	147 μ sie/cm	2500
22/07/2024	CONDUCTIVITY	149 μ sie/cm	2500
08/08/2024	CONDUCTIVITY	152 μ sie/cm	2500
27/08/2024	CONDUCTIVITY	154 μ sie/cm	2500
28/08/2024	CONDUCTIVITY	154 μ sie/cm	2500
03/09/2024	CONDUCTIVITY	157 μ sie/cm	2500
04/09/2024	CONDUCTIVITY	157 μ sie/cm	2500
10/09/2024	CONDUCTIVITY	155 μ sie/cm	2500
24/09/2024	CONDUCTIVITY	154 μ sie/cm	2500
26/09/2024	CONDUCTIVITY	157 μ sie/cm	2500
04/10/2024	CONDUCTIVITY	156 μ sie/cm	2500
08/10/2024	CONDUCTIVITY	160 μ sie/cm	2500
09/10/2024	CONDUCTIVITY	83.7 μ sie/cm	2500
14/10/2024	CONDUCTIVITY	158 μ sie/cm	2500
16/10/2024	CONDUCTIVITY	160 μ sie/cm	2500
17/10/2024	CONDUCTIVITY	157 μ sie/cm	2500
31/10/2024	CONDUCTIVITY	165 μ sie/cm	2500
07/11/2024	CONDUCTIVITY	163 μ sie/cm	2500
18/11/2024	CONDUCTIVITY	164 μ sie/cm	2500
19/11/2024	CONDUCTIVITY	164 μ sie/cm	2500
21/11/2024	CONDUCTIVITY	165 μ sie/cm	2500
27/11/2024	CONDUCTIVITY	162 μ sie/cm	2500
06/12/2024	CONDUCTIVITY	153 μ sie/cm	2500
12/12/2024	CONDUCTIVITY	144 μ sie/cm	2500
18/12/2024	CONDUCTIVITY	144 μ sie/cm	2500
21/12/2024	CONDUCTIVITY	144 μ sie/cm	2500

02/01/2025	CONDUCTIVITY	144 μ sie/cm	2500
24/01/2025	CONDUCTIVITY	139 μ sie/cm	2500
29/01/2025	CONDUCTIVITY	136 μ sie/cm	2500
30/01/2025	CONDUCTIVITY	133 μ sie/cm	2500
07/02/2025	CONDUCTIVITY	139 μ sie/cm	2500
11/02/2025	CONDUCTIVITY	136 μ sie/cm	2500
24/02/2025	CONDUCTIVITY	132 μ sie/cm	2500
27/02/2025	CONDUCTIVITY	135 μ sie/cm	2500
13/03/2025	CONDUCTIVITY	136 μ sie/cm	2500
17/03/2025	CONDUCTIVITY	139 μ sie/cm	2500
21/03/2025	CONDUCTIVITY	135 μ sie/cm	2500
25/03/2025	CONDUCTIVITY	139 μ sie/cm	2500
03/04/2025	CONDUCTIVITY	138 μ sie/cm	2500
08/04/2025	CONDUCTIVITY	142 μ sie/cm	2500
16/04/2025	CONDUCTIVITY	142 μ sie/cm	2500
22/04/2025	CONDUCTIVITY	147 μ sie/cm	2500
07/05/2025	CONDUCTIVITY	150 μ sie/cm	2500
12/05/2025	CONDUCTIVITY	148 μ sie/cm	2500
13/05/2025	CONDUCTIVITY	160 μ sie/cm	2500
28/05/2025	CONDUCTIVITY	139 μ sie/cm	2500
05/06/2025	CONDUCTIVITY	144 μ sie/cm	2500
11/06/2025	CONDUCTIVITY	138 μ sie/cm	2500
16/06/2025	CONDUCTIVITY	141 μ sie/cm	2500
18/06/2025	CONDUCTIVITY	144 μ sie/cm	2500
19/06/2025	CONDUCTIVITY	145 μ sie/cm	2500
20/06/2025	CONDUCTIVITY	143 μ sie/cm	2500
01/07/2025	CONDUCTIVITY	152 μ sie/cm	2500
09/07/2025	CONDUCTIVITY	122 μ sie/cm	2500
21/07/2025	CONDUCTIVITY	94.3 μ sie/cm	2500
01/08/2025	CONDUCTIVITY	169 μ sie/cm	2500
07/08/2025	CONDUCTIVITY	160 μ sie/cm	2500
08/08/2025	CONDUCTIVITY	165 μ sie/cm	2500
03/09/2025	CONDUCTIVITY	148 μ sie/cm	2500
06/09/2025	CONDUCTIVITY	177 μ sie/cm	2500
10/09/2025	CONDUCTIVITY	144 μ sie/cm	2500
12/09/2025	CONDUCTIVITY	132 μ sie/cm	2500
30/09/2025	CONDUCTIVITY	136 μ sie/cm	2500
01/10/2025	CONDUCTIVITY	84.5 μ sie/cm	2500
08/10/2025	CONDUCTIVITY	92.2 μ sie/cm	2500
10/10/2025	CONDUCTIVITY	152 μ sie/cm	2500
14/10/2025	CONDUCTIVITY	90.1 μ sie/cm	2500
15/10/2025	CONDUCTIVITY	154 μ sie/cm	2500
20/10/2025	CONDUCTIVITY	140 μ sie/cm	2500
22/10/2025	CONDUCTIVITY	79.8 μ sie/cm	2500
28/10/2025	CONDUCTIVITY	144 μ sie/cm	2500
08/11/2025	CONDUCTIVITY	142 μ sie/cm	2500
12/11/2025	CONDUCTIVITY	143 μ sie/cm	2500
19/11/2025	CONDUCTIVITY	134 μ sie/cm	2500

26/11/2025	CONDUCTIVITY		132 µsie/cm	2500
03/12/2025	CONDUCTIVITY		139 µsie/cm	2500
11/12/2025	CONDUCTIVITY		84 µsie/cm	2500
12/12/2025	CONDUCTIVITY		135 µsie/cm	2500
08/01/2026	CONDUCTIVITY		121 µsie/cm	2500
15/01/2026	CONDUCTIVITY		141 µsie/cm	2500
19/01/2026	CONDUCTIVITY		137 µsie/cm	2500
20/01/2026	CONDUCTIVITY		140 µsie/cm	2500
27/01/2026	CONDUCTIVITY		138 µsie/cm	2500
28/01/2026	CONDUCTIVITY		135 µsie/cm	2500
05/02/2026	CONDUCTIVITY		137 µsie/cm	2500
11/02/2026	CONDUCTIVITY		137 µsie/cm	2500
21/05/2021	COPPER		59.8 µg/l	2000
23/06/2021	COPPER		16.4 µg/l	2000
30/06/2021	COPPER		49.6 µg/l	2000
24/09/2021	COPPER		22.8 µg/l	2000
29/09/2021	COPPER		13.7 µg/l	2000
07/10/2021	COPPER	<	10.4 µg/l	2000
26/10/2021	COPPER	<	10.4 µg/l	2000
25/11/2021	COPPER		7.81 µg/l	2000
24/01/2022	COPPER	<	3.16 µg/l	2000
25/02/2022	COPPER		133 µg/l	2000
11/04/2022	COPPER		24.8 µg/l	2000
18/05/2022	COPPER	<	10.4 µg/l	2000
07/06/2022	COPPER		11.7 µg/l	2000
11/08/2022	COPPER		22.1 µg/l	2000
27/08/2022	COPPER		18 µg/l	2000
05/10/2022	COPPER		14 µg/l	2000
24/01/2023	COPPER	<	10.4 µg/l	2000
02/03/2023	COPPER	<	10.4 µg/l	2000
05/04/2023	COPPER		16.9 µg/l	2000
12/07/2023	COPPER	<	10.4 µg/l	2000
31/07/2023	COPPER		27.8 µg/l	2000
14/10/2023	COPPER	<	10.4 µg/l	2000
10/11/2023	COPPER		64.3 µg/l	2000
18/12/2023	COPPER		34.6 µg/l	2000
19/12/2023	COPPER	<	10.4 µg/l	2000
05/01/2024	COPPER	<	10.4 µg/l	2000
08/02/2024	COPPER	<	10.4 µg/l	2000
22/02/2024	COPPER	<	10.4 µg/l	2000
15/05/2024	COPPER	<	10.4 µg/l	2000
14/06/2024	COPPER	<	10.4 µg/l	2000
24/07/2024	COPPER		98.5 µg/l	2000
06/09/2024	COPPER		50.1 µg/l	2000
13/11/2024	COPPER	<	10.4 µg/l	2000
15/11/2024	COPPER	<	10.4 µg/l	2000
07/02/2025	COPPER		28.7 µg/l	2000
29/03/2025	COPPER	<	10.4 µg/l	2000

24/04/2025	COPPER	<	10.4 µg/l	2000
27/06/2025	COPPER	<	10.4 µg/l	2000
04/07/2025	COPPER		13 µg/l	2000
10/10/2025	COPPER	<	10.4 µg/l	2000
29/10/2025	COPPER		82.6 µg/l	2000
19/12/2025	COPPER	<	10.4 µg/l	2000
09/02/2026	COPPER	<	24.8 µg/l	2000
03/03/2021	E COLI		0 No/100ml	0
10/03/2021	E COLI		0 No/100ml	0
11/03/2021	E COLI		0 No/100ml	0
14/03/2021	E COLI		0 No/100ml	0
19/03/2021	E COLI		0 No/100ml	0
20/03/2021	E COLI		0 No/100ml	0
21/03/2021	E COLI		0 No/100ml	0
25/03/2021	E COLI		0 No/100ml	0
26/03/2021	E COLI		0 No/100ml	0
29/03/2021	E COLI		0 No/100ml	0
30/03/2021	E COLI		0 No/100ml	0
31/03/2021	E COLI		0 No/100ml	0
01/04/2021	E COLI		0 No/100ml	0
04/04/2021	E COLI		0 No/100ml	0
07/04/2021	E COLI		0 No/100ml	0
08/04/2021	E COLI		0 No/100ml	0
09/04/2021	E COLI		0 No/100ml	0
10/04/2021	E COLI		0 No/100ml	0
18/04/2021	E COLI		0 No/100ml	0
23/04/2021	E COLI		0 No/100ml	0
06/05/2021	E COLI		0 No/100ml	0
08/05/2021	E COLI		0 No/100ml	0
10/05/2021	E COLI		0 No/100ml	0
11/05/2021	E COLI		0 No/100ml	0
12/05/2021	E COLI		0 No/100ml	0
14/05/2021	E COLI		0 No/100ml	0
17/05/2021	E COLI		0 No/100ml	0
19/05/2021	E COLI		0 No/100ml	0
20/05/2021	E COLI		0 No/100ml	0
21/05/2021	E COLI		0 No/100ml	0
22/05/2021	E COLI		0 No/100ml	0
25/05/2021	E COLI		0 No/100ml	0
26/05/2021	E COLI		0 No/100ml	0
27/05/2021	E COLI		0 No/100ml	0
28/05/2021	E COLI		0 No/100ml	0
29/05/2021	E COLI		0 No/100ml	0
30/05/2021	E COLI		0 No/100ml	0
02/06/2021	E COLI		0 No/100ml	0
04/06/2021	E COLI		0 No/100ml	0
07/06/2021	E COLI		0 No/100ml	0
08/06/2021	E COLI		0 No/100ml	0

09/06/2021 E COLI	0 No/100ml	0
11/06/2021 E COLI	0 No/100ml	0
14/06/2021 E COLI	0 No/100ml	0
15/06/2021 E COLI	0 No/100ml	0
23/06/2021 E COLI	0 No/100ml	0
24/06/2021 E COLI	0 No/100ml	0
25/06/2021 E COLI	0 No/100ml	0
29/06/2021 E COLI	0 No/100ml	0
30/06/2021 E COLI	0 No/100ml	0
01/07/2021 E COLI	0 No/100ml	0
02/07/2021 E COLI	0 No/100ml	0
06/07/2021 E COLI	0 No/100ml	0
07/07/2021 E COLI	0 No/100ml	0
08/07/2021 E COLI	0 No/100ml	0
09/07/2021 E COLI	0 No/100ml	0
12/07/2021 E COLI	0 No/100ml	0
14/07/2021 E COLI	0 No/100ml	0
15/07/2021 E COLI	0 No/100ml	0
21/07/2021 E COLI	0 No/100ml	0
22/07/2021 E COLI	0 No/100ml	0
23/07/2021 E COLI	0 No/100ml	0
26/07/2021 E COLI	0 No/100ml	0
03/08/2021 E COLI	0 No/100ml	0
06/08/2021 E COLI	0 No/100ml	0
07/08/2021 E COLI	0 No/100ml	0
08/08/2021 E COLI	0 No/100ml	0
09/08/2021 E COLI	0 No/100ml	0
16/08/2021 E COLI	0 No/100ml	0
25/08/2021 E COLI	0 No/100ml	0
27/08/2021 E COLI	0 No/100ml	0
01/09/2021 E COLI	0 No/100ml	0
06/09/2021 E COLI	0 No/100ml	0
09/09/2021 E COLI	0 No/100ml	0
24/09/2021 E COLI	0 No/100ml	0
28/09/2021 E COLI	0 No/100ml	0
29/09/2021 E COLI	0 No/100ml	0
30/09/2021 E COLI	0 No/100ml	0
01/10/2021 E COLI	0 No/100ml	0
04/10/2021 E COLI	0 No/100ml	0
05/10/2021 E COLI	0 No/100ml	0
07/10/2021 E COLI	0 No/100ml	0
13/10/2021 E COLI	0 No/100ml	0
14/10/2021 E COLI	0 No/100ml	0
17/10/2021 E COLI	0 No/100ml	0
18/10/2021 E COLI	0 No/100ml	0
19/10/2021 E COLI	0 No/100ml	0
20/10/2021 E COLI	0 No/100ml	0
21/10/2021 E COLI	0 No/100ml	0

22/10/2021 E COLI	0 No/100ml	0
25/10/2021 E COLI	0 No/100ml	0
26/10/2021 E COLI	0 No/100ml	0
28/10/2021 E COLI	0 No/100ml	0
29/10/2021 E COLI	0 No/100ml	0
30/10/2021 E COLI	0 No/100ml	0
03/11/2021 E COLI	0 No/100ml	0
04/11/2021 E COLI	0 No/100ml	0
05/11/2021 E COLI	0 No/100ml	0
08/11/2021 E COLI	0 No/100ml	0
10/11/2021 E COLI	0 No/100ml	0
11/11/2021 E COLI	0 No/100ml	0
13/11/2021 E COLI	0 No/100ml	0
15/11/2021 E COLI	0 No/100ml	0
16/11/2021 E COLI	0 No/100ml	0
18/11/2021 E COLI	0 No/100ml	0
19/11/2021 E COLI	0 No/100ml	0
22/11/2021 E COLI	0 No/100ml	0
23/11/2021 E COLI	0 No/100ml	0
25/11/2021 E COLI	0 No/100ml	0
29/11/2021 E COLI	0 No/100ml	0
30/11/2021 E COLI	0 No/100ml	0
02/12/2021 E COLI	0 No/100ml	0
03/12/2021 E COLI	0 No/100ml	0
04/12/2021 E COLI	0 No/100ml	0
06/12/2021 E COLI	0 No/100ml	0
07/12/2021 E COLI	0 No/100ml	0
08/12/2021 E COLI	0 No/100ml	0
09/12/2021 E COLI	0 No/100ml	0
09/12/2021 E COLI	0 No/100ml	0
10/12/2021 E COLI	0 No/100ml	0
10/12/2021 E COLI	0 No/100ml	0
11/12/2021 E COLI	0 No/100ml	0
13/12/2021 E COLI	0 No/100ml	0
14/12/2021 E COLI	0 No/100ml	0
15/12/2021 E COLI	0 No/100ml	0
15/12/2021 E COLI	0 No/100ml	0
16/12/2021 E COLI	0 No/100ml	0
17/12/2021 E COLI	0 No/100ml	0
17/12/2021 E COLI	0 No/100ml	0
18/12/2021 E COLI	0 No/100ml	0
19/12/2021 E COLI	0 No/100ml	0
20/12/2021 E COLI	0 No/100ml	0
20/12/2021 E COLI	0 No/100ml	0
21/12/2021 E COLI	0 No/100ml	0
21/12/2021 E COLI	0 No/100ml	0
22/12/2021 E COLI	0 No/100ml	0
22/12/2021 E COLI	0 No/100ml	0

23/12/2021 E COLI	0 No/100ml	0
05/01/2022 E COLI	0 No/100ml	0
07/01/2022 E COLI	0 No/100ml	0
12/01/2022 E COLI	0 No/100ml	0
14/01/2022 E COLI	0 No/100ml	0
19/01/2022 E COLI	0 No/100ml	0
24/01/2022 E COLI	0 No/100ml	0
25/01/2022 E COLI	0 No/100ml	0
27/01/2022 E COLI	0 No/100ml	0
28/01/2022 E COLI	0 No/100ml	0
31/01/2022 E COLI	0 No/100ml	0
01/02/2022 E COLI	0 No/100ml	0
04/02/2022 E COLI	0 No/100ml	0
07/02/2022 E COLI	0 No/100ml	0
08/02/2022 E COLI	0 No/100ml	0
09/02/2022 E COLI	0 No/100ml	0
11/02/2022 E COLI	0 No/100ml	0
16/02/2022 E COLI	0 No/100ml	0
18/02/2022 E COLI	0 No/100ml	0
21/02/2022 E COLI	0 No/100ml	0
22/02/2022 E COLI	0 No/100ml	0
25/02/2022 E COLI	0 No/100ml	0
26/02/2022 E COLI	0 No/100ml	0
01/03/2022 E COLI	0 No/100ml	0
01/03/2022 E COLI	0 No/100ml	0
02/03/2022 E COLI	0 No/100ml	0
03/03/2022 E COLI	0 No/100ml	0
04/03/2022 E COLI	0 No/100ml	0
10/03/2022 E COLI	0 No/100ml	0
15/03/2022 E COLI	0 No/100ml	0
16/03/2022 E COLI	0 No/100ml	0
17/03/2022 E COLI	0 No/100ml	0
21/03/2022 E COLI	0 No/100ml	0
22/03/2022 E COLI	0 No/100ml	0
24/03/2022 E COLI	0 No/100ml	0
28/03/2022 E COLI	0 No/100ml	0
30/03/2022 E COLI	0 No/100ml	0
31/03/2022 E COLI	0 No/100ml	0
05/04/2022 E COLI	0 No/100ml	0
07/04/2022 E COLI	0 No/100ml	0
08/04/2022 E COLI	0 No/100ml	0
11/04/2022 E COLI	0 No/100ml	0
12/04/2022 E COLI	0 No/100ml	0
13/04/2022 E COLI	0 No/100ml	0
14/04/2022 E COLI	0 No/100ml	0
19/04/2022 E COLI	0 No/100ml	0
20/04/2022 E COLI	0 No/100ml	0
21/04/2022 E COLI	0 No/100ml	0

25/04/2022	E COLI	0 No/100ml	0
28/04/2022	E COLI	0 No/100ml	0
03/05/2022	E COLI	0 No/100ml	0
04/05/2022	E COLI	0 No/100ml	0
05/05/2022	E COLI	0 No/100ml	0
09/05/2022	E COLI	0 No/100ml	0
10/05/2022	E COLI	0 No/100ml	0
12/05/2022	E COLI	0 No/100ml	0
16/05/2022	E COLI	0 No/100ml	0
17/05/2022	E COLI	0 No/100ml	0
18/05/2022	E COLI	0 No/100ml	0
19/05/2022	E COLI	0 No/100ml	0
23/05/2022	E COLI	0 No/100ml	0
24/05/2022	E COLI	0 No/100ml	0
25/05/2022	E COLI	0 No/100ml	0
27/05/2022	E COLI	0 No/100ml	0
01/06/2022	E COLI	0 No/100ml	0
04/06/2022	E COLI	0 No/100ml	0
05/06/2022	E COLI	0 No/100ml	0
07/06/2022	E COLI	0 No/100ml	0
09/06/2022	E COLI	0 No/100ml	0
10/06/2022	E COLI	0 No/100ml	0
13/06/2022	E COLI	0 No/100ml	0
15/06/2022	E COLI	0 No/100ml	0
16/06/2022	E COLI	0 No/100ml	0
17/06/2022	E COLI	0 No/100ml	0
20/06/2022	E COLI	0 No/100ml	0
21/06/2022	E COLI	0 No/100ml	0
24/06/2022	E COLI	0 No/100ml	0
28/06/2022	E COLI	0 No/100ml	0
01/07/2022	E COLI	0 No/100ml	0
06/07/2022	E COLI	0 No/100ml	0
07/07/2022	E COLI	0 No/100ml	0
08/07/2022	E COLI	0 No/100ml	0
11/07/2022	E COLI	0 No/100ml	0
20/07/2022	E COLI	0 No/100ml	0
21/07/2022	E COLI	0 No/100ml	0
26/07/2022	E COLI	0 No/100ml	0
27/07/2022	E COLI	0 No/100ml	0
29/07/2022	E COLI	0 No/100ml	0
05/08/2022	E COLI	0 No/100ml	0
09/08/2022	E COLI	0 No/100ml	0
10/08/2022	E COLI	0 No/100ml	0
11/08/2022	E COLI	0 No/100ml	0
15/08/2022	E COLI	0 No/100ml	0
18/08/2022	E COLI	0 No/100ml	0
19/08/2022	E COLI	0 No/100ml	0
23/08/2022	E COLI	0 No/100ml	0

24/08/2022	E COLI	0 No/100ml	0
27/08/2022	E COLI	0 No/100ml	0
28/08/2022	E COLI	0 No/100ml	0
07/09/2022	E COLI	0 No/100ml	0
08/09/2022	E COLI	0 No/100ml	0
14/09/2022	E COLI	0 No/100ml	0
15/09/2022	E COLI	0 No/100ml	0
20/09/2022	E COLI	0 No/100ml	0
22/09/2022	E COLI	0 No/100ml	0
28/09/2022	E COLI	0 No/100ml	0
29/09/2022	E COLI	0 No/100ml	0
04/10/2022	E COLI	0 No/100ml	0
05/10/2022	E COLI	0 No/100ml	0
17/10/2022	E COLI	0 No/100ml	0
20/10/2022	E COLI	0 No/100ml	0
26/10/2022	E COLI	0 No/100ml	0
01/11/2022	E COLI	0 No/100ml	0
03/11/2022	E COLI	0 No/100ml	0
07/11/2022	E COLI	0 No/100ml	0
08/11/2022	E COLI	0 No/100ml	0
10/11/2022	E COLI	0 No/100ml	0
14/11/2022	E COLI	0 No/100ml	0
15/11/2022	E COLI	0 No/100ml	0
16/11/2022	E COLI	0 No/100ml	0
18/11/2022	E COLI	0 No/100ml	0
19/11/2022	E COLI	0 No/100ml	0
22/11/2022	E COLI	0 No/100ml	0
24/11/2022	E COLI	0 No/100ml	0
28/11/2022	E COLI	0 No/100ml	0
29/11/2022	E COLI	0 No/100ml	0
30/11/2022	E COLI	0 No/100ml	0
05/12/2022	E COLI	0 No/100ml	0
06/12/2022	E COLI	0 No/100ml	0
07/12/2022	E COLI	0 No/100ml	0
09/12/2022	E COLI	0 No/100ml	0
12/12/2022	E COLI	0 No/100ml	0
14/12/2022	E COLI	0 No/100ml	0
16/12/2022	E COLI	0 No/100ml	0
17/12/2022	E COLI	0 No/100ml	0
03/01/2023	E COLI	0 No/100ml	0
10/01/2023	E COLI	0 No/100ml	0
11/01/2023	E COLI	0 No/100ml	0
16/01/2023	E COLI	0 No/100ml	0
17/01/2023	E COLI	0 No/100ml	0
18/01/2023	E COLI	0 No/100ml	0
24/01/2023	E COLI	0 No/100ml	0
27/01/2023	E COLI	0 No/100ml	0
01/02/2023	E COLI	0 No/100ml	0

02/02/2023	E COLI	0 No/100ml	0
07/02/2023	E COLI	0 No/100ml	0
09/02/2023	E COLI	0 No/100ml	0
10/02/2023	E COLI	0 No/100ml	0
11/02/2023	E COLI	0 No/100ml	0
20/02/2023	E COLI	0 No/100ml	0
22/02/2023	E COLI	0 No/100ml	0
24/02/2023	E COLI	0 No/100ml	0
27/02/2023	E COLI	0 No/100ml	0
28/02/2023	E COLI	0 No/100ml	0
01/03/2023	E COLI	0 No/100ml	0
02/03/2023	E COLI	0 No/100ml	0
06/03/2023	E COLI	0 No/100ml	0
08/03/2023	E COLI	0 No/100ml	0
14/03/2023	E COLI	0 No/100ml	0
20/03/2023	E COLI	0 No/100ml	0
22/03/2023	E COLI	0 No/100ml	0
24/03/2023	E COLI	0 No/100ml	0
29/03/2023	E COLI	0 No/100ml	0
31/03/2023	E COLI	0 No/100ml	0
04/04/2023	E COLI	0 No/100ml	0
05/04/2023	E COLI	0 No/100ml	0
06/04/2023	E COLI	0 No/100ml	0
08/04/2023	E COLI	0 No/100ml	0
11/04/2023	E COLI	0 No/100ml	0
18/04/2023	E COLI	0 No/100ml	0
19/04/2023	E COLI	0 No/100ml	0
21/04/2023	E COLI	0 No/100ml	0
25/04/2023	E COLI	0 No/100ml	0
26/04/2023	E COLI	0 No/100ml	0
27/04/2023	E COLI	0 No/100ml	0
02/05/2023	E COLI	0 No/100ml	0
05/05/2023	E COLI	0 No/100ml	0
09/05/2023	E COLI	0 No/100ml	0
10/05/2023	E COLI	0 No/100ml	0
13/05/2023	E COLI	0 No/100ml	0
15/05/2023	E COLI	0 No/100ml	0
17/05/2023	E COLI	0 No/100ml	0
19/05/2023	E COLI	0 No/100ml	0
20/05/2023	E COLI	0 No/100ml	0
24/05/2023	E COLI	0 No/100ml	0
30/05/2023	E COLI	0 No/100ml	0
01/06/2023	E COLI	0 No/100ml	0
06/06/2023	E COLI	0 No/100ml	0
07/06/2023	E COLI	0 No/100ml	0
08/06/2023	E COLI	0 No/100ml	0
09/06/2023	E COLI	0 No/100ml	0
12/06/2023	E COLI	0 No/100ml	0

14/06/2023 E COLI	0 No/100ml	0
15/06/2023 E COLI	0 No/100ml	0
19/06/2023 E COLI	0 No/100ml	0
28/06/2023 E COLI	0 No/100ml	0
29/06/2023 E COLI	0 No/100ml	0
30/06/2023 E COLI	0 No/100ml	0
04/07/2023 E COLI	0 No/100ml	0
05/07/2023 E COLI	0 No/100ml	0
07/07/2023 E COLI	0 No/100ml	0
11/07/2023 E COLI	0 No/100ml	0
12/07/2023 E COLI	0 No/100ml	0
13/07/2023 E COLI	0 No/100ml	0
14/07/2023 E COLI	0 No/100ml	0
17/07/2023 E COLI	0 No/100ml	0
18/07/2023 E COLI	0 No/100ml	0
19/07/2023 E COLI	0 No/100ml	0
25/07/2023 E COLI	0 No/100ml	0
27/07/2023 E COLI	0 No/100ml	0
28/07/2023 E COLI	0 No/100ml	0
28/07/2023 E COLI	0 No/100ml	0
31/07/2023 E COLI	0 No/100ml	0
01/08/2023 E COLI	0 No/100ml	0
02/08/2023 E COLI	0 No/100ml	0
03/08/2023 E COLI	0 No/100ml	0
05/08/2023 E COLI	0 No/100ml	0
07/08/2023 E COLI	0 No/100ml	0
08/08/2023 E COLI	0 No/100ml	0
10/08/2023 E COLI	0 No/100ml	0
11/08/2023 E COLI	0 No/100ml	0
16/08/2023 E COLI	0 No/100ml	0
17/08/2023 E COLI	0 No/100ml	0
19/08/2023 E COLI	0 No/100ml	0
21/08/2023 E COLI	0 No/100ml	0
24/08/2023 E COLI	0 No/100ml	0
30/08/2023 E COLI	0 No/100ml	0
02/09/2023 E COLI	0 No/100ml	0
04/09/2023 E COLI	0 No/100ml	0
12/09/2023 E COLI	0 No/100ml	0
14/09/2023 E COLI	0 No/100ml	0
22/09/2023 E COLI	0 No/100ml	0
28/09/2023 E COLI	0 No/100ml	0
04/10/2023 E COLI	0 No/100ml	0
06/10/2023 E COLI	0 No/100ml	0
14/10/2023 E COLI	0 No/100ml	0
17/10/2023 E COLI	0 No/100ml	0
20/10/2023 E COLI	0 No/100ml	0
27/10/2023 E COLI	0 No/100ml	0
28/10/2023 E COLI	0 No/100ml	0

31/10/2023 E COLI	0 No/100ml	0
04/11/2023 E COLI	0 No/100ml	0
06/11/2023 E COLI	0 No/100ml	0
08/11/2023 E COLI	0 No/100ml	0
10/11/2023 E COLI	0 No/100ml	0
14/11/2023 E COLI	0 No/100ml	0
14/11/2023 E COLI	0 No/100ml	0
14/11/2023 E COLI	0 No/100ml	0
15/11/2023 E COLI	0 No/100ml	0
15/11/2023 E COLI	0 No/100ml	0
16/11/2023 E COLI	0 No/100ml	0
17/11/2023 E COLI	0 No/100ml	0
20/11/2023 E COLI	0 No/100ml	0
22/11/2023 E COLI	0 No/100ml	0
22/11/2023 E COLI	0 No/100ml	0
23/11/2023 E COLI	0 No/100ml	0
27/11/2023 E COLI	0 No/100ml	0
28/11/2023 E COLI	0 No/100ml	0
29/11/2023 E COLI	0 No/100ml	0
04/12/2023 E COLI	0 No/100ml	0
05/12/2023 E COLI	0 No/100ml	0
06/12/2023 E COLI	0 No/100ml	0
08/12/2023 E COLI	0 No/100ml	0
13/12/2023 E COLI	0 No/100ml	0
15/12/2023 E COLI	0 No/100ml	0
18/12/2023 E COLI	0 No/100ml	0
19/12/2023 E COLI	0 No/100ml	0
21/12/2023 E COLI	0 No/100ml	0
22/12/2023 E COLI	0 No/100ml	0
03/01/2024 E COLI	0 No/100ml	0
04/01/2024 E COLI	0 No/100ml	0
05/01/2024 E COLI	0 No/100ml	0
06/01/2024 E COLI	0 No/100ml	0
08/01/2024 E COLI	0 No/100ml	0
09/01/2024 E COLI	0 No/100ml	0
11/01/2024 E COLI	0 No/100ml	0
12/01/2024 E COLI	0 No/100ml	0
15/01/2024 E COLI	0 No/100ml	0
17/01/2024 E COLI	0 No/100ml	0
19/01/2024 E COLI	0 No/100ml	0
23/01/2024 E COLI	0 No/100ml	0
24/01/2024 E COLI	0 No/100ml	0
26/01/2024 E COLI	0 No/100ml	0
27/01/2024 E COLI	0 No/100ml	0
30/01/2024 E COLI	0 No/100ml	0
31/01/2024 E COLI	0 No/100ml	0
01/02/2024 E COLI	0 No/100ml	0
06/02/2024 E COLI	0 No/100ml	0

08/02/2024	E COLI	0 No/100ml	0
12/02/2024	E COLI	0 No/100ml	0
13/02/2024	E COLI	0 No/100ml	0
19/02/2024	E COLI	0 No/100ml	0
20/02/2024	E COLI	0 No/100ml	0
22/02/2024	E COLI	0 No/100ml	0
23/02/2024	E COLI	0 No/100ml	0
27/02/2024	E COLI	0 No/100ml	0
28/02/2024	E COLI	0 No/100ml	0
05/03/2024	E COLI	0 No/100ml	0
07/03/2024	E COLI	0 No/100ml	0
08/03/2024	E COLI	0 No/100ml	0
12/03/2024	E COLI	0 No/100ml	0
13/03/2024	E COLI	0 No/100ml	0
14/03/2024	E COLI	0 No/100ml	0
15/03/2024	E COLI	0 No/100ml	0
19/03/2024	E COLI	0 No/100ml	0
20/03/2024	E COLI	0 No/100ml	0
22/03/2024	E COLI	0 No/100ml	0
26/03/2024	E COLI	0 No/100ml	0
04/04/2024	E COLI	0 No/100ml	0
08/04/2024	E COLI	0 No/100ml	0
10/04/2024	E COLI	0 No/100ml	0
11/04/2024	E COLI	0 No/100ml	0
18/04/2024	E COLI	0 No/100ml	0
19/04/2024	E COLI	0 No/100ml	0
23/04/2024	E COLI	0 No/100ml	0
26/04/2024	E COLI	0 No/100ml	0
01/05/2024	E COLI	0 No/100ml	0
03/05/2024	E COLI	0 No/100ml	0
08/05/2024	E COLI	0 No/100ml	0
09/05/2024	E COLI	0 No/100ml	0
13/05/2024	E COLI	0 No/100ml	0
14/05/2024	E COLI	0 No/100ml	0
15/05/2024	E COLI	0 No/100ml	0
16/05/2024	E COLI	0 No/100ml	0
21/05/2024	E COLI	0 No/100ml	0
23/05/2024	E COLI	0 No/100ml	0
24/05/2024	E COLI	0 No/100ml	0
28/05/2024	E COLI	0 No/100ml	0
07/06/2024	E COLI	0 No/100ml	0
11/06/2024	E COLI	0 No/100ml	0
13/06/2024	E COLI	0 No/100ml	0
14/06/2024	E COLI	0 No/100ml	0
18/06/2024	E COLI	0 No/100ml	0
20/06/2024	E COLI	0 No/100ml	0
25/06/2024	E COLI	0 No/100ml	0
26/06/2024	E COLI	0 No/100ml	0

27/06/2024 E COLI	0 No/100ml	0
28/06/2024 E COLI	0 No/100ml	0
02/07/2024 E COLI	0 No/100ml	0
03/07/2024 E COLI	0 No/100ml	0
08/07/2024 E COLI	0 No/100ml	0
16/07/2024 E COLI	0 No/100ml	0
17/07/2024 E COLI	0 No/100ml	0
19/07/2024 E COLI	0 No/100ml	0
22/07/2024 E COLI	0 No/100ml	0
24/07/2024 E COLI	0 No/100ml	0
26/07/2024 E COLI	0 No/100ml	0
31/07/2024 E COLI	0 No/100ml	0
07/08/2024 E COLI	0 No/100ml	0
08/08/2024 E COLI	0 No/100ml	0
09/08/2024 E COLI	0 No/100ml	0
13/08/2024 E COLI	0 No/100ml	0
14/08/2024 E COLI	0 No/100ml	0
16/08/2024 E COLI	0 No/100ml	0
23/08/2024 E COLI	0 No/100ml	0
27/08/2024 E COLI	0 No/100ml	0
28/08/2024 E COLI	0 No/100ml	0
29/08/2024 E COLI	0 No/100ml	0
30/08/2024 E COLI	0 No/100ml	0
02/09/2024 E COLI	0 No/100ml	0
03/09/2024 E COLI	0 No/100ml	0
04/09/2024 E COLI	0 No/100ml	0
06/09/2024 E COLI	0 No/100ml	0
10/09/2024 E COLI	0 No/100ml	0
17/09/2024 E COLI	0 No/100ml	0
24/09/2024 E COLI	0 No/100ml	0
26/09/2024 E COLI	0 No/100ml	0
27/09/2024 E COLI	0 No/100ml	0
01/10/2024 E COLI	0 No/100ml	0
02/10/2024 E COLI	0 No/100ml	0
03/10/2024 E COLI	0 No/100ml	0
04/10/2024 E COLI	0 No/100ml	0
08/10/2024 E COLI	0 No/100ml	0
09/10/2024 E COLI	0 No/100ml	0
10/10/2024 E COLI	0 No/100ml	0
11/10/2024 E COLI	0 No/100ml	0
14/10/2024 E COLI	0 No/100ml	0
15/10/2024 E COLI	0 No/100ml	0
16/10/2024 E COLI	0 No/100ml	0
17/10/2024 E COLI	0 No/100ml	0
21/10/2024 E COLI	0 No/100ml	0
22/10/2024 E COLI	0 No/100ml	0
23/10/2024 E COLI	0 No/100ml	0
25/10/2024 E COLI	0 No/100ml	0

29/10/2024 E COLI	0 No/100ml	0
31/10/2024 E COLI	0 No/100ml	0
05/11/2024 E COLI	0 No/100ml	0
07/11/2024 E COLI	0 No/100ml	0
13/11/2024 E COLI	0 No/100ml	0
13/11/2024 E COLI	0 No/100ml	0
15/11/2024 E COLI	0 No/100ml	0
18/11/2024 E COLI	0 No/100ml	0
19/11/2024 E COLI	0 No/100ml	0
20/11/2024 E COLI	0 No/100ml	0
21/11/2024 E COLI	0 No/100ml	0
22/11/2024 E COLI	0 No/100ml	0
25/11/2024 E COLI	0 No/100ml	0
27/11/2024 E COLI	0 No/100ml	0
28/11/2024 E COLI	0 No/100ml	0
03/12/2024 E COLI	0 No/100ml	0
04/12/2024 E COLI	0 No/100ml	0
06/12/2024 E COLI	0 No/100ml	0
10/12/2024 E COLI	0 No/100ml	0
12/12/2024 E COLI	0 No/100ml	0
18/12/2024 E COLI	0 No/100ml	0
19/12/2024 E COLI	0 No/100ml	0
21/12/2024 E COLI	0 No/100ml	0
02/01/2025 E COLI	0 No/100ml	0
10/01/2025 E COLI	0 No/100ml	0
16/01/2025 E COLI	0 No/100ml	0
18/01/2025 E COLI	0 No/100ml	0
20/01/2025 E COLI	0 No/100ml	0
21/01/2025 E COLI	0 No/100ml	0
22/01/2025 E COLI	0 No/100ml	0
24/01/2025 E COLI	0 No/100ml	0
28/01/2025 E COLI	0 No/100ml	0
29/01/2025 E COLI	0 No/100ml	0
30/01/2025 E COLI	0 No/100ml	0
04/02/2025 E COLI	0 No/100ml	0
05/02/2025 E COLI	0 No/100ml	0
06/02/2025 E COLI	0 No/100ml	0
07/02/2025 E COLI	0 No/100ml	0
11/02/2025 E COLI	0 No/100ml	0
12/02/2025 E COLI	0 No/100ml	0
14/02/2025 E COLI	0 No/100ml	0
24/02/2025 E COLI	0 No/100ml	0
27/02/2025 E COLI	0 No/100ml	0
27/02/2025 E COLI	0 No/100ml	0
05/03/2025 E COLI	0 No/100ml	0
07/03/2025 E COLI	0 No/100ml	0
13/03/2025 E COLI	0 No/100ml	0
17/03/2025 E COLI	0 No/100ml	0

19/03/2025 E COLI	0 No/100ml	0
21/03/2025 E COLI	0 No/100ml	0
25/03/2025 E COLI	0 No/100ml	0
26/03/2025 E COLI	0 No/100ml	0
29/03/2025 E COLI	0 No/100ml	0
03/04/2025 E COLI	0 No/100ml	0
05/04/2025 E COLI	0 No/100ml	0
08/04/2025 E COLI	0 No/100ml	0
10/04/2025 E COLI	0 No/100ml	0
11/04/2025 E COLI	0 No/100ml	0
16/04/2025 E COLI	0 No/100ml	0
22/04/2025 E COLI	0 No/100ml	0
24/04/2025 E COLI	0 No/100ml	0
29/04/2025 E COLI	0 No/100ml	0
01/05/2025 E COLI	0 No/100ml	0
06/05/2025 E COLI	0 No/100ml	0
07/05/2025 E COLI	0 No/100ml	0
08/05/2025 E COLI	0 No/100ml	0
12/05/2025 E COLI	0 No/100ml	0
13/05/2025 E COLI	0 No/100ml	0
14/05/2025 E COLI	0 No/100ml	0
16/05/2025 E COLI	0 No/100ml	0
17/05/2025 E COLI	0 No/100ml	0
21/05/2025 E COLI	0 No/100ml	0
23/05/2025 E COLI	0 No/100ml	0
28/05/2025 E COLI	0 No/100ml	0
05/06/2025 E COLI	0 No/100ml	0
09/06/2025 E COLI	0 No/100ml	0
11/06/2025 E COLI	0 No/100ml	0
12/06/2025 E COLI	0 No/100ml	0
13/06/2025 E COLI	0 No/100ml	0
14/06/2025 E COLI	0 No/100ml	0
15/06/2025 E COLI	0 No/100ml	0
16/06/2025 E COLI	0 No/100ml	0
17/06/2025 E COLI	0 No/100ml	0
18/06/2025 E COLI	0 No/100ml	0
19/06/2025 E COLI	0 No/100ml	0
20/06/2025 E COLI	0 No/100ml	0
26/06/2025 E COLI	0 No/100ml	0
27/06/2025 E COLI	0 No/100ml	0
01/07/2025 E COLI	0 No/100ml	0
04/07/2025 E COLI	0 No/100ml	0
08/07/2025 E COLI	0 No/100ml	0
09/07/2025 E COLI	0 No/100ml	0
10/07/2025 E COLI	0 No/100ml	0
11/07/2025 E COLI	0 No/100ml	0
15/07/2025 E COLI	0 No/100ml	0
21/07/2025 E COLI	0 No/100ml	0

23/07/2025 E COLI	0 No/100ml	0
24/07/2025 E COLI	0 No/100ml	0
25/07/2025 E COLI	0 No/100ml	0
29/07/2025 E COLI	0 No/100ml	0
30/07/2025 E COLI	0 No/100ml	0
01/08/2025 E COLI	0 No/100ml	0
07/08/2025 E COLI	0 No/100ml	0
08/08/2025 E COLI	0 No/100ml	0
13/08/2025 E COLI	0 No/100ml	0
28/08/2025 E COLI	0 No/100ml	0
03/09/2025 E COLI	0 No/100ml	0
05/09/2025 E COLI	0 No/100ml	0
06/09/2025 E COLI	0 No/100ml	0
10/09/2025 E COLI	0 No/100ml	0
12/09/2025 E COLI	0 No/100ml	0
16/09/2025 E COLI	0 No/100ml	0
17/09/2025 E COLI	0 No/100ml	0
29/09/2025 E COLI	0 No/100ml	0
30/09/2025 E COLI	0 No/100ml	0
01/10/2025 E COLI	0 No/100ml	0
03/10/2025 E COLI	0 No/100ml	0
05/10/2025 E COLI	0 No/100ml	0
06/10/2025 E COLI	0 No/100ml	0
08/10/2025 E COLI	0 No/100ml	0
10/10/2025 E COLI	0 No/100ml	0
14/10/2025 E COLI	0 No/100ml	0
15/10/2025 E COLI	0 No/100ml	0
18/10/2025 E COLI	0 No/100ml	0
20/10/2025 E COLI	0 No/100ml	0
22/10/2025 E COLI	0 No/100ml	0
23/10/2025 E COLI	0 No/100ml	0
24/10/2025 E COLI	0 No/100ml	0
27/10/2025 E COLI	0 No/100ml	0
28/10/2025 E COLI	0 No/100ml	0
29/10/2025 E COLI	0 No/100ml	0
31/10/2025 E COLI	0 No/100ml	0
03/11/2025 E COLI	0 No/100ml	0
05/11/2025 E COLI	0 No/100ml	0
08/11/2025 E COLI	0 No/100ml	0
10/11/2025 E COLI	0 No/100ml	0
12/11/2025 E COLI	0 No/100ml	0
17/11/2025 E COLI	0 No/100ml	0
18/11/2025 E COLI	0 No/100ml	0
19/11/2025 E COLI	0 No/100ml	0
20/11/2025 E COLI	0 No/100ml	0
24/11/2025 E COLI	0 No/100ml	0
26/11/2025 E COLI	0 No/100ml	0
27/11/2025 E COLI	0 No/100ml	0

02/12/2025 E COLI	0 No/100ml	0
03/12/2025 E COLI	0 No/100ml	0
05/12/2025 E COLI	0 No/100ml	0
09/12/2025 E COLI	0 No/100ml	0
11/12/2025 E COLI	0 No/100ml	0
12/12/2025 E COLI	0 No/100ml	0
15/12/2025 E COLI	0 No/100ml	0
16/12/2025 E COLI	0 No/100ml	0
18/12/2025 E COLI	0 No/100ml	0
19/12/2025 E COLI	0 No/100ml	0
22/12/2025 E COLI	0 No/100ml	0
06/01/2026 E COLI	0 No/100ml	0
08/01/2026 E COLI	0 No/100ml	0
09/01/2026 E COLI	0 No/100ml	0
13/01/2026 E COLI	0 No/100ml	0
14/01/2026 E COLI	0 No/100ml	0
15/01/2026 E COLI	0 No/100ml	0
19/01/2026 E COLI	0 No/100ml	0
20/01/2026 E COLI	0 No/100ml	0
21/01/2026 E COLI	0 No/100ml	0
27/01/2026 E COLI	0 No/100ml	0
28/01/2026 E COLI	0 No/100ml	0
29/01/2026 E COLI	0 No/100ml	0
30/01/2026 E COLI	0 No/100ml	0
02/02/2026 E COLI	0 No/100ml	0
05/02/2026 E COLI	0 No/100ml	0
09/02/2026 E COLI	0 No/100ml	0
10/02/2026 E COLI	0 No/100ml	0
11/02/2026 E COLI	0 No/100ml	0
13/02/2026 E COLI	0 No/100ml	0
17/02/2026 E COLI	0 No/100ml	0
21/05/2021 ENTEROCOCCI	0 No/100ml	0
07/06/2021 ENTEROCOCCI	0 No/100ml	0
22/07/2021 ENTEROCOCCI	0 No/100ml	0
23/07/2021 ENTEROCOCCI	0 No/100ml	0
08/08/2021 ENTEROCOCCI	0 No/100ml	0
05/10/2021 ENTEROCOCCI	0 No/100ml	0
05/11/2021 ENTEROCOCCI	0 No/100ml	0
21/12/2021 ENTEROCOCCI	0 No/100ml	0
09/02/2022 ENTEROCOCCI	0 No/100ml	0
18/02/2022 ENTEROCOCCI	0 No/100ml	0
22/03/2022 ENTEROCOCCI	0 No/100ml	0
20/04/2022 ENTEROCOCCI	0 No/100ml	0
01/06/2022 ENTEROCOCCI	0 No/100ml	0
27/07/2022 ENTEROCOCCI	0 No/100ml	0
14/11/2022 ENTEROCOCCI	0 No/100ml	0
14/12/2022 ENTEROCOCCI	0 No/100ml	0
16/12/2022 ENTEROCOCCI	0 No/100ml	0

01/02/2023	ENTEROCOCCI	0 No/100ml	0
31/03/2023	ENTEROCOCCI	0 No/100ml	0
11/04/2023	ENTEROCOCCI	0 No/100ml	0
19/05/2023	ENTEROCOCCI	0 No/100ml	0
14/07/2023	ENTEROCOCCI	0 No/100ml	0
22/09/2023	ENTEROCOCCI	0 No/100ml	0
14/11/2023	ENTEROCOCCI	0 No/100ml	0
17/11/2023	ENTEROCOCCI	0 No/100ml	0
04/12/2023	ENTEROCOCCI	0 No/100ml	0
05/01/2024	ENTEROCOCCI	0 No/100ml	0
09/01/2024	ENTEROCOCCI	0 No/100ml	0
08/03/2024	ENTEROCOCCI	0 No/100ml	0
19/04/2024	ENTEROCOCCI	0 No/100ml	0
19/07/2024	ENTEROCOCCI	0 No/100ml	0
31/07/2024	ENTEROCOCCI	0 No/100ml	0
02/10/2024	ENTEROCOCCI	0 No/100ml	0
09/10/2024	ENTEROCOCCI	0 No/100ml	0
13/11/2024	ENTEROCOCCI	0 No/100ml	0
12/02/2025	ENTEROCOCCI	0 No/100ml	0
21/03/2025	ENTEROCOCCI	0 No/100ml	0
22/04/2025	ENTEROCOCCI	0 No/100ml	0
17/05/2025	ENTEROCOCCI	0 No/100ml	0
01/08/2025	ENTEROCOCCI	0 No/100ml	0
05/09/2025	ENTEROCOCCI	0 No/100ml	0
28/10/2025	ENTEROCOCCI	0 No/100ml	0
03/12/2025	ENTEROCOCCI	0 No/100ml	0
11/02/2026	ENTEROCOCCI	0 No/100ml	0
03/03/2021	HARDNESS TOTAL	36 mg/l	No regulatory limit
20/03/2021	HARDNESS TOTAL	34.1 mg/l	No regulatory limit
26/03/2021	HARDNESS TOTAL	35.1 mg/l	No regulatory limit
30/03/2021	HARDNESS TOTAL	34.8 mg/l	No regulatory limit
31/03/2021	HARDNESS TOTAL	35.6 mg/l	No regulatory limit
08/04/2021	HARDNESS TOTAL	37 mg/l	No regulatory limit
09/04/2021	HARDNESS TOTAL	26 mg/l	No regulatory limit
10/04/2021	HARDNESS TOTAL	35.8 mg/l	No regulatory limit
23/04/2021	HARDNESS TOTAL	31.4 mg/l	No regulatory limit
11/05/2021	HARDNESS TOTAL	39 mg/l	No regulatory limit
20/05/2021	HARDNESS TOTAL	30.6 mg/l	No regulatory limit
22/05/2021	HARDNESS TOTAL	41.2 mg/l	No regulatory limit
25/05/2021	HARDNESS TOTAL	28.3 mg/l	No regulatory limit
27/05/2021	HARDNESS TOTAL	38.1 mg/l	No regulatory limit
28/05/2021	HARDNESS TOTAL	40.5 mg/l	No regulatory limit
04/06/2021	HARDNESS TOTAL	39.6 mg/l	No regulatory limit
07/06/2021	HARDNESS TOTAL	41.2 mg/l	No regulatory limit
09/06/2021	HARDNESS TOTAL	39.3 mg/l	No regulatory limit
15/06/2021	HARDNESS TOTAL	41.6 mg/l	No regulatory limit
25/06/2021	HARDNESS TOTAL	43 mg/l	No regulatory limit
30/06/2021	HARDNESS TOTAL	42.1 mg/l	No regulatory limit

06/07/2021	HARDNESS TOTAL	41.8 mg/l	No regulatory limit
03/08/2021	HARDNESS TOTAL	44.5 mg/l	No regulatory limit
07/08/2021	HARDNESS TOTAL	45.3 mg/l	No regulatory limit
08/08/2021	HARDNESS TOTAL	46.3 mg/l	No regulatory limit
27/08/2021	HARDNESS TOTAL	44 mg/l	No regulatory limit
01/09/2021	HARDNESS TOTAL	47.3 mg/l	No regulatory limit
09/09/2021	HARDNESS TOTAL	47.3 mg/l	No regulatory limit
24/09/2021	HARDNESS TOTAL	48.8 mg/l	No regulatory limit
28/09/2021	HARDNESS TOTAL	49.2 mg/l	No regulatory limit
30/09/2021	HARDNESS TOTAL	50.7 mg/l	No regulatory limit
04/10/2021	HARDNESS TOTAL	51.1 mg/l	No regulatory limit
07/10/2021	HARDNESS TOTAL	48 mg/l	No regulatory limit
17/10/2021	HARDNESS TOTAL	33.8 mg/l	No regulatory limit
20/10/2021	HARDNESS TOTAL	49.2 mg/l	No regulatory limit
21/10/2021	HARDNESS TOTAL	49.2 mg/l	No regulatory limit
26/10/2021	HARDNESS TOTAL	48.4 mg/l	No regulatory limit
03/11/2021	HARDNESS TOTAL	43.5 mg/l	No regulatory limit
05/11/2021	HARDNESS TOTAL	45.1 mg/l	No regulatory limit
13/11/2021	HARDNESS TOTAL	47.9 mg/l	No regulatory limit
18/11/2021	HARDNESS TOTAL	43.9 mg/l	No regulatory limit
25/11/2021	HARDNESS TOTAL	34.7 mg/l	No regulatory limit
29/11/2021	HARDNESS TOTAL	44.3 mg/l	No regulatory limit
06/12/2021	HARDNESS TOTAL	43.6 mg/l	No regulatory limit
07/12/2021	HARDNESS TOTAL	45 mg/l	No regulatory limit
09/12/2021	HARDNESS TOTAL	41.1 mg/l	No regulatory limit
09/12/2021	HARDNESS TOTAL	45.1 mg/l	No regulatory limit
14/12/2021	HARDNESS TOTAL	39.4 mg/l	No regulatory limit
15/12/2021	HARDNESS TOTAL	41.1 mg/l	No regulatory limit
16/12/2021	HARDNESS TOTAL	41.2 mg/l	No regulatory limit
21/12/2021	HARDNESS TOTAL	41 mg/l	No regulatory limit
22/12/2021	HARDNESS TOTAL	40.5 mg/l	No regulatory limit
05/01/2022	HARDNESS TOTAL	40.6 mg/l	No regulatory limit
14/01/2022	HARDNESS TOTAL	40.3 mg/l	No regulatory limit
27/01/2022	HARDNESS TOTAL	41.8 mg/l	No regulatory limit
31/01/2022	HARDNESS TOTAL	41.2 mg/l	No regulatory limit
01/02/2022	HARDNESS TOTAL	46.3 mg/l	No regulatory limit
09/02/2022	HARDNESS TOTAL	40.1 mg/l	No regulatory limit
21/02/2022	HARDNESS TOTAL	37.1 mg/l	No regulatory limit
22/02/2022	HARDNESS TOTAL	35.9 mg/l	No regulatory limit
01/03/2022	HARDNESS TOTAL	34.8 mg/l	No regulatory limit
04/03/2022	HARDNESS TOTAL	24.2 mg/l	No regulatory limit
16/03/2022	HARDNESS TOTAL	35.1 mg/l	No regulatory limit
22/03/2022	HARDNESS TOTAL	38.1 mg/l	No regulatory limit
24/03/2022	HARDNESS TOTAL	23.8 mg/l	No regulatory limit
30/03/2022	HARDNESS TOTAL	34.7 mg/l	No regulatory limit
05/04/2022	HARDNESS TOTAL	32.9 mg/l	No regulatory limit
11/04/2022	HARDNESS TOTAL	35.8 mg/l	No regulatory limit
14/04/2022	HARDNESS TOTAL	36.5 mg/l	No regulatory limit

19/04/2022	HARDNESS TOTAL	36.5 mg/l	No regulatory limit
20/04/2022	HARDNESS TOTAL	35.4 mg/l	No regulatory limit
28/04/2022	HARDNESS TOTAL	38.1 mg/l	No regulatory limit
03/05/2022	HARDNESS TOTAL	38.7 mg/l	No regulatory limit
10/05/2022	HARDNESS TOTAL	37.9 mg/l	No regulatory limit
27/05/2022	HARDNESS TOTAL	40.5 mg/l	No regulatory limit
05/06/2022	HARDNESS TOTAL	40.6 mg/l	No regulatory limit
09/06/2022	HARDNESS TOTAL	40.7 mg/l	No regulatory limit
13/06/2022	HARDNESS TOTAL	41.6 mg/l	No regulatory limit
15/06/2022	HARDNESS TOTAL	45.4 mg/l	No regulatory limit
17/06/2022	HARDNESS TOTAL	42.9 mg/l	No regulatory limit
21/06/2022	HARDNESS TOTAL	44.2 mg/l	No regulatory limit
01/07/2022	HARDNESS TOTAL	48.5 mg/l	No regulatory limit
07/07/2022	HARDNESS TOTAL	46.3 mg/l	No regulatory limit
20/07/2022	HARDNESS TOTAL	49.2 mg/l	No regulatory limit
27/07/2022	HARDNESS TOTAL	47.5 mg/l	No regulatory limit
09/08/2022	HARDNESS TOTAL	49.3 mg/l	No regulatory limit
11/08/2022	HARDNESS TOTAL	50 mg/l	No regulatory limit
19/08/2022	HARDNESS TOTAL	31.7 mg/l	No regulatory limit
27/08/2022	HARDNESS TOTAL	36.1 mg/l	No regulatory limit
07/09/2022	HARDNESS TOTAL	52 mg/l	No regulatory limit
08/09/2022	HARDNESS TOTAL	42.9 mg/l	No regulatory limit
15/09/2022	HARDNESS TOTAL	45.8 mg/l	No regulatory limit
29/09/2022	HARDNESS TOTAL	46.9 mg/l	No regulatory limit
04/10/2022	HARDNESS TOTAL	41.2 mg/l	No regulatory limit
17/10/2022	HARDNESS TOTAL	44.4 mg/l	No regulatory limit
03/11/2022	HARDNESS TOTAL	29.4 mg/l	No regulatory limit
18/11/2022	HARDNESS TOTAL	33.5 mg/l	No regulatory limit
22/11/2022	HARDNESS TOTAL	37.6 mg/l	No regulatory limit
29/11/2022	HARDNESS TOTAL	35.9 mg/l	No regulatory limit
30/11/2022	HARDNESS TOTAL	34.3 mg/l	No regulatory limit
06/12/2022	HARDNESS TOTAL	37.8 mg/l	No regulatory limit
12/12/2022	HARDNESS TOTAL	37.8 mg/l	No regulatory limit
14/12/2022	HARDNESS TOTAL	43 mg/l	No regulatory limit
16/12/2022	HARDNESS TOTAL	40.9 mg/l	No regulatory limit
10/01/2023	HARDNESS TOTAL	40.5 mg/l	No regulatory limit
17/01/2023	HARDNESS TOTAL	34.7 mg/l	No regulatory limit
24/01/2023	HARDNESS TOTAL	37.3 mg/l	No regulatory limit
10/02/2023	HARDNESS TOTAL	39 mg/l	No regulatory limit
20/02/2023	HARDNESS TOTAL	38.7 mg/l	No regulatory limit
22/02/2023	HARDNESS TOTAL	38.3 mg/l	No regulatory limit
28/02/2023	HARDNESS TOTAL	38 mg/l	No regulatory limit
01/03/2023	HARDNESS TOTAL	37.7 mg/l	No regulatory limit
08/03/2023	HARDNESS TOTAL	38.4 mg/l	No regulatory limit
14/03/2023	HARDNESS TOTAL	39.7 mg/l	No regulatory limit
22/03/2023	HARDNESS TOTAL	38.2 mg/l	No regulatory limit
31/03/2023	HARDNESS TOTAL	37.2 mg/l	No regulatory limit
05/04/2023	HARDNESS TOTAL	37.7 mg/l	No regulatory limit

11/04/2023	HARDNESS TOTAL	36.2 mg/l	No regulatory limit
21/04/2023	HARDNESS TOTAL	39.2 mg/l	No regulatory limit
25/04/2023	HARDNESS TOTAL	36.5 mg/l	No regulatory limit
05/05/2023	HARDNESS TOTAL	39.4 mg/l	No regulatory limit
10/05/2023	HARDNESS TOTAL	39.3 mg/l	No regulatory limit
13/05/2023	HARDNESS TOTAL	38.6 mg/l	No regulatory limit
20/05/2023	HARDNESS TOTAL	40.5 mg/l	No regulatory limit
30/05/2023	HARDNESS TOTAL	40.8 mg/l	No regulatory limit
07/06/2023	HARDNESS TOTAL	42 mg/l	No regulatory limit
14/06/2023	HARDNESS TOTAL	44.6 mg/l	No regulatory limit
28/06/2023	HARDNESS TOTAL	46.4 mg/l	No regulatory limit
05/07/2023	HARDNESS TOTAL	47.2 mg/l	No regulatory limit
11/07/2023	HARDNESS TOTAL	45.9 mg/l	No regulatory limit
12/07/2023	HARDNESS TOTAL	50.5 mg/l	No regulatory limit
17/07/2023	HARDNESS TOTAL	37.1 mg/l	No regulatory limit
28/07/2023	HARDNESS TOTAL	42.9 mg/l	No regulatory limit
31/07/2023	HARDNESS TOTAL	40.7 mg/l	No regulatory limit
07/08/2023	HARDNESS TOTAL	41 mg/l	No regulatory limit
10/08/2023	HARDNESS TOTAL	40.9 mg/l	No regulatory limit
24/08/2023	HARDNESS TOTAL	45.9 mg/l	No regulatory limit
02/09/2023	HARDNESS TOTAL	43.5 mg/l	No regulatory limit
04/09/2023	HARDNESS TOTAL	44.2 mg/l	No regulatory limit
14/09/2023	HARDNESS TOTAL	44.7 mg/l	No regulatory limit
22/09/2023	HARDNESS TOTAL	45 mg/l	No regulatory limit
04/10/2023	HARDNESS TOTAL	41.4 mg/l	No regulatory limit
14/10/2023	HARDNESS TOTAL	39.8 mg/l	No regulatory limit
20/10/2023	HARDNESS TOTAL	27.1 mg/l	No regulatory limit
04/11/2023	HARDNESS TOTAL	24 mg/l	No regulatory limit
06/11/2023	HARDNESS TOTAL	24.2 mg/l	No regulatory limit
14/11/2023	HARDNESS TOTAL	25.5 mg/l	No regulatory limit
14/11/2023	HARDNESS TOTAL	39.2 mg/l	No regulatory limit
15/11/2023	HARDNESS TOTAL	39.9 mg/l	No regulatory limit
16/11/2023	HARDNESS TOTAL	38.8 mg/l	No regulatory limit
17/11/2023	HARDNESS TOTAL	40.7 mg/l	No regulatory limit
23/11/2023	HARDNESS TOTAL	35.8 mg/l	No regulatory limit
04/12/2023	HARDNESS TOTAL	30.7 mg/l	No regulatory limit
05/12/2023	HARDNESS TOTAL	37.5 mg/l	No regulatory limit
15/12/2023	HARDNESS TOTAL	35.9 mg/l	No regulatory limit
18/12/2023	HARDNESS TOTAL	36.8 mg/l	No regulatory limit
19/12/2023	HARDNESS TOTAL	34.9 mg/l	No regulatory limit
22/12/2023	HARDNESS TOTAL	34.6 mg/l	No regulatory limit
06/01/2024	HARDNESS TOTAL	31.8 mg/l	No regulatory limit
08/01/2024	HARDNESS TOTAL	34 mg/l	No regulatory limit
11/01/2024	HARDNESS TOTAL	32.9 mg/l	No regulatory limit
15/01/2024	HARDNESS TOTAL	31.7 mg/l	No regulatory limit
19/01/2024	HARDNESS TOTAL	36.2 mg/l	No regulatory limit
27/01/2024	HARDNESS TOTAL	31.9 mg/l	No regulatory limit
01/02/2024	HARDNESS TOTAL	32.1 mg/l	No regulatory limit

06/02/2024	HARDNESS TOTAL	33.8 mg/l	No regulatory limit
12/02/2024	HARDNESS TOTAL	33.1 mg/l	No regulatory limit
19/02/2024	HARDNESS TOTAL	34.5 mg/l	No regulatory limit
07/03/2024	HARDNESS TOTAL	32.6 mg/l	No regulatory limit
13/03/2024	HARDNESS TOTAL	32.7 mg/l	No regulatory limit
15/03/2024	HARDNESS TOTAL	33.1 mg/l	No regulatory limit
20/03/2024	HARDNESS TOTAL	32.7 mg/l	No regulatory limit
26/03/2024	HARDNESS TOTAL	32 mg/l	No regulatory limit
04/04/2024	HARDNESS TOTAL	34.1 mg/l	No regulatory limit
11/04/2024	HARDNESS TOTAL	31.3 mg/l	No regulatory limit
19/04/2024	HARDNESS TOTAL	32.2 mg/l	No regulatory limit
26/04/2024	HARDNESS TOTAL	33.9 mg/l	No regulatory limit
01/05/2024	HARDNESS TOTAL	32.9 mg/l	No regulatory limit
09/05/2024	HARDNESS TOTAL	35.6 mg/l	No regulatory limit
13/05/2024	HARDNESS TOTAL	34.2 mg/l	No regulatory limit
24/05/2024	HARDNESS TOTAL	33.9 mg/l	No regulatory limit
28/05/2024	HARDNESS TOTAL	35.2 mg/l	No regulatory limit
07/06/2024	HARDNESS TOTAL	34.9 mg/l	No regulatory limit
13/06/2024	HARDNESS TOTAL	35.6 mg/l	No regulatory limit
18/06/2024	HARDNESS TOTAL	34.8 mg/l	No regulatory limit
25/06/2024	HARDNESS TOTAL	35.2 mg/l	No regulatory limit
02/07/2024	HARDNESS TOTAL	34.2 mg/l	No regulatory limit
17/07/2024	HARDNESS TOTAL	40.7 mg/l	No regulatory limit
24/07/2024	HARDNESS TOTAL	42.3 mg/l	No regulatory limit
26/07/2024	HARDNESS TOTAL	41.7 mg/l	No regulatory limit
07/08/2024	HARDNESS TOTAL	42.5 mg/l	No regulatory limit
09/08/2024	HARDNESS TOTAL	42.4 mg/l	No regulatory limit
16/08/2024	HARDNESS TOTAL	43.9 mg/l	No regulatory limit
29/08/2024	HARDNESS TOTAL	49.5 mg/l	No regulatory limit
30/08/2024	HARDNESS TOTAL	45.5 mg/l	No regulatory limit
03/09/2024	HARDNESS TOTAL	47.7 mg/l	No regulatory limit
04/09/2024	HARDNESS TOTAL	49.8 mg/l	No regulatory limit
17/09/2024	HARDNESS TOTAL	49.6 mg/l	No regulatory limit
27/09/2024	HARDNESS TOTAL	49.4 mg/l	No regulatory limit
10/10/2024	HARDNESS TOTAL	48.3 mg/l	No regulatory limit
16/10/2024	HARDNESS TOTAL	48.4 mg/l	No regulatory limit
21/10/2024	HARDNESS TOTAL	49.7 mg/l	No regulatory limit
25/10/2024	HARDNESS TOTAL	27.1 mg/l	No regulatory limit
07/11/2024	HARDNESS TOTAL	51.2 mg/l	No regulatory limit
15/11/2024	HARDNESS TOTAL	52.6 mg/l	No regulatory limit
18/11/2024	HARDNESS TOTAL	51.2 mg/l	No regulatory limit
25/11/2024	HARDNESS TOTAL	47.3 mg/l	No regulatory limit
28/11/2024	HARDNESS TOTAL	28.3 mg/l	No regulatory limit
03/12/2024	HARDNESS TOTAL	41.7 mg/l	No regulatory limit
10/12/2024	HARDNESS TOTAL	27.6 mg/l	No regulatory limit
21/12/2024	HARDNESS TOTAL	40.4 mg/l	No regulatory limit
02/01/2025	HARDNESS TOTAL	39.6 mg/l	No regulatory limit
22/01/2025	HARDNESS TOTAL	41.4 mg/l	No regulatory limit

29/01/2025	HARDNESS TOTAL	38.2 mg/l	No regulatory limit
30/01/2025	HARDNESS TOTAL	38.3 mg/l	No regulatory limit
04/02/2025	HARDNESS TOTAL	37.1 mg/l	No regulatory limit
14/02/2025	HARDNESS TOTAL	38.7 mg/l	No regulatory limit
27/02/2025	HARDNESS TOTAL	39.5 mg/l	No regulatory limit
17/03/2025	HARDNESS TOTAL	40.3 mg/l	No regulatory limit
21/03/2025	HARDNESS TOTAL	41.6 mg/l	No regulatory limit
25/03/2025	HARDNESS TOTAL	41.6 mg/l	No regulatory limit
05/04/2025	HARDNESS TOTAL	43.7 mg/l	No regulatory limit
10/04/2025	HARDNESS TOTAL	42.5 mg/l	No regulatory limit
16/04/2025	HARDNESS TOTAL	43.8 mg/l	No regulatory limit
24/04/2025	HARDNESS TOTAL	43.7 mg/l	No regulatory limit
29/04/2025	HARDNESS TOTAL	39 mg/l	No regulatory limit
07/05/2025	HARDNESS TOTAL	51.5 mg/l	No regulatory limit
14/05/2025	HARDNESS TOTAL	41.3 mg/l	No regulatory limit
17/05/2025	HARDNESS TOTAL	42.7 mg/l	No regulatory limit
05/06/2025	HARDNESS TOTAL	39.4 mg/l	No regulatory limit
13/06/2025	HARDNESS TOTAL	38.8 mg/l	No regulatory limit
14/06/2025	HARDNESS TOTAL	40.3 mg/l	No regulatory limit
15/06/2025	HARDNESS TOTAL	38.8 mg/l	No regulatory limit
17/06/2025	HARDNESS TOTAL	43.3 mg/l	No regulatory limit
18/06/2025	HARDNESS TOTAL	41.9 mg/l	No regulatory limit
20/06/2025	HARDNESS TOTAL	40.9 mg/l	No regulatory limit
27/06/2025	HARDNESS TOTAL	41.6 mg/l	No regulatory limit
04/07/2025	HARDNESS TOTAL	41 mg/l	No regulatory limit
09/07/2025	HARDNESS TOTAL	37.8 mg/l	No regulatory limit
10/07/2025	HARDNESS TOTAL	42.8 mg/l	No regulatory limit
23/07/2025	HARDNESS TOTAL	44.9 mg/l	No regulatory limit
01/08/2025	HARDNESS TOTAL	47 mg/l	No regulatory limit
07/08/2025	HARDNESS TOTAL	48.3 mg/l	No regulatory limit
08/08/2025	HARDNESS TOTAL	48 mg/l	No regulatory limit
03/09/2025	HARDNESS TOTAL	46.2 mg/l	No regulatory limit
06/09/2025	HARDNESS TOTAL	55.7 mg/l	No regulatory limit
12/09/2025	HARDNESS TOTAL	42.1 mg/l	No regulatory limit
01/10/2025	HARDNESS TOTAL	30.8 mg/l	No regulatory limit
06/10/2025	HARDNESS TOTAL	38.7 mg/l	No regulatory limit
08/10/2025	HARDNESS TOTAL	29.7 mg/l	No regulatory limit
14/10/2025	HARDNESS TOTAL	30.1 mg/l	No regulatory limit
15/10/2025	HARDNESS TOTAL	40.7 mg/l	No regulatory limit
22/10/2025	HARDNESS TOTAL	29.6 mg/l	No regulatory limit
23/10/2025	HARDNESS TOTAL	39.9 mg/l	No regulatory limit
24/10/2025	HARDNESS TOTAL	44.5 mg/l	No regulatory limit
28/10/2025	HARDNESS TOTAL	40.3 mg/l	No regulatory limit
05/11/2025	HARDNESS TOTAL	36.4 mg/l	No regulatory limit
12/11/2025	HARDNESS TOTAL	39.6 mg/l	No regulatory limit
18/11/2025	HARDNESS TOTAL	25.2 mg/l	No regulatory limit
24/11/2025	HARDNESS TOTAL	32.4 mg/l	No regulatory limit
03/12/2025	HARDNESS TOTAL	40.5 mg/l	No regulatory limit

09/12/2025	HARDNESS TOTAL	26.7 mg/l	No regulatory limit
15/12/2025	HARDNESS TOTAL	36.3 mg/l	No regulatory limit
09/01/2026	HARDNESS TOTAL	38.3 mg/l	No regulatory limit
15/01/2026	HARDNESS TOTAL	39.9 mg/l	No regulatory limit
20/01/2026	HARDNESS TOTAL	39.7 mg/l	No regulatory limit
29/01/2026	HARDNESS TOTAL	37.2 mg/l	No regulatory limit
30/01/2026	HARDNESS TOTAL	37 mg/l	No regulatory limit
02/02/2026	HARDNESS TOTAL	37.9 mg/l	No regulatory limit
11/02/2026	HARDNESS TOTAL	37.9 mg/l	No regulatory limit
17/02/2026	HARDNESS TOTAL	37.2 mg/l	No regulatory limit
03/03/2021	IRON	12.2 µg/l	200
20/03/2021	IRON	4.4 µg/l	200
26/03/2021	IRON	10.5 µg/l	200
30/03/2021	IRON	12.4 µg/l	200
31/03/2021	IRON	3.6 µg/l	200
08/04/2021	IRON	4.04 µg/l	200
09/04/2021	IRON	14.5 µg/l	200
10/04/2021	IRON	15.1 µg/l	200
23/04/2021	IRON	8.5 µg/l	200
12/05/2021	IRON	< 2.1 µg/l	200
28/05/2021	IRON	11.9 µg/l	200
30/05/2021	IRON	12.1 µg/l	200
02/06/2021	IRON	7.5 µg/l	200
07/06/2021	IRON	6.6 µg/l	200
09/06/2021	IRON	99.1 µg/l	200
25/06/2021	IRON	6 µg/l	200
29/06/2021	IRON	14.8 µg/l	200
30/06/2021	IRON	76.3 µg/l	200
02/07/2021	IRON	8.2 µg/l	200
08/07/2021	IRON	5.8 µg/l	200
12/07/2021	IRON	4.3 µg/l	200
03/08/2021	IRON	3.2 µg/l	200
06/08/2021	IRON	4.8 µg/l	200
08/08/2021	IRON	4.4 µg/l	200
27/08/2021	IRON	10.5 µg/l	200
01/09/2021	IRON	7.8 µg/l	200
09/09/2021	IRON	3.1 µg/l	200
24/09/2021	IRON	9.7 µg/l	200
28/09/2021	IRON	11.5 µg/l	200
30/09/2021	IRON	6.4 µg/l	200
04/10/2021	IRON	7.9 µg/l	200
07/10/2021	IRON	5.7 µg/l	200
17/10/2021	IRON	7.3 µg/l	200
21/10/2021	IRON	22.2 µg/l	200
26/10/2021	IRON	4.4 µg/l	200
03/11/2021	IRON	5.4 µg/l	200
05/11/2021	IRON	7.5 µg/l	200
13/11/2021	IRON	16 µg/l	200

16/11/2021	IRON		5.5 µg/l	200
18/11/2021	IRON		6.2 µg/l	200
23/11/2021	IRON		4.9 µg/l	200
25/11/2021	IRON		11.6 µg/l	200
29/11/2021	IRON		5.6 µg/l	200
06/12/2021	IRON		5.6 µg/l	200
07/12/2021	IRON		98.2 µg/l	200
09/12/2021	IRON		6.1 µg/l	200
09/12/2021	IRON		17.9 µg/l	200
14/12/2021	IRON		5.3 µg/l	200
15/12/2021	IRON		5.3 µg/l	200
16/12/2021	IRON		7.3 µg/l	200
18/12/2021	IRON		12.3 µg/l	200
21/12/2021	IRON		12.9 µg/l	200
22/12/2021	IRON		12.4 µg/l	200
05/01/2022	IRON		5.1 µg/l	200
14/01/2022	IRON		4.49 µg/l	200
27/01/2022	IRON		12.5 µg/l	200
31/01/2022	IRON		7.91 µg/l	200
01/02/2022	IRON		11.1 µg/l	200
09/02/2022	IRON		9.97 µg/l	200
21/02/2022	IRON		8.14 µg/l	200
22/02/2022	IRON		5.71 µg/l	200
01/03/2022	IRON		9.95 µg/l	200
04/03/2022	IRON		10.3 µg/l	200
16/03/2022	IRON		9 µg/l	200
22/03/2022	IRON		7.8 µg/l	200
24/03/2022	IRON		5 µg/l	200
30/03/2022	IRON		14 µg/l	200
05/04/2022	IRON		7.8 µg/l	200
11/04/2022	IRON	<	7 µg/l	200
14/04/2022	IRON	<	7 µg/l	200
19/04/2022	IRON	<	7 µg/l	200
20/04/2022	IRON		436 µg/l	200
28/04/2022	IRON	<	7 µg/l	200
03/05/2022	IRON	<	7 µg/l	200
10/05/2022	IRON	<	7 µg/l	200
27/05/2022	IRON		3.4 µg/l	200
05/06/2022	IRON		3.1 µg/l	200
09/06/2022	IRON		71 µg/l	200
13/06/2022	IRON		9 µg/l	200
15/06/2022	IRON	<	2.1 µg/l	200
17/06/2022	IRON		8 µg/l	200
21/06/2022	IRON	<	7 µg/l	200
01/07/2022	IRON	<	7 µg/l	200
07/07/2022	IRON		8 µg/l	200
20/07/2022	IRON		3.6 µg/l	200
27/07/2022	IRON	<	7 µg/l	200

09/08/2022	IRON		11 µg/l	200
11/08/2022	IRON	<	7 µg/l	200
19/08/2022	IRON	<	7 µg/l	200
27/08/2022	IRON		6.6 µg/l	200
07/09/2022	IRON		38 µg/l	200
08/09/2022	IRON	<	7 µg/l	200
15/09/2022	IRON		14 µg/l	200
29/09/2022	IRON		9 µg/l	200
04/10/2022	IRON		6.7 µg/l	200
17/10/2022	IRON		6.2 µg/l	200
03/11/2022	IRON	<	7 µg/l	200
18/11/2022	IRON		8 µg/l	200
22/11/2022	IRON		12 µg/l	200
29/11/2022	IRON	<	7 µg/l	200
30/11/2022	IRON		9 µg/l	200
06/12/2022	IRON		17 µg/l	200
12/12/2022	IRON		8 µg/l	200
14/12/2022	IRON		8 µg/l	200
16/12/2022	IRON		8 µg/l	200
10/01/2023	IRON		6.1 µg/l	200
17/01/2023	IRON	<	7 µg/l	200
24/01/2023	IRON	<	7 µg/l	200
10/02/2023	IRON		10 µg/l	200
20/02/2023	IRON		10 µg/l	200
22/02/2023	IRON		10 µg/l	200
28/02/2023	IRON	<	7 µg/l	200
01/03/2023	IRON	<	7 µg/l	200
08/03/2023	IRON	<	7 µg/l	200
14/03/2023	IRON	<	7 µg/l	200
22/03/2023	IRON		10 µg/l	200
31/03/2023	IRON		12 µg/l	200
05/04/2023	IRON		11 µg/l	200
06/04/2023	IRON		10 µg/l	200
11/04/2023	IRON		10 µg/l	200
21/04/2023	IRON	<	7 µg/l	200
25/04/2023	IRON		23 µg/l	200
05/05/2023	IRON	<	7 µg/l	200
10/05/2023	IRON		10 µg/l	200
13/05/2023	IRON	<	7 µg/l	200
20/05/2023	IRON		14.5 µg/l	200
30/05/2023	IRON		4.4 µg/l	200
07/06/2023	IRON	<	7 µg/l	200
14/06/2023	IRON		8 µg/l	200
28/06/2023	IRON		2.9 µg/l	200
05/07/2023	IRON	<	7 µg/l	200
11/07/2023	IRON		8 µg/l	200
12/07/2023	IRON	<	7 µg/l	200
17/07/2023	IRON	<	7 µg/l	200

28/07/2023	IRON		19 µg/l	200
31/07/2023	IRON	<	7 µg/l	200
07/08/2023	IRON		7 µg/l	200
10/08/2023	IRON		37 µg/l	200
24/08/2023	IRON		11.1 µg/l	200
02/09/2023	IRON	<	7 µg/l	200
04/09/2023	IRON	<	7 µg/l	200
14/09/2023	IRON		6.5 µg/l	200
22/09/2023	IRON		11 µg/l	200
04/10/2023	IRON		19 µg/l	200
14/10/2023	IRON	<	7 µg/l	200
20/10/2023	IRON		7 µg/l	200
04/11/2023	IRON	<	7 µg/l	200
06/11/2023	IRON	<	7 µg/l	200
14/11/2023	IRON		5.9 µg/l	200
15/11/2023	IRON		17 µg/l	200
16/11/2023	IRON		8 µg/l	200
17/11/2023	IRON		12 µg/l	200
23/11/2023	IRON	<	7 µg/l	200
04/12/2023	IRON		14 µg/l	200
15/12/2023	IRON		7.5 µg/l	200
18/12/2023	IRON		12.3 µg/l	200
19/12/2023	IRON		42 µg/l	200
21/12/2023	IRON		8 µg/l	200
22/12/2023	IRON		11 µg/l	200
06/01/2024	IRON	<	7 µg/l	200
08/01/2024	IRON		12 µg/l	200
11/01/2024	IRON		7 µg/l	200
15/01/2024	IRON	<	7 µg/l	200
19/01/2024	IRON		4.6 µg/l	200
27/01/2024	IRON	<	7 µg/l	200
01/02/2024	IRON	<	7 µg/l	200
06/02/2024	IRON		7 µg/l	200
12/02/2024	IRON		19.3 µg/l	200
19/02/2024	IRON		4 µg/l	200
07/03/2024	IRON		4.3 µg/l	200
13/03/2024	IRON	<	7 µg/l	200
15/03/2024	IRON		6.8 µg/l	200
20/03/2024	IRON		8 µg/l	200
26/03/2024	IRON		8 µg/l	200
04/04/2024	IRON		3.7 µg/l	200
11/04/2024	IRON	<	7 µg/l	200
19/04/2024	IRON	<	7 µg/l	200
26/04/2024	IRON	<	7 µg/l	200
01/05/2024	IRON		5.1 µg/l	200
09/05/2024	IRON		3.7 µg/l	200
13/05/2024	IRON		8.8 µg/l	200
24/05/2024	IRON		7 µg/l	200

28/05/2024	IRON	<	7 µg/l	200
07/06/2024	IRON	<	7 µg/l	200
13/06/2024	IRON		11 µg/l	200
18/06/2024	IRON	<	7 µg/l	200
25/06/2024	IRON	<	7 µg/l	200
02/07/2024	IRON		15 µg/l	200
17/07/2024	IRON		8 µg/l	200
24/07/2024	IRON	<	7 µg/l	200
26/07/2024	IRON		7 µg/l	200
07/08/2024	IRON		24.6 µg/l	200
09/08/2024	IRON	<	7 µg/l	200
16/08/2024	IRON	<	7 µg/l	200
29/08/2024	IRON		3.4 µg/l	200
30/08/2024	IRON	<	7 µg/l	200
03/09/2024	IRON	<	7 µg/l	200
04/09/2024	IRON	<	7 µg/l	200
17/09/2024	IRON	<	7 µg/l	200
27/09/2024	IRON		4.1 µg/l	200
10/10/2024	IRON	<	7 µg/l	200
16/10/2024	IRON		7 µg/l	200
21/10/2024	IRON		6.3 µg/l	200
25/10/2024	IRON	<	7 µg/l	200
07/11/2024	IRON		7 µg/l	200
15/11/2024	IRON		3.1 µg/l	200
18/11/2024	IRON		13 µg/l	200
25/11/2024	IRON	<	7 µg/l	200
28/11/2024	IRON		10.2 µg/l	200
03/12/2024	IRON	<	7 µg/l	200
10/12/2024	IRON		3.4 µg/l	200
21/12/2024	IRON	<	7 µg/l	200
02/01/2025	IRON		11 µg/l	200
22/01/2025	IRON	<	7 µg/l	200
29/01/2025	IRON		8.6 µg/l	200
30/01/2025	IRON		6 µg/l	200
04/02/2025	IRON	<	7 µg/l	200
14/02/2025	IRON		3.5 µg/l	200
27/02/2025	IRON		14.4 µg/l	200
17/03/2025	IRON		8 µg/l	200
21/03/2025	IRON		5.1 µg/l	200
25/03/2025	IRON	<	7 µg/l	200
05/04/2025	IRON		7 µg/l	200
10/04/2025	IRON	<	7 µg/l	200
16/04/2025	IRON		2.4 µg/l	200
24/04/2025	IRON	<	7 µg/l	200
29/04/2025	IRON	<	7 µg/l	200
07/05/2025	IRON		38 µg/l	200
14/05/2025	IRON		8 µg/l	200
17/05/2025	IRON	<	7 µg/l	200

05/06/2025	IRON		21 µg/l	200
13/06/2025	IRON		31 µg/l	200
14/06/2025	IRON	<	7 µg/l	200
15/06/2025	IRON	<	7 µg/l	200
17/06/2025	IRON	<	7 µg/l	200
18/06/2025	IRON		7 µg/l	200
20/06/2025	IRON		12 µg/l	200
27/06/2025	IRON		76.5 µg/l	200
04/07/2025	IRON	<	7 µg/l	200
09/07/2025	IRON	<	7 µg/l	200
10/07/2025	IRON	<	7 µg/l	200
23/07/2025	IRON		10 µg/l	200
01/08/2025	IRON	<	7 µg/l	200
07/08/2025	IRON	<	7 µg/l	200
08/08/2025	IRON		9 µg/l	200
03/09/2025	IRON	<	7 µg/l	200
06/09/2025	IRON		26 µg/l	200
12/09/2025	IRON		16 µg/l	200
01/10/2025	IRON		8.9 µg/l	200
06/10/2025	IRON		11.9 µg/l	200
08/10/2025	IRON	<	7 µg/l	200
14/10/2025	IRON		12 µg/l	200
15/10/2025	IRON		20 µg/l	200
22/10/2025	IRON		6.3 µg/l	200
23/10/2025	IRON		10 µg/l	200
24/10/2025	IRON		11 µg/l	200
28/10/2025	IRON		11.7 µg/l	200
05/11/2025	IRON		16 µg/l	200
12/11/2025	IRON		11.7 µg/l	200
18/11/2025	IRON	<	7 µg/l	200
24/11/2025	IRON		13 µg/l	200
03/12/2025	IRON		31.6 µg/l	200
09/12/2025	IRON		20 µg/l	200
15/12/2025	IRON		5.9 µg/l	200
09/01/2026	IRON	<	7 µg/l	200
15/01/2026	IRON		16 µg/l	200
20/01/2026	IRON		18 µg/l	200
29/01/2026	IRON		11 µg/l	200
30/01/2026	IRON		8 µg/l	200
02/02/2026	IRON	<	7 µg/l	200
11/02/2026	IRON		7 µg/l	200
17/02/2026	IRON	<	7 µg/l	200
21/05/2021	LEAD	<	0.55 µg/l	10
23/06/2021	LEAD	<	0.95 µg/l	10
30/06/2021	LEAD	<	0.55 µg/l	10
24/09/2021	LEAD	<	0.55 µg/l	10
29/09/2021	LEAD	<	0.55 µg/l	10
07/10/2021	LEAD	<	0.55 µg/l	10

26/10/2021	LEAD	<	0.55 µg/l	10
25/11/2021	LEAD	<	0.95 µg/l	10
24/01/2022	LEAD	<	0.95 µg/l	10
25/02/2022	LEAD	<	0.55 µg/l	10
11/04/2022	LEAD	<	0.55 µg/l	10
18/05/2022	LEAD	<	0.55 µg/l	10
07/06/2022	LEAD	<	0.55 µg/l	10
11/08/2022	LEAD	<	0.55 µg/l	10
27/08/2022	LEAD	<	0.55 µg/l	10
05/10/2022	LEAD	<	0.55 µg/l	10
24/01/2023	LEAD	<	0.55 µg/l	10
02/03/2023	LEAD	<	0.55 µg/l	10
05/04/2023	LEAD	<	0.55 µg/l	10
12/07/2023	LEAD	<	0.55 µg/l	10
31/07/2023	LEAD	<	0.55 µg/l	10
14/10/2023	LEAD	<	0.55 µg/l	10
10/11/2023	LEAD	<	0.55 µg/l	10
18/12/2023	LEAD	<	0.55 µg/l	10
19/12/2023	LEAD	<	0.55 µg/l	10
22/12/2023	LEAD	<	0.55 µg/l	10
05/01/2024	LEAD	<	0.55 µg/l	10
08/02/2024	LEAD	<	0.55 µg/l	10
22/02/2024	LEAD	<	0.55 µg/l	10
15/05/2024	LEAD	<	0.55 µg/l	10
14/06/2024	LEAD	<	0.55 µg/l	10
24/07/2024	LEAD	<	0.55 µg/l	10
06/09/2024	LEAD		2.58 µg/l	10
13/11/2024	LEAD	<	0.55 µg/l	10
15/11/2024	LEAD	<	0.55 µg/l	10
07/02/2025	LEAD	<	0.55 µg/l	10
29/03/2025	LEAD	<	0.55 µg/l	10
24/04/2025	LEAD	<	0.55 µg/l	10
27/06/2025	LEAD	<	0.55 µg/l	10
04/07/2025	LEAD	<	0.55 µg/l	10
10/10/2025	LEAD	<	0.55 µg/l	10
29/10/2025	LEAD	<	0.55 µg/l	10
19/12/2025	LEAD	<	0.55 µg/l	10
09/02/2026	LEAD	<	0.55 µg/l	10
03/03/2021	Magnesium		4.21 mg/l	No regulatory limit
20/03/2021	Magnesium		4.07 mg/l	No regulatory limit
26/03/2021	Magnesium		4.09 mg/l	No regulatory limit
30/03/2021	Magnesium		4.15 mg/l	No regulatory limit
31/03/2021	Magnesium		4.14 mg/l	No regulatory limit
08/04/2021	Magnesium		4.42 mg/l	No regulatory limit
09/04/2021	Magnesium		1.62 mg/l	No regulatory limit
10/04/2021	Magnesium		4.23 mg/l	No regulatory limit
23/04/2021	Magnesium		1.73 mg/l	No regulatory limit
08/05/2021	Magnesium		4.44 mg/l	No regulatory limit

10/05/2021	Magnesium	4.49 mg/l	No regulatory limit
20/05/2021	Magnesium	1.72 mg/l	No regulatory limit
22/05/2021	Magnesium	4.27 mg/l	No regulatory limit
25/05/2021	Magnesium	1.44 mg/l	No regulatory limit
29/05/2021	Magnesium	4.46 mg/l	No regulatory limit
02/06/2021	Magnesium	1.47 mg/l	No regulatory limit
07/06/2021	Magnesium	4.19 mg/l	No regulatory limit
08/06/2021	Magnesium	4.57 mg/l	No regulatory limit
01/07/2021	Magnesium	4.45 mg/l	No regulatory limit
08/07/2021	Magnesium	4.93 mg/l	No regulatory limit
12/07/2021	Magnesium	4.97 mg/l	No regulatory limit
21/07/2021	Magnesium	4.97 mg/l	No regulatory limit
22/07/2021	Magnesium	5.05 mg/l	No regulatory limit
03/08/2021	Magnesium	5.08 mg/l	No regulatory limit
06/08/2021	Magnesium	5.46 mg/l	No regulatory limit
27/08/2021	Magnesium	2.25 mg/l	No regulatory limit
01/09/2021	Magnesium	5.47 mg/l	No regulatory limit
09/09/2021	Magnesium	5.58 mg/l	No regulatory limit
24/09/2021	Magnesium	5.56 mg/l	No regulatory limit
28/09/2021	Magnesium	5.64 mg/l	No regulatory limit
30/09/2021	Magnesium	5.66 mg/l	No regulatory limit
04/10/2021	Magnesium	5.98 mg/l	No regulatory limit
17/10/2021	Magnesium	2.13 mg/l	No regulatory limit
21/10/2021	Magnesium	5.75 mg/l	No regulatory limit
26/10/2021	Magnesium	5.64 mg/l	No regulatory limit
03/11/2021	Magnesium	5.05 mg/l	No regulatory limit
05/11/2021	Magnesium	5.19 mg/l	No regulatory limit
13/11/2021	Magnesium	5.19 mg/l	No regulatory limit
18/11/2021	Magnesium	5.08 mg/l	No regulatory limit
23/11/2021	Magnesium	5.05 mg/l	No regulatory limit
25/11/2021	Magnesium	1.98 mg/l	No regulatory limit
29/11/2021	Magnesium	5.24 mg/l	No regulatory limit
06/12/2021	Magnesium	5.09 mg/l	No regulatory limit
09/12/2021	Magnesium	4.7 mg/l	No regulatory limit
09/12/2021	Magnesium	5.13 mg/l	No regulatory limit
14/12/2021	Magnesium	4.58 mg/l	No regulatory limit
15/12/2021	Magnesium	4.74 mg/l	No regulatory limit
18/12/2021	Magnesium	4.8 mg/l	No regulatory limit
21/12/2021	Magnesium	4.57 mg/l	No regulatory limit
22/12/2021	Magnesium	4.72 mg/l	No regulatory limit
22/12/2021	Magnesium	4.71 mg/l	No regulatory limit
23/12/2021	Magnesium	4.84 mg/l	No regulatory limit
05/01/2022	Magnesium	4.69 mg/l	No regulatory limit
14/01/2022	Magnesium	4.73 mg/l	No regulatory limit
27/01/2022	Magnesium	4.93 mg/l	No regulatory limit
31/01/2022	Magnesium	4.87 mg/l	No regulatory limit
01/02/2022	Magnesium	4.77 mg/l	No regulatory limit
09/02/2022	Magnesium	4.58 mg/l	No regulatory limit

21/02/2022	Magnesium	4.43 mg/l	No regulatory limit
22/02/2022	Magnesium	4.25 mg/l	No regulatory limit
01/03/2022	Magnesium	4.08 mg/l	No regulatory limit
04/03/2022	Magnesium	1.17 mg/l	No regulatory limit
16/03/2022	Magnesium	3.87 mg/l	No regulatory limit
22/03/2022	Magnesium	4.19 mg/l	No regulatory limit
24/03/2022	Magnesium	1.01 mg/l	No regulatory limit
30/03/2022	Magnesium	3.91 mg/l	No regulatory limit
05/04/2022	Magnesium	1.44 mg/l	No regulatory limit
11/04/2022	Magnesium	4.17 mg/l	No regulatory limit
14/04/2022	Magnesium	4.04 mg/l	No regulatory limit
19/04/2022	Magnesium	4.08 mg/l	No regulatory limit
20/04/2022	Magnesium	4 mg/l	No regulatory limit
28/04/2022	Magnesium	4.37 mg/l	No regulatory limit
03/05/2022	Magnesium	4.44 mg/l	No regulatory limit
10/05/2022	Magnesium	4.39 mg/l	No regulatory limit
27/05/2022	Magnesium	4.77 mg/l	No regulatory limit
05/06/2022	Magnesium	4.7 mg/l	No regulatory limit
09/06/2022	Magnesium	4.46 mg/l	No regulatory limit
13/06/2022	Magnesium	4.74 mg/l	No regulatory limit
15/06/2022	Magnesium	5.12 mg/l	No regulatory limit
17/06/2022	Magnesium	4.71 mg/l	No regulatory limit
21/06/2022	Magnesium	5.11 mg/l	No regulatory limit
01/07/2022	Magnesium	5.03 mg/l	No regulatory limit
07/07/2022	Magnesium	5.2 mg/l	No regulatory limit
20/07/2022	Magnesium	5.41 mg/l	No regulatory limit
27/07/2022	Magnesium	5.35 mg/l	No regulatory limit
09/08/2022	Magnesium	5.57 mg/l	No regulatory limit
11/08/2022	Magnesium	5.58 mg/l	No regulatory limit
19/08/2022	Magnesium	1.46 mg/l	No regulatory limit
27/08/2022	Magnesium	1.83 mg/l	No regulatory limit
07/09/2022	Magnesium	5.53 mg/l	No regulatory limit
08/09/2022	Magnesium	4.72 mg/l	No regulatory limit
15/09/2022	Magnesium	5.09 mg/l	No regulatory limit
29/09/2022	Magnesium	4.8 mg/l	No regulatory limit
04/10/2022	Magnesium	2.08 mg/l	No regulatory limit
17/10/2022	Magnesium	5.12 mg/l	No regulatory limit
03/11/2022	Magnesium	1.35 mg/l	No regulatory limit
18/11/2022	Magnesium	1.42 mg/l	No regulatory limit
22/11/2022	Magnesium	4.25 mg/l	No regulatory limit
29/11/2022	Magnesium	4.04 mg/l	No regulatory limit
30/11/2022	Magnesium	1.54 mg/l	No regulatory limit
06/12/2022	Magnesium	4.1 mg/l	No regulatory limit
12/12/2022	Magnesium	4.4 mg/l	No regulatory limit
14/12/2022	Magnesium	4.25 mg/l	No regulatory limit
16/12/2022	Magnesium	4.54 mg/l	No regulatory limit
10/01/2023	Magnesium	4.67 mg/l	No regulatory limit
17/01/2023	Magnesium	3.93 mg/l	No regulatory limit

24/01/2023	Magnesium	4.29 mg/l	No regulatory limit
10/02/2023	Magnesium	4.35 mg/l	No regulatory limit
20/02/2023	Magnesium	4.4 mg/l	No regulatory limit
22/02/2023	Magnesium	4.24 mg/l	No regulatory limit
28/02/2023	Magnesium	4.36 mg/l	No regulatory limit
01/03/2023	Magnesium	4.31 mg/l	No regulatory limit
08/03/2023	Magnesium	4.27 mg/l	No regulatory limit
14/03/2023	Magnesium	4.6 mg/l	No regulatory limit
22/03/2023	Magnesium	4.38 mg/l	No regulatory limit
31/03/2023	Magnesium	4.18 mg/l	No regulatory limit
05/04/2023	Magnesium	4.15 mg/l	No regulatory limit
11/04/2023	Magnesium	4 mg/l	No regulatory limit
21/04/2023	Magnesium	4.13 mg/l	No regulatory limit
25/04/2023	Magnesium	4.13 mg/l	No regulatory limit
05/05/2023	Magnesium	4.44 mg/l	No regulatory limit
10/05/2023	Magnesium	4.5 mg/l	No regulatory limit
13/05/2023	Magnesium	4.39 mg/l	No regulatory limit
20/05/2023	Magnesium	4.71 mg/l	No regulatory limit
30/05/2023	Magnesium	4.73 mg/l	No regulatory limit
07/06/2023	Magnesium	4.78 mg/l	No regulatory limit
14/06/2023	Magnesium	4.97 mg/l	No regulatory limit
28/06/2023	Magnesium	5.36 mg/l	No regulatory limit
05/07/2023	Magnesium	5.18 mg/l	No regulatory limit
11/07/2023	Magnesium	5.13 mg/l	No regulatory limit
12/07/2023	Magnesium	5.11 mg/l	No regulatory limit
17/07/2023	Magnesium	1.78 mg/l	No regulatory limit
28/07/2023	Magnesium	4.77 mg/l	No regulatory limit
31/07/2023	Magnesium	4.54 mg/l	No regulatory limit
07/08/2023	Magnesium	4.7 mg/l	No regulatory limit
10/08/2023	Magnesium	4.63 mg/l	No regulatory limit
24/08/2023	Magnesium	4.93 mg/l	No regulatory limit
02/09/2023	Magnesium	4.85 mg/l	No regulatory limit
04/09/2023	Magnesium	4.8 mg/l	No regulatory limit
14/09/2023	Magnesium	5.23 mg/l	No regulatory limit
22/09/2023	Magnesium	5.02 mg/l	No regulatory limit
04/10/2023	Magnesium	4.56 mg/l	No regulatory limit
14/10/2023	Magnesium	4.45 mg/l	No regulatory limit
20/10/2023	Magnesium	1.53 mg/l	No regulatory limit
04/11/2023	Magnesium	1.07 mg/l	No regulatory limit
06/11/2023	Magnesium	1.09 mg/l	No regulatory limit
14/11/2023	Magnesium	1.11 mg/l	No regulatory limit
14/11/2023	Magnesium	4.52 mg/l	No regulatory limit
15/11/2023	Magnesium	4.36 mg/l	No regulatory limit
16/11/2023	Magnesium	4.37 mg/l	No regulatory limit
17/11/2023	Magnesium	4.22 mg/l	No regulatory limit
23/11/2023	Magnesium	4.13 mg/l	No regulatory limit
04/12/2023	Magnesium	1.87 mg/l	No regulatory limit
05/12/2023	Magnesium	4.4 mg/l	No regulatory limit

15/12/2023	Magnesium	4.16 mg/l	No regulatory limit
18/12/2023	Magnesium	4.19 mg/l	No regulatory limit
19/12/2023	Magnesium	3.52 mg/l	No regulatory limit
22/12/2023	Magnesium	3.84 mg/l	No regulatory limit
06/01/2024	Magnesium	3.63 mg/l	No regulatory limit
08/01/2024	Magnesium	3.41 mg/l	No regulatory limit
11/01/2024	Magnesium	3.79 mg/l	No regulatory limit
15/01/2024	Magnesium	3.57 mg/l	No regulatory limit
19/01/2024	Magnesium	4.31 mg/l	No regulatory limit
27/01/2024	Magnesium	3.68 mg/l	No regulatory limit
01/02/2024	Magnesium	3.68 mg/l	No regulatory limit
06/02/2024	Magnesium	3.69 mg/l	No regulatory limit
12/02/2024	Magnesium	3.91 mg/l	No regulatory limit
19/02/2024	Magnesium	3.97 mg/l	No regulatory limit
07/03/2024	Magnesium	3.86 mg/l	No regulatory limit
13/03/2024	Magnesium	3.68 mg/l	No regulatory limit
15/03/2024	Magnesium	3.91 mg/l	No regulatory limit
20/03/2024	Magnesium	3.81 mg/l	No regulatory limit
26/03/2024	Magnesium	3.62 mg/l	No regulatory limit
04/04/2024	Magnesium	4.06 mg/l	No regulatory limit
11/04/2024	Magnesium	3.56 mg/l	No regulatory limit
19/04/2024	Magnesium	3.78 mg/l	No regulatory limit
26/04/2024	Magnesium	3.78 mg/l	No regulatory limit
01/05/2024	Magnesium	3.79 mg/l	No regulatory limit
09/05/2024	Magnesium	4.22 mg/l	No regulatory limit
13/05/2024	Magnesium	4.05 mg/l	No regulatory limit
24/05/2024	Magnesium	3.8 mg/l	No regulatory limit
28/05/2024	Magnesium	4.07 mg/l	No regulatory limit
07/06/2024	Magnesium	4.09 mg/l	No regulatory limit
13/06/2024	Magnesium	4.03 mg/l	No regulatory limit
18/06/2024	Magnesium	3.96 mg/l	No regulatory limit
25/06/2024	Magnesium	4.03 mg/l	No regulatory limit
02/07/2024	Magnesium	3.91 mg/l	No regulatory limit
17/07/2024	Magnesium	4.57 mg/l	No regulatory limit
24/07/2024	Magnesium	4.44 mg/l	No regulatory limit
26/07/2024	Magnesium	4.58 mg/l	No regulatory limit
07/08/2024	Magnesium	5.09 mg/l	No regulatory limit
09/08/2024	Magnesium	4.92 mg/l	No regulatory limit
16/08/2024	Magnesium	5.09 mg/l	No regulatory limit
29/08/2024	Magnesium	5.53 mg/l	No regulatory limit
30/08/2024	Magnesium	5.11 mg/l	No regulatory limit
03/09/2024	Magnesium	5.32 mg/l	No regulatory limit
04/09/2024	Magnesium	5.67 mg/l	No regulatory limit
17/09/2024	Magnesium	5.56 mg/l	No regulatory limit
27/09/2024	Magnesium	5.76 mg/l	No regulatory limit
10/10/2024	Magnesium	5.38 mg/l	No regulatory limit
16/10/2024	Magnesium	5.33 mg/l	No regulatory limit
21/10/2024	Magnesium	5.49 mg/l	No regulatory limit

25/10/2024	Magnesium	1.06 mg/l	No regulatory limit
07/11/2024	Magnesium	5.82 mg/l	No regulatory limit
15/11/2024	Magnesium	6.1 mg/l	No regulatory limit
18/11/2024	Magnesium	5.83 mg/l	No regulatory limit
25/11/2024	Magnesium	5.38 mg/l	No regulatory limit
28/11/2024	Magnesium	1.1 mg/l	No regulatory limit
03/12/2024	Magnesium	4.76 mg/l	No regulatory limit
10/12/2024	Magnesium	1.14 mg/l	No regulatory limit
21/12/2024	Magnesium	4.52 mg/l	No regulatory limit
02/01/2025	Magnesium	4.49 mg/l	No regulatory limit
22/01/2025	Magnesium	4.83 mg/l	No regulatory limit
29/01/2025	Magnesium	4.44 mg/l	No regulatory limit
30/01/2025	Magnesium	4.15 mg/l	No regulatory limit
04/02/2025	Magnesium	4.26 mg/l	No regulatory limit
14/02/2025	Magnesium	4.57 mg/l	No regulatory limit
27/02/2025	Magnesium	4.62 mg/l	No regulatory limit
17/03/2025	Magnesium	4.56 mg/l	No regulatory limit
21/03/2025	Magnesium	4.92 mg/l	No regulatory limit
25/03/2025	Magnesium	4.59 mg/l	No regulatory limit
05/04/2025	Magnesium	4.88 mg/l	No regulatory limit
10/04/2025	Magnesium	4.92 mg/l	No regulatory limit
16/04/2025	Magnesium	5.16 mg/l	No regulatory limit
24/04/2025	Magnesium	4.98 mg/l	No regulatory limit
29/04/2025	Magnesium	4.38 mg/l	No regulatory limit
07/05/2025	Magnesium	2.38 mg/l	No regulatory limit
14/05/2025	Magnesium	4.68 mg/l	No regulatory limit
17/05/2025	Magnesium	2.04 mg/l	No regulatory limit
05/06/2025	Magnesium	4.37 mg/l	No regulatory limit
13/06/2025	Magnesium	4.3 mg/l	No regulatory limit
14/06/2025	Magnesium	4.63 mg/l	No regulatory limit
15/06/2025	Magnesium	4.43 mg/l	No regulatory limit
17/06/2025	Magnesium	4.7 mg/l	No regulatory limit
18/06/2025	Magnesium	4.74 mg/l	No regulatory limit
20/06/2025	Magnesium	4.53 mg/l	No regulatory limit
27/06/2025	Magnesium	4.82 mg/l	No regulatory limit
04/07/2025	Magnesium	4.6 mg/l	No regulatory limit
09/07/2025	Magnesium	1.84 mg/l	No regulatory limit
10/07/2025	Magnesium	4.75 mg/l	No regulatory limit
23/07/2025	Magnesium	5.02 mg/l	No regulatory limit
01/08/2025	Magnesium	5.2 mg/l	No regulatory limit
07/08/2025	Magnesium	5.55 mg/l	No regulatory limit
08/08/2025	Magnesium	5.52 mg/l	No regulatory limit
03/09/2025	Magnesium	4.11 mg/l	No regulatory limit
06/09/2025	Magnesium	6.16 mg/l	No regulatory limit
12/09/2025	Magnesium	2.18 mg/l	No regulatory limit
01/10/2025	Magnesium	1.34 mg/l	No regulatory limit
06/10/2025	Magnesium	3.97 mg/l	No regulatory limit
08/10/2025	Magnesium	1.61 mg/l	No regulatory limit

14/10/2025	Magnesium		1.49 mg/l	No regulatory limit
15/10/2025	Magnesium		4.11 mg/l	No regulatory limit
22/10/2025	Magnesium		1.13 mg/l	No regulatory limit
23/10/2025	Magnesium		4.07 mg/l	No regulatory limit
24/10/2025	Magnesium		3.73 mg/l	No regulatory limit
28/10/2025	Magnesium		4.39 mg/l	No regulatory limit
05/11/2025	Magnesium		3.8 mg/l	No regulatory limit
12/11/2025	Magnesium		4.51 mg/l	No regulatory limit
18/11/2025	Magnesium		1.1 mg/l	No regulatory limit
24/11/2025	Magnesium		3.55 mg/l	No regulatory limit
03/12/2025	Magnesium		4.21 mg/l	No regulatory limit
09/12/2025	Magnesium		1.4 mg/l	No regulatory limit
15/12/2025	Magnesium		4.12 mg/l	No regulatory limit
09/01/2026	Magnesium		4.2 mg/l	No regulatory limit
15/01/2026	Magnesium		4.51 mg/l	No regulatory limit
20/01/2026	Magnesium		4.21 mg/l	No regulatory limit
29/01/2026	Magnesium		4.06 mg/l	No regulatory limit
30/01/2026	Magnesium		4.23 mg/l	No regulatory limit
02/02/2026	Magnesium		4.35 mg/l	No regulatory limit
11/02/2026	Magnesium		4.32 mg/l	No regulatory limit
17/02/2026	Magnesium		4.24 mg/l	No regulatory limit
03/03/2021	MANGANESE		0.57 µg/l	50
20/03/2021	MANGANESE		3.73 µg/l	50
26/03/2021	MANGANESE		0.44 µg/l	50
30/03/2021	MANGANESE		0.71 µg/l	50
31/03/2021	MANGANESE		0.43 µg/l	50
08/04/2021	MANGANESE	<	0.37 µg/l	50
09/04/2021	MANGANESE		0.99 µg/l	50
10/04/2021	MANGANESE		0.51 µg/l	50
23/04/2021	MANGANESE		0.59 µg/l	50
08/05/2021	MANGANESE		0.61 µg/l	50
14/05/2021	MANGANESE		0.57 µg/l	50
19/05/2021	MANGANESE		1 µg/l	50
22/05/2021	MANGANESE		0.94 µg/l	50
25/05/2021	MANGANESE		0.51 µg/l	50
27/05/2021	MANGANESE		5.42 µg/l	50
29/05/2021	MANGANESE		0.97 µg/l	50
02/06/2021	MANGANESE		0.75 µg/l	50
07/06/2021	MANGANESE		1.65 µg/l	50
11/06/2021	MANGANESE		0.5 µg/l	50
15/06/2021	MANGANESE	<	0.37 µg/l	50
01/07/2021	MANGANESE		4.92 µg/l	50
09/07/2021	MANGANESE	<	0.37 µg/l	50
22/07/2021	MANGANESE		0.98 µg/l	50
03/08/2021	MANGANESE		0.42 µg/l	50
08/08/2021	MANGANESE		0.54 µg/l	50
27/08/2021	MANGANESE		1.36 µg/l	50
01/09/2021	MANGANESE		1.62 µg/l	50

09/09/2021	MANGANESE	0.64 µg/l	50
24/09/2021	MANGANESE	2.44 µg/l	50
28/09/2021	MANGANESE	2.69 µg/l	50
30/09/2021	MANGANESE	3.5 µg/l	50
04/10/2021	MANGANESE	3.5 µg/l	50
17/10/2021	MANGANESE	1.16 µg/l	50
20/10/2021	MANGANESE	2.3 µg/l	50
21/10/2021	MANGANESE	2.23 µg/l	50
26/10/2021	MANGANESE	1.95 µg/l	50
03/11/2021	MANGANESE	2.41 µg/l	50
05/11/2021	MANGANESE	3.2 µg/l	50
13/11/2021	MANGANESE	2.36 µg/l	50
16/11/2021	MANGANESE	3.15 µg/l	50
18/11/2021	MANGANESE	3.11 µg/l	50
25/11/2021	MANGANESE	1.88 µg/l	50
29/11/2021	MANGANESE	1.45 µg/l	50
06/12/2021	MANGANESE	1.03 µg/l	50
07/12/2021	MANGANESE	3.12 µg/l	50
09/12/2021	MANGANESE	1.41 µg/l	50
09/12/2021	MANGANESE	1.64 µg/l	50
14/12/2021	MANGANESE	0.81 µg/l	50
15/12/2021	MANGANESE	0.73 µg/l	50
16/12/2021	MANGANESE	1.34 µg/l	50
18/12/2021	MANGANESE	1.31 µg/l	50
21/12/2021	MANGANESE	1.64 µg/l	50
22/12/2021	MANGANESE	1.69 µg/l	50
05/01/2022	MANGANESE	1.5 µg/l	50
14/01/2022	MANGANESE	1.46 µg/l	50
27/01/2022	MANGANESE	5.3 µg/l	50
31/01/2022	MANGANESE	5.17 µg/l	50
01/02/2022	MANGANESE	4.8 µg/l	50
09/02/2022	MANGANESE	4.15 µg/l	50
21/02/2022	MANGANESE	4.39 µg/l	50
22/02/2022	MANGANESE	3.62 µg/l	50
01/03/2022	MANGANESE	3.88 µg/l	50
04/03/2022	MANGANESE	1.55 µg/l	50
16/03/2022	MANGANESE	2.6 µg/l	50
22/03/2022	MANGANESE	2.91 µg/l	50
24/03/2022	MANGANESE	1.14 µg/l	50
30/03/2022	MANGANESE	2.86 µg/l	50
05/04/2022	MANGANESE	0.85 µg/l	50
11/04/2022	MANGANESE	0.87 µg/l	50
14/04/2022	MANGANESE	0.6 µg/l	50
19/04/2022	MANGANESE	0.51 µg/l	50
20/04/2022	MANGANESE	6.36 µg/l	50
28/04/2022	MANGANESE	1.64 µg/l	50
03/05/2022	MANGANESE	0.73 µg/l	50
10/05/2022	MANGANESE	0.45 µg/l	50

27/05/2022	MANGANESE		0.53 µg/l	50
05/06/2022	MANGANESE		0.42 µg/l	50
09/06/2022	MANGANESE		1.13 µg/l	50
13/06/2022	MANGANESE		0.74 µg/l	50
15/06/2022	MANGANESE	<	0.37 µg/l	50
17/06/2022	MANGANESE	<	0.45 µg/l	50
21/06/2022	MANGANESE	<	0.45 µg/l	50
01/07/2022	MANGANESE	<	0.45 µg/l	50
07/07/2022	MANGANESE	<	0.45 µg/l	50
20/07/2022	MANGANESE	<	0.37 µg/l	50
27/07/2022	MANGANESE	<	0.45 µg/l	50
09/08/2022	MANGANESE		4.63 µg/l	50
11/08/2022	MANGANESE	<	0.45 µg/l	50
19/08/2022	MANGANESE		1.39 µg/l	50
27/08/2022	MANGANESE		0.73 µg/l	50
07/09/2022	MANGANESE		2.34 µg/l	50
08/09/2022	MANGANESE		10.8 µg/l	50
15/09/2022	MANGANESE		6.01 µg/l	50
29/09/2022	MANGANESE		0.84 µg/l	50
04/10/2022	MANGANESE		2.75 µg/l	50
17/10/2022	MANGANESE		0.9 µg/l	50
03/11/2022	MANGANESE		1.88 µg/l	50
18/11/2022	MANGANESE		1.34 µg/l	50
22/11/2022	MANGANESE		0.65 µg/l	50
29/11/2022	MANGANESE	<	0.45 µg/l	50
30/11/2022	MANGANESE		3.05 µg/l	50
06/12/2022	MANGANESE		0.65 µg/l	50
12/12/2022	MANGANESE	<	0.45 µg/l	50
14/12/2022	MANGANESE	<	0.45 µg/l	50
16/12/2022	MANGANESE	<	0.45 µg/l	50
10/01/2023	MANGANESE		0.47 µg/l	50
17/01/2023	MANGANESE	<	0.45 µg/l	50
24/01/2023	MANGANESE	<	0.45 µg/l	50
10/02/2023	MANGANESE		0.55 µg/l	50
20/02/2023	MANGANESE	<	0.45 µg/l	50
22/02/2023	MANGANESE	<	0.45 µg/l	50
28/02/2023	MANGANESE	<	0.45 µg/l	50
01/03/2023	MANGANESE	<	0.45 µg/l	50
08/03/2023	MANGANESE		0.48 µg/l	50
14/03/2023	MANGANESE		0.67 µg/l	50
22/03/2023	MANGANESE		0.61 µg/l	50
31/03/2023	MANGANESE		0.69 µg/l	50
05/04/2023	MANGANESE		0.61 µg/l	50
06/04/2023	MANGANESE	<	0.45 µg/l	50
11/04/2023	MANGANESE	<	0.45 µg/l	50
21/04/2023	MANGANESE	<	0.45 µg/l	50
25/04/2023	MANGANESE		0.52 µg/l	50
05/05/2023	MANGANESE	<	0.45 µg/l	50

10/05/2023	MANGANESE		1.13 µg/l	50
13/05/2023	MANGANESE	<	0.45 µg/l	50
20/05/2023	MANGANESE		1.24 µg/l	50
30/05/2023	MANGANESE	<	0.37 µg/l	50
07/06/2023	MANGANESE	<	0.45 µg/l	50
14/06/2023	MANGANESE		0.51 µg/l	50
28/06/2023	MANGANESE	<	0.37 µg/l	50
05/07/2023	MANGANESE	<	0.45 µg/l	50
11/07/2023	MANGANESE	<	0.45 µg/l	50
12/07/2023	MANGANESE	<	0.45 µg/l	50
17/07/2023	MANGANESE		1.25 µg/l	50
28/07/2023	MANGANESE		1.03 µg/l	50
31/07/2023	MANGANESE	<	0.45 µg/l	50
07/08/2023	MANGANESE	<	0.45 µg/l	50
10/08/2023	MANGANESE		3.94 µg/l	50
24/08/2023	MANGANESE	<	0.37 µg/l	50
02/09/2023	MANGANESE	<	0.45 µg/l	50
04/09/2023	MANGANESE	<	0.45 µg/l	50
14/09/2023	MANGANESE	<	0.37 µg/l	50
22/09/2023	MANGANESE	<	0.45 µg/l	50
04/10/2023	MANGANESE		0.69 µg/l	50
14/10/2023	MANGANESE	<	0.45 µg/l	50
20/10/2023	MANGANESE		0.95 µg/l	50
04/11/2023	MANGANESE		2.65 µg/l	50
06/11/2023	MANGANESE		1.12 µg/l	50
14/11/2023	MANGANESE		2.3 µg/l	50
15/11/2023	MANGANESE		1.08 µg/l	50
16/11/2023	MANGANESE	<	0.45 µg/l	50
17/11/2023	MANGANESE	<	0.45 µg/l	50
23/11/2023	MANGANESE	<	0.45 µg/l	50
04/12/2023	MANGANESE		1.33 µg/l	50
15/12/2023	MANGANESE	<	0.37 µg/l	50
18/12/2023	MANGANESE	<	0.37 µg/l	50
19/12/2023	MANGANESE		0.98 µg/l	50
21/12/2023	MANGANESE	<	0.45 µg/l	50
22/12/2023	MANGANESE		0.58 µg/l	50
06/01/2024	MANGANESE	<	0.45 µg/l	50
08/01/2024	MANGANESE	<	0.45 µg/l	50
11/01/2024	MANGANESE	<	0.37 µg/l	50
15/01/2024	MANGANESE	<	0.45 µg/l	50
19/01/2024	MANGANESE		0.51 µg/l	50
27/01/2024	MANGANESE		0.47 µg/l	50
01/02/2024	MANGANESE	<	0.45 µg/l	50
06/02/2024	MANGANESE		0.53 µg/l	50
12/02/2024	MANGANESE		0.5 µg/l	50
19/02/2024	MANGANESE	<	0.37 µg/l	50
07/03/2024	MANGANESE		0.4 µg/l	50
13/03/2024	MANGANESE	<	0.45 µg/l	50

15/03/2024	MANGANESE		0.44 µg/l	50
20/03/2024	MANGANESE		0.49 µg/l	50
26/03/2024	MANGANESE	<	0.45 µg/l	50
04/04/2024	MANGANESE	<	0.37 µg/l	50
11/04/2024	MANGANESE	<	0.45 µg/l	50
19/04/2024	MANGANESE	<	0.45 µg/l	50
26/04/2024	MANGANESE	<	0.45 µg/l	50
01/05/2024	MANGANESE	<	0.45 µg/l	50
09/05/2024	MANGANESE	<	0.37 µg/l	50
13/05/2024	MANGANESE		0.73 µg/l	50
24/05/2024	MANGANESE		0.58 µg/l	50
28/05/2024	MANGANESE		0.57 µg/l	50
07/06/2024	MANGANESE		0.69 µg/l	50
13/06/2024	MANGANESE		1.31 µg/l	50
18/06/2024	MANGANESE		1.21 µg/l	50
25/06/2024	MANGANESE		1.57 µg/l	50
02/07/2024	MANGANESE		1.9 µg/l	50
17/07/2024	MANGANESE		5.69 µg/l	50
24/07/2024	MANGANESE		6.89 µg/l	50
26/07/2024	MANGANESE		7.61 µg/l	50
07/08/2024	MANGANESE		26.4 µg/l	50
09/08/2024	MANGANESE		8.17 µg/l	50
16/08/2024	MANGANESE		7.51 µg/l	50
29/08/2024	MANGANESE		1.34 µg/l	50
30/08/2024	MANGANESE		1.63 µg/l	50
03/09/2024	MANGANESE		2.41 µg/l	50
04/09/2024	MANGANESE		1.49 µg/l	50
17/09/2024	MANGANESE		0.63 µg/l	50
27/09/2024	MANGANESE		0.46 µg/l	50
10/10/2024	MANGANESE		0.79 µg/l	50
16/10/2024	MANGANESE		0.54 µg/l	50
21/10/2024	MANGANESE		1.02 µg/l	50
25/10/2024	MANGANESE		1.15 µg/l	50
07/11/2024	MANGANESE		1.5 µg/l	50
15/11/2024	MANGANESE		2.56 µg/l	50
18/11/2024	MANGANESE		3.4 µg/l	50
25/11/2024	MANGANESE		3.02 µg/l	50
28/11/2024	MANGANESE		0.78 µg/l	50
03/12/2024	MANGANESE		1.75 µg/l	50
10/12/2024	MANGANESE		1.04 µg/l	50
21/12/2024	MANGANESE		1.58 µg/l	50
02/01/2025	MANGANESE		1.73 µg/l	50
22/01/2025	MANGANESE		0.76 µg/l	50
29/01/2025	MANGANESE		0.63 µg/l	50
30/01/2025	MANGANESE		0.51 µg/l	50
04/02/2025	MANGANESE		0.74 µg/l	50
14/02/2025	MANGANESE		0.68 µg/l	50
27/02/2025	MANGANESE		1.59 µg/l	50

17/03/2025	MANGANESE	0.72 µg/l	50
21/03/2025	MANGANESE	0.94 µg/l	50
25/03/2025	MANGANESE	0.88 µg/l	50
05/04/2025	MANGANESE	1.21 µg/l	50
10/04/2025	MANGANESE	1 µg/l	50
16/04/2025	MANGANESE	0.79 µg/l	50
24/04/2025	MANGANESE	1.42 µg/l	50
29/04/2025	MANGANESE	1.5 µg/l	50
07/05/2025	MANGANESE	0.9 µg/l	50
14/05/2025	MANGANESE	1.91 µg/l	50
17/05/2025	MANGANESE	0.87 µg/l	50
05/06/2025	MANGANESE	4.34 µg/l	50
13/06/2025	MANGANESE	4.56 µg/l	50
14/06/2025	MANGANESE	4.1 µg/l	50
15/06/2025	MANGANESE	3.28 µg/l	50
17/06/2025	MANGANESE	5.31 µg/l	50
18/06/2025	MANGANESE	6.12 µg/l	50
20/06/2025	MANGANESE	4.96 µg/l	50
27/06/2025	MANGANESE	6.52 µg/l	50
04/07/2025	MANGANESE	2.88 µg/l	50
09/07/2025	MANGANESE	0.92 µg/l	50
10/07/2025	MANGANESE	1.46 µg/l	50
23/07/2025	MANGANESE	7.31 µg/l	50
01/08/2025	MANGANESE	13.6 µg/l	50
07/08/2025	MANGANESE	3.07 µg/l	50
08/08/2025	MANGANESE	6.27 µg/l	50
03/09/2025	MANGANESE	4.59 µg/l	50
06/09/2025	MANGANESE	6.38 µg/l	50
12/09/2025	MANGANESE	5.63 µg/l	50
01/10/2025	MANGANESE	1.83 µg/l	50
06/10/2025	MANGANESE	3.43 µg/l	50
08/10/2025	MANGANESE	1.63 µg/l	50
14/10/2025	MANGANESE	1.37 µg/l	50
15/10/2025	MANGANESE	5.04 µg/l	50
22/10/2025	MANGANESE	0.69 µg/l	50
23/10/2025	MANGANESE	6.78 µg/l	50
24/10/2025	MANGANESE	5.27 µg/l	50
28/10/2025	MANGANESE	5.09 µg/l	50
05/11/2025	MANGANESE	3.36 µg/l	50
12/11/2025	MANGANESE	2.69 µg/l	50
18/11/2025	MANGANESE	1.41 µg/l	50
24/11/2025	MANGANESE	1.22 µg/l	50
03/12/2025	MANGANESE	2.55 µg/l	50
09/12/2025	MANGANESE	2.02 µg/l	50
15/12/2025	MANGANESE	0.74 µg/l	50
09/01/2026	MANGANESE	0.57 µg/l	50
15/01/2026	MANGANESE	1.16 µg/l	50
20/01/2026	MANGANESE	1.23 µg/l	50

29/01/2026	MANGANESE		1.03 µg/l	50
30/01/2026	MANGANESE		1.13 µg/l	50
02/02/2026	MANGANESE		1.43 µg/l	50
11/02/2026	MANGANESE		0.91 µg/l	50
17/02/2026	MANGANESE		0.62 µg/l	50
21/05/2021	NICKEL		1.71 µg/l	20
23/06/2021	NICKEL		1.21 µg/l	20
30/06/2021	NICKEL		1.19 µg/l	20
24/09/2021	NICKEL		1.42 µg/l	20
29/09/2021	NICKEL	<	0.77 µg/l	20
07/10/2021	NICKEL		1.51 µg/l	20
26/10/2021	NICKEL		1.23 µg/l	20
25/11/2021	NICKEL	<	1.07 µg/l	20
24/01/2022	NICKEL		1.72 µg/l	20
25/02/2022	NICKEL		1.85 µg/l	20
11/04/2022	NICKEL		1.7 µg/l	20
18/05/2022	NICKEL		1.44 µg/l	20
07/06/2022	NICKEL		1.93 µg/l	20
11/08/2022	NICKEL		2.03 µg/l	20
27/08/2022	NICKEL	<	0.77 µg/l	20
05/10/2022	NICKEL		1.17 µg/l	20
24/01/2023	NICKEL		1.34 µg/l	20
02/03/2023	NICKEL		1.75 µg/l	20
05/04/2023	NICKEL		1.31 µg/l	20
12/07/2023	NICKEL		1.56 µg/l	20
31/07/2023	NICKEL		1.85 µg/l	20
14/10/2023	NICKEL		1.97 µg/l	20
10/11/2023	NICKEL		1.44 µg/l	20
18/12/2023	NICKEL		1.94 µg/l	20
19/12/2023	NICKEL		1.22 µg/l	20
22/12/2023	NICKEL		1.62 µg/l	20
05/01/2024	NICKEL		1.47 µg/l	20
08/02/2024	NICKEL		1.97 µg/l	20
22/02/2024	NICKEL		2.23 µg/l	20
15/05/2024	NICKEL		1.82 µg/l	20
14/06/2024	NICKEL		1.57 µg/l	20
24/07/2024	NICKEL		4.14 µg/l	20
06/09/2024	NICKEL		1.8 µg/l	20
13/11/2024	NICKEL		1.1 µg/l	20
15/11/2024	NICKEL		1.24 µg/l	20
07/02/2025	NICKEL		1.3 µg/l	20
29/03/2025	NICKEL		1.13 µg/l	20
24/04/2025	NICKEL		1.05 µg/l	20
27/06/2025	NICKEL		0.81 µg/l	20
04/07/2025	NICKEL		0.98 µg/l	20
10/10/2025	NICKEL	<	0.77 µg/l	20
29/10/2025	NICKEL		0.84 µg/l	20
19/12/2025	NICKEL	<	0.77 µg/l	20

09/02/2026	NICKEL		0.99 µg/l	20
21/03/2021	NITRATE as N	<	0.4 mg/l	50
25/03/2021	NITRATE as N		0.4 mg/l	50
01/04/2021	NITRATE as N	<	0.4 mg/l	50
08/06/2021	NITRATE as N		0.3 mg/l	50
14/06/2021	NITRATE as N		0.29 mg/l	50
06/08/2021	NITRATE as N	<	0.4 mg/l	50
07/08/2021	NITRATE as N	<	0.23 mg/l	50
25/08/2021	NITRATE as N	<	0.23 mg/l	50
05/10/2021	NITRATE as N	<	0.23 mg/l	50
13/10/2021	NITRATE as N	<	0.4 mg/l	50
17/10/2021	NITRATE as N		0.41 mg/l	50
05/11/2021	NITRATE as N		0.3 mg/l	50
15/11/2021	NITRATE as N		0.34 mg/l	50
02/12/2021	NITRATE as N		0.33 mg/l	50
09/12/2021	NITRATE as N		0.34 mg/l	50
21/12/2021	NITRATE as N	<	0.4 mg/l	50
11/02/2022	NITRATE as N	<	0.4 mg/l	50
21/03/2022	NITRATE as N	<	0.4 mg/l	50
24/05/2022	NITRATE as N	<	0.4 mg/l	50
14/06/2022	NITRATE as N	<	0.4 mg/l	50
15/06/2022	NITRATE as N	<	0.4 mg/l	50
07/07/2022	NITRATE as N	<	0.4 mg/l	50
29/09/2022	NITRATE as N	<	0.4 mg/l	50
24/11/2022	NITRATE as N	<	0.4 mg/l	50
05/12/2022	NITRATE as N	<	0.4 mg/l	50
02/02/2023	NITRATE as N		0.47 mg/l	50
22/02/2023	NITRATE as N		0.5 mg/l	50
25/04/2023	NITRATE as N		0.5 mg/l	50
19/07/2023	NITRATE as N	<	0.55 mg/l	50
03/08/2023	NITRATE as N	<	0.55 mg/l	50
21/08/2023	NITRATE as N	<	0.99 mg/l	50
04/10/2023	NITRATE as N	<	0.55 mg/l	50
15/12/2023	NITRATE as N	<	0.99 mg/l	50
18/12/2023	NITRATE as N	<	0.99 mg/l	50
22/12/2023	NITRATE as N	<	0.99 mg/l	50
03/01/2024	NITRATE as N	<	0.99 mg/l	50
08/02/2024	NITRATE as N	<	0.99 mg/l	50
13/03/2024	NITRATE as N	<	0.99 mg/l	50
11/04/2024	NITRATE as N	<	0.99 mg/l	50
13/06/2024	NITRATE as N	<	0.55 mg/l	50
08/07/2024	NITRATE as N	<	0.46 mg/l	50
30/08/2024	NITRATE as N	<	0.46 mg/l	50
09/10/2024	NITRATE as N	<	0.46 mg/l	50
13/11/2024	NITRATE as N	<	0.55 mg/l	50
28/01/2025	NITRATE as N		0.61 mg/l	50
24/02/2025	NITRATE as N		0.64 mg/l	50
08/04/2025	NITRATE as N	<	0.55 mg/l	50

17/06/2025	NITRATE as N	<	0.46 mg/l	50
30/07/2025	NITRATE as N	<	0.55 mg/l	50
06/09/2025	NITRATE as N	<	0.46 mg/l	50
09/12/2025	NITRATE as N	<	0.46 mg/l	50
18/12/2025	NITRATE as N	<	0.55 mg/l	50
22/12/2025	NITRATE as N		0.47 mg/l	50
05/02/2026	NITRATE as N		0.55 mg/l	50
21/03/2021	NITRITE as N	<	0.0035 mg/l	0.5
25/03/2021	NITRITE as N	<	0.0035 mg/l	0.5
01/04/2021	NITRITE as N	<	0.0035 mg/l	0.5
02/06/2021	NITRITE as N	<	0.0019 mg/l	0.5
23/06/2021	NITRITE as N	<	0.0019 mg/l	0.5
06/08/2021	NITRITE as N	<	0.0035 mg/l	0.5
07/08/2021	NITRITE as N	<	0.0019 mg/l	0.5
25/08/2021	NITRITE as N	<	0.0019 mg/l	0.5
05/10/2021	NITRITE as N	<	0.0019 mg/l	0.5
13/10/2021	NITRITE as N	<	0.0035 mg/l	0.5
17/10/2021	NITRITE as N	<	0.0019 mg/l	0.5
05/11/2021	NITRITE as N	<	0.0019 mg/l	0.5
15/11/2021	NITRITE as N	<	0.0019 mg/l	0.5
02/12/2021	NITRITE as N	<	0.0019 mg/l	0.5
09/12/2021	NITRITE as N	<	0.0019 mg/l	0.5
21/12/2021	NITRITE as N	<	0.0035 mg/l	0.5
11/02/2022	NITRITE as N	<	0.0035 mg/l	0.5
21/03/2022	NITRITE as N	<	0.0035 mg/l	0.5
24/05/2022	NITRITE as N	<	0.0035 mg/l	0.5
14/06/2022	NITRITE as N	<	0.0035 mg/l	0.5
15/06/2022	NITRITE as N	<	0.0035 mg/l	0.5
07/07/2022	NITRITE as N	<	0.0035 mg/l	0.5
29/09/2022	NITRITE as N	<	0.0035 mg/l	0.5
24/11/2022	NITRITE as N	<	0.0035 mg/l	0.5
05/12/2022	NITRITE as N	<	0.0035 mg/l	0.5
02/02/2023	NITRITE as N	<	0.0035 mg/l	0.5
22/02/2023	NITRITE as N	<	0.0035 mg/l	0.5
25/04/2023	NITRITE as N	<	0.0035 mg/l	0.5
19/07/2023	NITRITE as N	<	0.0023 mg/l	0.5
03/08/2023	NITRITE as N	<	0.0023 mg/l	0.5
21/08/2023	NITRITE as N	<	0.003 mg/l	0.5
04/10/2023	NITRITE as N	<	0.0023 mg/l	0.5
15/12/2023	NITRITE as N	<	0.003 mg/l	0.5
18/12/2023	NITRITE as N	<	0.003 mg/l	0.5
22/12/2023	NITRITE as N	<	0.003 mg/l	0.5
03/01/2024	NITRITE as N	<	0.003 mg/l	0.5
08/02/2024	NITRITE as N	<	0.003 mg/l	0.5
13/03/2024	NITRITE as N	<	0.003 mg/l	0.5
11/04/2024	NITRITE as N	<	0.003 mg/l	0.5
13/06/2024	NITRITE as N	<	0.0023 mg/l	0.5
08/07/2024	NITRITE as N	<	0.0023 mg/l	0.5

30/08/2024	NITRITE as N	<	0.0023 mg/l	0.5
09/10/2024	NITRITE as N	<	0.0023 mg/l	0.5
13/11/2024	NITRITE as N	<	0.003 mg/l	0.5
28/01/2025	NITRITE as N	<	0.003 mg/l	0.5
24/02/2025	NITRITE as N	<	0.0023 mg/l	0.5
08/04/2025	NITRITE as N	<	0.003 mg/l	0.5
17/06/2025	NITRITE as N	<	0.0023 mg/l	0.5
30/07/2025	NITRITE as N	<	0.003 mg/l	0.5
06/09/2025	NITRITE as N	<	0.0023 mg/l	0.5
09/12/2025	NITRITE as N	<	0.0023 mg/l	0.5
18/12/2025	NITRITE as N	<	0.003 mg/l	0.5
22/12/2025	NITRITE as N	<	0.0023 mg/l	0.5
05/02/2026	NITRITE as N	<	0.003 mg/l	0.5
21/03/2021	NO3 PLUS NO2 DWI		0.033 mg/l	
25/03/2021	NO3 PLUS NO2 DWI		0.036 mg/l	
01/04/2021	NO3 PLUS NO2 DWI		0.032 mg/l	
07/06/2021	NO3 PLUS NO2 DWI		0.025 mg/l	
11/06/2021	NO3 PLUS NO2 DWI		0.034 mg/l	
06/08/2021	NO3 PLUS NO2 DWI		0.019 mg/l	
07/08/2021	NO3 PLUS NO2 DWI		0.017 mg/l	
25/08/2021	NO3 PLUS NO2 DWI		0.019 mg/l	
05/10/2021	NO3 PLUS NO2 DWI		0.017 mg/l	
13/10/2021	NO3 PLUS NO2 DWI		0.021 mg/l	
17/10/2021	NO3 PLUS NO2 DWI		0.036 mg/l	
05/11/2021	NO3 PLUS NO2 DWI		0.026 mg/l	
15/11/2021	NO3 PLUS NO2 DWI		0.029 mg/l	
02/12/2021	NO3 PLUS NO2 DWI		0.029 mg/l	
09/12/2021	NO3 PLUS NO2 DWI		0.03 mg/l	
21/12/2021	NO3 PLUS NO2 DWI		0.032 mg/l	
11/02/2022	NO3 PLUS NO2 DWI		0.021 mg/l	
21/03/2022	NO3 PLUS NO2 DWI		0.015 mg/l	
24/05/2022	NO3 PLUS NO2 DWI		0.033 mg/l	
14/06/2022	NO3 PLUS NO2 DWI		0.032 mg/l	
15/06/2022	NO3 PLUS NO2 DWI		0.029 mg/l	
07/07/2022	NO3 PLUS NO2 DWI		0.021 mg/l	
29/09/2022	NO3 PLUS NO2 DWI		0.017 mg/l	
24/11/2022	NO3 PLUS NO2 DWI		0.034 mg/l	
05/12/2022	NO3 PLUS NO2 DWI		0.034 mg/l	
02/02/2023	NO3 PLUS NO2 DWI		0.042 mg/l	
22/02/2023	NO3 PLUS NO2 DWI		0.041 mg/l	
25/04/2023	NO3 PLUS NO2 DWI		0.041 mg/l	
19/07/2023	NO3 PLUS NO2 DWI		0.03 mg/l	
03/08/2023	NO3 PLUS NO2 DWI		0.028 mg/l	
21/08/2023	NO3 PLUS NO2 DWI		0.022 mg/l	
04/10/2023	NO3 PLUS NO2 DWI		0.024 mg/l	
15/12/2023	NO3 PLUS NO2 DWI		0.027 mg/l	
18/12/2023	NO3 PLUS NO2 DWI		0.027 mg/l	
22/12/2023	NO3 PLUS NO2 DWI		0.031 mg/l	

03/01/2024	NO3 PLUS NO2 DWI	0.029 mg/l	
08/02/2024	NO3 PLUS NO2 DWI	0.038 mg/l	
13/03/2024	NO3 PLUS NO2 DWI	0.06 mg/l	
11/04/2024	NO3 PLUS NO2 DWI	0.034 mg/l	
13/06/2024	NO3 PLUS NO2 DWI	0.031 mg/l	
08/07/2024	NO3 PLUS NO2 DWI	0.033 mg/l	
30/08/2024	NO3 PLUS NO2 DWI	0.013 mg/l	
09/10/2024	NO3 PLUS NO2 DWI	0.02 mg/l	
13/11/2024	NO3 PLUS NO2 DWI	0.027 mg/l	
28/01/2025	NO3 PLUS NO2 DWI	0.054 mg/l	
24/02/2025	NO3 PLUS NO2 DWI	0.056 mg/l	
08/04/2025	NO3 PLUS NO2 DWI	0.048 mg/l	
17/06/2025	NO3 PLUS NO2 DWI	0.033 mg/l	
30/07/2025	NO3 PLUS NO2 DWI	0.039 mg/l	
06/09/2025	NO3 PLUS NO2 DWI	0.029 mg/l	
09/12/2025	NO3 PLUS NO2 DWI	0.02 mg/l	
18/12/2025	NO3 PLUS NO2 DWI	0.039 mg/l	
22/12/2025	NO3 PLUS NO2 DWI	0.041 mg/l	
05/02/2026	NO3 PLUS NO2 DWI	0.048 mg/l	
11/03/2021	ODOUR QUANTITATIVE	0 Diln	0
19/03/2021	ODOUR QUANTITATIVE	0 Diln	0
21/03/2021	ODOUR QUANTITATIVE	0 Diln	0
31/03/2021	ODOUR QUANTITATIVE	0 Diln	0
01/04/2021	ODOUR QUANTITATIVE	0 Diln	0
04/04/2021	ODOUR QUANTITATIVE	0 Diln	0
08/04/2021	ODOUR QUANTITATIVE	0 Diln	0
09/04/2021	ODOUR QUANTITATIVE	0 Diln	0
10/05/2021	ODOUR QUANTITATIVE	0 Diln	0
20/05/2021	ODOUR QUANTITATIVE	0 Diln	0
27/05/2021	ODOUR QUANTITATIVE	0 Diln	0
29/05/2021	ODOUR QUANTITATIVE	0 Diln	0
02/06/2021	ODOUR QUANTITATIVE	0 Diln	0
11/06/2021	ODOUR QUANTITATIVE	0 Diln	0
14/06/2021	ODOUR QUANTITATIVE	0 Diln	0
23/06/2021	ODOUR QUANTITATIVE	0 Diln	0
25/06/2021	ODOUR QUANTITATIVE	0 Diln	0
29/06/2021	ODOUR QUANTITATIVE	0 Diln	0
30/06/2021	ODOUR QUANTITATIVE	0 Diln	0
08/07/2021	ODOUR QUANTITATIVE	0 Diln	0
14/07/2021	ODOUR QUANTITATIVE	0 Diln	0
21/07/2021	ODOUR QUANTITATIVE	0 Diln	0
22/07/2021	ODOUR QUANTITATIVE	0 Diln	0
23/07/2021	ODOUR QUANTITATIVE	0 Diln	0
27/08/2021	ODOUR QUANTITATIVE	0 Diln	0
01/09/2021	ODOUR QUANTITATIVE	0 Diln	0
30/09/2021	ODOUR QUANTITATIVE	0 Diln	0
01/10/2021	ODOUR QUANTITATIVE	0 Diln	0
14/10/2021	ODOUR QUANTITATIVE	0 Diln	0

17/10/2021	ODOUR QUANTITATIVE	0 Diln	0
18/10/2021	ODOUR QUANTITATIVE	0 Diln	0
20/10/2021	ODOUR QUANTITATIVE	0 Diln	0
22/10/2021	ODOUR QUANTITATIVE	0 Diln	0
26/10/2021	ODOUR QUANTITATIVE	0 Diln	0
28/10/2021	ODOUR QUANTITATIVE	0 Diln	0
30/10/2021	ODOUR QUANTITATIVE	0 Diln	0
04/11/2021	ODOUR QUANTITATIVE	0 Diln	0
10/11/2021	ODOUR QUANTITATIVE	0 Diln	0
13/11/2021	ODOUR QUANTITATIVE	0 Diln	0
16/11/2021	ODOUR QUANTITATIVE	0 Diln	0
19/11/2021	ODOUR QUANTITATIVE	0 Diln	0
23/11/2021	ODOUR QUANTITATIVE	0 Diln	0
25/11/2021	ODOUR QUANTITATIVE	0 Diln	0
30/11/2021	ODOUR QUANTITATIVE	0 Diln	0
03/12/2021	ODOUR QUANTITATIVE	0 Diln	0
06/12/2021	ODOUR QUANTITATIVE	0 Diln	0
07/12/2021	ODOUR QUANTITATIVE	0 Diln	0
09/12/2021	ODOUR QUANTITATIVE	0 Diln	0
10/12/2021	ODOUR QUANTITATIVE	0 Diln	0
13/12/2021	ODOUR QUANTITATIVE	0 Diln	0
15/12/2021	ODOUR QUANTITATIVE	0 Diln	0
16/12/2021	ODOUR QUANTITATIVE	0 Diln	0
18/12/2021	ODOUR QUANTITATIVE	0 Diln	0
22/12/2021	ODOUR QUANTITATIVE	0 Diln	0
23/12/2021	ODOUR QUANTITATIVE	0 Diln	0
05/01/2022	ODOUR QUANTITATIVE	0 Diln	0
14/01/2022	ODOUR QUANTITATIVE	1 Diln	0
27/01/2022	ODOUR QUANTITATIVE	0 Diln	0
31/01/2022	ODOUR QUANTITATIVE	0 Diln	0
04/02/2022	ODOUR QUANTITATIVE	0 Diln	0
09/02/2022	ODOUR QUANTITATIVE	0 Diln	0
16/02/2022	ODOUR QUANTITATIVE	0 Diln	0
22/02/2022	ODOUR QUANTITATIVE	0 Diln	0
01/03/2022	ODOUR QUANTITATIVE	0 Diln	0
02/03/2022	ODOUR QUANTITATIVE	0 Diln	0
10/03/2022	ODOUR QUANTITATIVE	0 Diln	0
16/03/2022	ODOUR QUANTITATIVE	0 Diln	0
05/04/2022	ODOUR QUANTITATIVE	0 Diln	0
07/04/2022	ODOUR QUANTITATIVE	0 Diln	0
11/04/2022	ODOUR QUANTITATIVE	0 Diln	0
14/04/2022	ODOUR QUANTITATIVE	0 Diln	0
25/04/2022	ODOUR QUANTITATIVE	0 Diln	0
04/05/2022	ODOUR QUANTITATIVE	0 Diln	0
05/05/2022	ODOUR QUANTITATIVE	0 Diln	0
10/05/2022	ODOUR QUANTITATIVE	0 Diln	0
16/05/2022	ODOUR QUANTITATIVE	0 Diln	0
18/05/2022	ODOUR QUANTITATIVE	0 Diln	0

23/05/2022	ODOUR QUANTITATIVE	0 Diln	0
25/05/2022	ODOUR QUANTITATIVE	0 Diln	0
04/06/2022	ODOUR QUANTITATIVE	0 Diln	0
05/06/2022	ODOUR QUANTITATIVE	0 Diln	0
10/06/2022	ODOUR QUANTITATIVE	0 Diln	0
16/06/2022	ODOUR QUANTITATIVE	0 Diln	0
17/06/2022	ODOUR QUANTITATIVE	0 Diln	0
21/06/2022	ODOUR QUANTITATIVE	0 Diln	0
28/06/2022	ODOUR QUANTITATIVE	0 Diln	0
07/07/2022	ODOUR QUANTITATIVE	0 Diln	0
26/07/2022	ODOUR QUANTITATIVE	0 Diln	0
27/07/2022	ODOUR QUANTITATIVE	0 Diln	0
29/07/2022	ODOUR QUANTITATIVE	0 Diln	0
11/08/2022	ODOUR QUANTITATIVE	0 Diln	0
19/08/2022	ODOUR QUANTITATIVE	0 Diln	0
23/08/2022	ODOUR QUANTITATIVE	0 Diln	0
27/08/2022	ODOUR QUANTITATIVE	0 Diln	0
08/09/2022	ODOUR QUANTITATIVE	0 Diln	0
15/09/2022	ODOUR QUANTITATIVE	0 Diln	0
28/09/2022	ODOUR QUANTITATIVE	0 Diln	0
05/10/2022	ODOUR QUANTITATIVE	0 Diln	0
20/10/2022	ODOUR QUANTITATIVE	0 Diln	0
01/11/2022	ODOUR QUANTITATIVE	0 Diln	0
10/11/2022	ODOUR QUANTITATIVE	0 Diln	0
15/11/2022	ODOUR QUANTITATIVE	0 Diln	0
24/11/2022	ODOUR QUANTITATIVE	0 Diln	0
29/11/2022	ODOUR QUANTITATIVE	0 Diln	0
05/12/2022	ODOUR QUANTITATIVE	0 Diln	0
07/12/2022	ODOUR QUANTITATIVE	0 Diln	0
16/12/2022	ODOUR QUANTITATIVE	0 Diln	0
03/01/2023	ODOUR QUANTITATIVE	0 Diln	0
11/01/2023	ODOUR QUANTITATIVE	0 Diln	0
24/01/2023	ODOUR QUANTITATIVE	0 Diln	0
02/02/2023	ODOUR QUANTITATIVE	0 Diln	0
09/02/2023	ODOUR QUANTITATIVE	0 Diln	0
11/02/2023	ODOUR QUANTITATIVE	0 Diln	0
20/02/2023	ODOUR QUANTITATIVE	0 Diln	0
22/02/2023	ODOUR QUANTITATIVE	0 Diln	0
02/03/2023	ODOUR QUANTITATIVE	0 Diln	0
08/03/2023	ODOUR QUANTITATIVE	0 Diln	0
24/03/2023	ODOUR QUANTITATIVE	0 Diln	0
31/03/2023	ODOUR QUANTITATIVE	0 Diln	0
05/04/2023	ODOUR QUANTITATIVE	0 Diln	0
06/04/2023	ODOUR QUANTITATIVE	0 Diln	0
19/04/2023	ODOUR QUANTITATIVE	0 Diln	0
25/04/2023	ODOUR QUANTITATIVE	0 Diln	0
02/05/2023	ODOUR QUANTITATIVE	0 Diln	0
10/05/2023	ODOUR QUANTITATIVE	0 Diln	0

19/05/2023	ODOUR QUANTITATIVE	0 Diln	0
14/06/2023	ODOUR QUANTITATIVE	0 Diln	0
29/06/2023	ODOUR QUANTITATIVE	0 Diln	0
30/06/2023	ODOUR QUANTITATIVE	0 Diln	0
04/07/2023	ODOUR QUANTITATIVE	0 Diln	0
11/07/2023	ODOUR QUANTITATIVE	0 Diln	0
12/07/2023	ODOUR QUANTITATIVE	0 Diln	0
13/07/2023	ODOUR QUANTITATIVE	0 Diln	0
18/07/2023	ODOUR QUANTITATIVE	0 Diln	0
27/07/2023	ODOUR QUANTITATIVE	0 Diln	0
01/08/2023	ODOUR QUANTITATIVE	0 Diln	0
02/08/2023	ODOUR QUANTITATIVE	0 Diln	0
05/08/2023	ODOUR QUANTITATIVE	0 Diln	0
07/08/2023	ODOUR QUANTITATIVE	0 Diln	0
08/08/2023	ODOUR QUANTITATIVE	0 Diln	0
11/08/2023	ODOUR QUANTITATIVE	0 Diln	0
21/08/2023	ODOUR QUANTITATIVE	0 Diln	0
30/08/2023	ODOUR QUANTITATIVE	0 Diln	0
06/10/2023	ODOUR QUANTITATIVE	0 Diln	0
20/10/2023	ODOUR QUANTITATIVE	0 Diln	0
27/10/2023	ODOUR QUANTITATIVE	0 Diln	0
28/10/2023	ODOUR QUANTITATIVE	0 Diln	0
04/11/2023	ODOUR QUANTITATIVE	0 Diln	0
08/11/2023	ODOUR QUANTITATIVE	0 Diln	0
14/11/2023	ODOUR QUANTITATIVE	0 Diln	0
14/11/2023	ODOUR QUANTITATIVE	0 Diln	0
14/11/2023	ODOUR QUANTITATIVE	0 Diln	0
15/11/2023	ODOUR QUANTITATIVE	0 Diln	0
16/11/2023	ODOUR QUANTITATIVE	1 Diln	0
17/11/2023	ODOUR QUANTITATIVE	0 Diln	0
22/11/2023	ODOUR QUANTITATIVE	0 Diln	0
23/11/2023	ODOUR QUANTITATIVE	0 Diln	0
27/11/2023	ODOUR QUANTITATIVE	0 Diln	0
29/11/2023	ODOUR QUANTITATIVE	0 Diln	0
06/12/2023	ODOUR QUANTITATIVE	0 Diln	0
13/12/2023	ODOUR QUANTITATIVE	0 Diln	0
18/12/2023	ODOUR QUANTITATIVE	0 Diln	0
19/12/2023	ODOUR QUANTITATIVE	0 Diln	0
05/01/2024	ODOUR QUANTITATIVE	0 Diln	0
06/01/2024	ODOUR QUANTITATIVE	0 Diln	0
09/01/2024	ODOUR QUANTITATIVE	0 Diln	0
17/01/2024	ODOUR QUANTITATIVE	0 Diln	0
27/01/2024	ODOUR QUANTITATIVE	0 Diln	0
01/02/2024	ODOUR QUANTITATIVE	0 Diln	0
06/02/2024	ODOUR QUANTITATIVE	0 Diln	0
13/02/2024	ODOUR QUANTITATIVE	0 Diln	0
19/02/2024	ODOUR QUANTITATIVE	0 Diln	0
27/02/2024	ODOUR QUANTITATIVE	0 Diln	0

07/03/2024	ODOUR QUANTITATIVE	0 Diln	0
15/03/2024	ODOUR QUANTITATIVE	0 Diln	0
19/03/2024	ODOUR QUANTITATIVE	0 Diln	0
04/04/2024	ODOUR QUANTITATIVE	0 Diln	0
11/04/2024	ODOUR QUANTITATIVE	0 Diln	0
26/04/2024	ODOUR QUANTITATIVE	0 Diln	0
08/05/2024	ODOUR QUANTITATIVE	0 Diln	0
09/05/2024	ODOUR QUANTITATIVE	0 Diln	0
16/05/2024	ODOUR QUANTITATIVE	0 Diln	0
24/05/2024	ODOUR QUANTITATIVE	0 Diln	0
28/05/2024	ODOUR QUANTITATIVE	0 Diln	0
07/06/2024	ODOUR QUANTITATIVE	0 Diln	0
11/06/2024	ODOUR QUANTITATIVE	0 Diln	0
18/06/2024	ODOUR QUANTITATIVE	0 Diln	0
25/06/2024	ODOUR QUANTITATIVE	0 Diln	0
26/06/2024	ODOUR QUANTITATIVE	0 Diln	0
28/06/2024	ODOUR QUANTITATIVE	0 Diln	0
17/07/2024	ODOUR QUANTITATIVE	0 Diln	0
22/07/2024	ODOUR QUANTITATIVE	0 Diln	0
26/07/2024	ODOUR QUANTITATIVE	0 Diln	0
31/07/2024	ODOUR QUANTITATIVE	0 Diln	0
16/08/2024	ODOUR QUANTITATIVE	0 Diln	0
23/08/2024	ODOUR QUANTITATIVE	0 Diln	0
28/08/2024	ODOUR QUANTITATIVE	0 Diln	0
02/09/2024	ODOUR QUANTITATIVE	0 Diln	0
17/09/2024	ODOUR QUANTITATIVE	0 Diln	0
24/09/2024	ODOUR QUANTITATIVE	0 Diln	0
27/09/2024	ODOUR QUANTITATIVE	0 Diln	0
03/10/2024	ODOUR QUANTITATIVE	0 Diln	0
10/10/2024	ODOUR QUANTITATIVE	0 Diln	0
16/10/2024	ODOUR QUANTITATIVE	0 Diln	0
21/10/2024	ODOUR QUANTITATIVE	0 Diln	0
25/10/2024	ODOUR QUANTITATIVE	0 Diln	0
29/10/2024	ODOUR QUANTITATIVE	0 Diln	0
05/11/2024	ODOUR QUANTITATIVE	0 Diln	0
15/11/2024	ODOUR QUANTITATIVE	0 Diln	0
18/11/2024	ODOUR QUANTITATIVE	0 Diln	0
25/11/2024	ODOUR QUANTITATIVE	0 Diln	0
27/11/2024	ODOUR QUANTITATIVE	0 Diln	0
03/12/2024	ODOUR QUANTITATIVE	0 Diln	0
10/12/2024	ODOUR QUANTITATIVE	0 Diln	0
18/12/2024	ODOUR QUANTITATIVE	0 Diln	0
19/12/2024	ODOUR QUANTITATIVE	0 Diln	0
21/12/2024	ODOUR QUANTITATIVE	0 Diln	0
02/01/2025	ODOUR QUANTITATIVE	0 Diln	0
10/01/2025	ODOUR QUANTITATIVE	0 Diln	0
16/01/2025	ODOUR QUANTITATIVE	0 Diln	0
21/01/2025	ODOUR QUANTITATIVE	0 Diln	0

30/01/2025	ODOUR QUANTITATIVE	0 Diln	0
07/02/2025	ODOUR QUANTITATIVE	0 Diln	0
12/02/2025	ODOUR QUANTITATIVE	0 Diln	0
27/02/2025	ODOUR QUANTITATIVE	0 Diln	0
27/02/2025	ODOUR QUANTITATIVE	0 Diln	0
05/03/2025	ODOUR QUANTITATIVE	0 Diln	0
21/03/2025	ODOUR QUANTITATIVE	0 Diln	0
25/03/2025	ODOUR QUANTITATIVE	0 Diln	0
29/03/2025	ODOUR QUANTITATIVE	0 Diln	0
10/04/2025	ODOUR QUANTITATIVE	0 Diln	0
24/04/2025	ODOUR QUANTITATIVE	0 Diln	0
29/04/2025	ODOUR QUANTITATIVE	0 Diln	0
01/05/2025	ODOUR QUANTITATIVE	0 Diln	0
06/05/2025	ODOUR QUANTITATIVE	0 Diln	0
08/05/2025	ODOUR QUANTITATIVE	0 Diln	0
12/05/2025	ODOUR QUANTITATIVE	0 Diln	0
17/05/2025	ODOUR QUANTITATIVE	0 Diln	0
21/05/2025	ODOUR QUANTITATIVE	0 Diln	0
05/06/2025	ODOUR QUANTITATIVE	0 Diln	0
11/06/2025	ODOUR QUANTITATIVE	0 Diln	0
14/06/2025	ODOUR QUANTITATIVE	0 Diln	0
17/06/2025	ODOUR QUANTITATIVE	0 Diln	0
19/06/2025	ODOUR QUANTITATIVE	0 Diln	0
26/06/2025	ODOUR QUANTITATIVE	0 Diln	0
11/07/2025	ODOUR QUANTITATIVE	0 Diln	0
23/07/2025	ODOUR QUANTITATIVE	0 Diln	0
29/07/2025	ODOUR QUANTITATIVE	0 Diln	0
07/08/2025	ODOUR QUANTITATIVE	0 Diln	0
13/08/2025	ODOUR QUANTITATIVE	0 Diln	0
05/09/2025	ODOUR QUANTITATIVE	0 Diln	0
12/09/2025	ODOUR QUANTITATIVE	0 Diln	0
30/09/2025	ODOUR QUANTITATIVE	0 Diln	0
01/10/2025	ODOUR QUANTITATIVE	0 Diln	0
03/10/2025	ODOUR QUANTITATIVE	0 Diln	0
06/10/2025	ODOUR QUANTITATIVE	0 Diln	0
14/10/2025	ODOUR QUANTITATIVE	0 Diln	0
18/10/2025	ODOUR QUANTITATIVE	0 Diln	0
20/10/2025	ODOUR QUANTITATIVE	0 Diln	0
22/10/2025	ODOUR QUANTITATIVE	0 Diln	0
29/10/2025	ODOUR QUANTITATIVE	0 Diln	0
31/10/2025	ODOUR QUANTITATIVE	0 Diln	0
08/11/2025	ODOUR QUANTITATIVE	0 Diln	0
12/11/2025	ODOUR QUANTITATIVE	0 Diln	0
18/11/2025	ODOUR QUANTITATIVE	0 Diln	0
20/11/2025	ODOUR QUANTITATIVE	0 Diln	0
27/11/2025	ODOUR QUANTITATIVE	0 Diln	0
02/12/2025	ODOUR QUANTITATIVE	0 Diln	0
11/12/2025	ODOUR QUANTITATIVE	0 Diln	0

16/12/2025 ODOUR QUANTITATIVE	0 Diln	0
19/12/2025 ODOUR QUANTITATIVE	0 Diln	0
06/01/2026 ODOUR QUANTITATIVE	0 Diln	0
15/01/2026 ODOUR QUANTITATIVE	0 Diln	0
20/01/2026 ODOUR QUANTITATIVE	0 Diln	0
30/01/2026 ODOUR QUANTITATIVE	0 Diln	0
09/02/2026 ODOUR QUANTITATIVE	0 Diln	0
10/02/2026 ODOUR QUANTITATIVE	0 Diln	0
09/04/2021 PAHs	0 µg/l	0.1
06/05/2021 PAHs	0 µg/l	0.1
21/05/2021 PAHs	0 µg/l	0.1
11/06/2021 PAHs	0 µg/l	0.1
14/06/2021 PAHs	0 µg/l	0.1
27/08/2021 PAHs	0 µg/l	0.1
01/09/2021 PAHs	0 µg/l	0.1
19/12/2021 PAHs	0 µg/l	0.1
22/12/2021 PAHs	0 µg/l	0.1
31/01/2022 PAHs	0 µg/l	0.1
18/02/2022 PAHs	0 µg/l	0.1
02/03/2022 PAHs	0 µg/l	0.1
10/05/2022 PAHs	0 µg/l	0.1
09/06/2022 PAHs	0 µg/l	0.1
29/07/2022 PAHs	0 µg/l	0.1
08/09/2022 PAHs	0 µg/l	0.1
15/11/2022 PAHs	0 µg/l	0.1
10/01/2023 PAHs	0 µg/l	0.1
02/05/2023 PAHs	0 µg/l	0.1
01/06/2023 PAHs	0 µg/l	0.1
17/07/2023 PAHs	0 µg/l	0.1
14/10/2023 PAHs	0 µg/l	0.1
10/11/2023 PAHs	0 µg/l	0.1
17/11/2023 PAHs	0 µg/l	0.1
28/11/2023 PAHs	0 µg/l	0.1
03/01/2024 PAHs	0 µg/l	0.1
23/02/2024 PAHs	0 µg/l	0.1
26/03/2024 PAHs	0 µg/l	0.1
04/04/2024 PAHs	0 µg/l	0.1
10/09/2024 PAHs	0 µg/l	0.1
24/09/2024 PAHs	0 µg/l	0.1
03/10/2024 PAHs	0 µg/l	0.1
11/10/2024 PAHs	0 µg/l	0.1
12/02/2025 PAHs	0 µg/l	0.1
01/05/2025 PAHs	0 µg/l	0.1
12/06/2025 PAHs	0 µg/l	0.1
14/06/2025 PAHs	0 µg/l	0.1
07/08/2025 PAHs	0 µg/l	0.1
01/10/2025 PAHs	0 µg/l	0.1
11/12/2025 PAHs	0.022 µg/l	0.1

16/12/2025 PAHs	0 µg/l	0.1
21/01/2026 PAHs	0 µg/l	0.1
11/03/2021 PH	7.34 pH units	6.5-9.5
21/03/2021 PH	7.06 pH units	6.5-9.5
01/04/2021 PH	6.93 pH units	6.5-9.5
09/04/2021 PH	7.21 pH units	6.5-9.5
10/04/2021 PH	7.13 pH units	6.5-9.5
18/04/2021 PH	7.11 pH units	6.5-9.5
19/04/2021 PH	7.24 pH units	6.5-9.5
21/04/2021 PH	7.02 pH units	6.5-9.5
23/04/2021 PH	7.44 pH units	6.5-9.5
06/05/2021 PH	6.95 pH units	6.5-9.5
11/05/2021 PH	6.91 pH units	6.5-9.5
19/05/2021 PH	7.61 pH units	6.5-9.5
21/05/2021 PH	7.07 pH units	6.5-9.5
26/05/2021 PH	7.01 pH units	6.5-9.5
29/05/2021 PH	7.12 pH units	6.5-9.5
02/06/2021 PH	7.19 pH units	6.5-9.5
11/06/2021 PH	7.28 pH units	6.5-9.5
14/06/2021 PH	7.22 pH units	6.5-9.5
24/06/2021 PH	7.06 pH units	6.5-9.5
30/06/2021 PH	6.95 pH units	6.5-9.5
06/07/2021 PH	7.23 pH units	6.5-9.5
15/07/2021 PH	7.04 pH units	6.5-9.5
23/07/2021 PH	7.08 pH units	6.5-9.5
03/08/2021 PH	7.06 pH units	6.5-9.5
06/08/2021 PH	7.15 pH units	6.5-9.5
07/08/2021 PH	7.18 pH units	6.5-9.5
08/08/2021 PH	7.29 pH units	6.5-9.5
09/08/2021 PH	7.25 pH units	6.5-9.5
27/08/2021 PH	7.27 pH units	6.5-9.5
01/09/2021 PH	7.03 pH units	6.5-9.5
04/10/2021 PH	7 pH units	6.5-9.5
19/10/2021 PH	7.49 pH units	6.5-9.5
25/10/2021 PH	7.11 pH units	6.5-9.5
28/10/2021 PH	7.36 pH units	6.5-9.5
29/10/2021 PH	7.01 pH units	6.5-9.5
05/11/2021 PH	7.02 pH units	6.5-9.5
13/11/2021 PH	7.33 pH units	6.5-9.5
18/11/2021 PH	7.09 pH units	6.5-9.5
23/11/2021 PH	7.05 pH units	6.5-9.5
25/11/2021 PH	7.25 pH units	6.5-9.5
29/11/2021 PH	7.01 pH units	6.5-9.5
06/12/2021 PH	7.09 pH units	6.5-9.5
09/12/2021 PH	7.28 pH units	6.5-9.5
09/12/2021 PH	7.14 pH units	6.5-9.5
14/12/2021 PH	7.03 pH units	6.5-9.5
17/12/2021 PH	7.2 pH units	6.5-9.5

17/12/2021 PH	7.4 pH units	6.5-9.5
19/12/2021 PH	6.99 pH units	6.5-9.5
20/12/2021 PH	7 pH units	6.5-9.5
21/12/2021 PH	7.09 pH units	6.5-9.5
22/12/2021 PH	7.26 pH units	6.5-9.5
22/12/2021 PH	7.07 pH units	6.5-9.5
19/01/2022 PH	7.19 pH units	6.5-9.5
27/01/2022 PH	7.11 pH units	6.5-9.5
31/01/2022 PH	7.15 pH units	6.5-9.5
02/02/2022 PH	7.21 pH units	6.5-9.5
04/02/2022 PH	7.27 pH units	6.5-9.5
08/02/2022 PH	7.2 pH units	6.5-9.5
18/02/2022 PH	7.12 pH units	6.5-9.5
26/02/2022 PH	7.21 pH units	6.5-9.5
01/03/2022 PH	7.09 pH units	6.5-9.5
15/03/2022 PH	7.35 pH units	6.5-9.5
16/03/2022 PH	7.33 pH units	6.5-9.5
17/03/2022 PH	7.04 pH units	6.5-9.5
21/03/2022 PH	7.34 pH units	6.5-9.5
08/04/2022 PH	7.21 pH units	6.5-9.5
13/04/2022 PH	7.04 pH units	6.5-9.5
14/04/2022 PH	7.22 pH units	6.5-9.5
21/04/2022 PH	7.06 pH units	6.5-9.5
05/05/2022 PH	7.29 pH units	6.5-9.5
09/05/2022 PH	7.37 pH units	6.5-9.5
10/05/2022 PH	7.36 pH units	6.5-9.5
18/05/2022 PH	7.04 pH units	6.5-9.5
19/05/2022 PH	7.29 pH units	6.5-9.5
24/05/2022 PH	7.78 pH units	6.5-9.5
25/05/2022 PH	7.17 pH units	6.5-9.5
01/06/2022 PH	7.63 pH units	6.5-9.5
09/06/2022 PH	7.56 pH units	6.5-9.5
16/06/2022 PH	6.94 pH units	6.5-9.5
17/06/2022 PH	7.26 pH units	6.5-9.5
20/06/2022 PH	7.01 pH units	6.5-9.5
07/07/2022 PH	7.3 pH units	6.5-9.5
08/07/2022 PH	7.23 pH units	6.5-9.5
11/07/2022 PH	7.44 pH units	6.5-9.5
26/07/2022 PH	7.05 pH units	6.5-9.5
27/07/2022 PH	7.04 pH units	6.5-9.5
10/08/2022 PH	7.62 pH units	6.5-9.5
15/08/2022 PH	7.37 pH units	6.5-9.5
23/08/2022 PH	6.98 pH units	6.5-9.5
27/08/2022 PH	7.45 pH units	6.5-9.5
07/09/2022 PH	7.27 pH units	6.5-9.5
08/09/2022 PH	7.18 pH units	6.5-9.5
22/09/2022 PH	7.27 pH units	6.5-9.5
29/09/2022 PH	7.86 pH units	6.5-9.5

04/10/2022 PH	7.6 pH units	6.5-9.5
03/11/2022 PH	7.22 pH units	6.5-9.5
07/11/2022 PH	7.12 pH units	6.5-9.5
08/11/2022 PH	7.48 pH units	6.5-9.5
15/11/2022 PH	7.01 pH units	6.5-9.5
22/11/2022 PH	7.21 pH units	6.5-9.5
28/11/2022 PH	9.57 pH units	6.5-9.5
06/12/2022 PH	7.22 pH units	6.5-9.5
14/12/2022 PH	7.4 pH units	6.5-9.5
17/12/2022 PH	6.98 pH units	6.5-9.5
03/01/2023 PH	7.01 pH units	6.5-9.5
10/01/2023 PH	7.37 pH units	6.5-9.5
18/01/2023 PH	7.26 pH units	6.5-9.5
27/01/2023 PH	7.13 pH units	6.5-9.5
01/02/2023 PH	7.02 pH units	6.5-9.5
10/02/2023 PH	7.23 pH units	6.5-9.5
20/02/2023 PH	7.02 pH units	6.5-9.5
24/02/2023 PH	7.15 pH units	6.5-9.5
27/02/2023 PH	7.02 pH units	6.5-9.5
28/02/2023 PH	6.87 pH units	6.5-9.5
06/03/2023 PH	7.12 pH units	6.5-9.5
24/03/2023 PH	7.23 pH units	6.5-9.5
29/03/2023 PH	7.39 pH units	6.5-9.5
11/04/2023 PH	7.22 pH units	6.5-9.5
18/04/2023 PH	7.43 pH units	6.5-9.5
27/04/2023 PH	7.18 pH units	6.5-9.5
05/05/2023 PH	7.36 pH units	6.5-9.5
13/05/2023 PH	7.34 pH units	6.5-9.5
24/05/2023 PH	7.18 pH units	6.5-9.5
30/05/2023 PH	7.2 pH units	6.5-9.5
07/06/2023 PH	7.03 pH units	6.5-9.5
14/06/2023 PH	7.33 pH units	6.5-9.5
29/06/2023 PH	7.53 pH units	6.5-9.5
07/07/2023 PH	7.18 pH units	6.5-9.5
12/07/2023 PH	7.82 pH units	6.5-9.5
19/07/2023 PH	7.25 pH units	6.5-9.5
28/07/2023 PH	7.08 pH units	6.5-9.5
02/08/2023 PH	6.85 pH units	6.5-9.5
07/08/2023 PH	7.16 pH units	6.5-9.5
08/08/2023 PH	7.07 pH units	6.5-9.5
19/08/2023 PH	7.24 pH units	6.5-9.5
21/08/2023 PH	7.97 pH units	6.5-9.5
30/08/2023 PH	7.09 pH units	6.5-9.5
12/09/2023 PH	7.28 pH units	6.5-9.5
14/09/2023 PH	7.21 pH units	6.5-9.5
04/10/2023 PH	7.07 pH units	6.5-9.5
14/10/2023 PH	7.06 pH units	6.5-9.5
20/10/2023 PH	7.3 pH units	6.5-9.5

31/10/2023 PH	7.11 pH units	6.5-9.5
10/11/2023 PH	7.39 pH units	6.5-9.5
14/11/2023 PH	7.03 pH units	6.5-9.5
15/11/2023 PH	7.87 pH units	6.5-9.5
15/11/2023 PH	7.29 pH units	6.5-9.5
16/11/2023 PH	7.01 pH units	6.5-9.5
17/11/2023 PH	7.63 pH units	6.5-9.5
20/11/2023 PH	7.31 pH units	6.5-9.5
22/11/2023 PH	7.05 pH units	6.5-9.5
29/11/2023 PH	6.98 pH units	6.5-9.5
08/12/2023 PH	7.22 pH units	6.5-9.5
13/12/2023 PH	6.98 pH units	6.5-9.5
18/12/2023 PH	7.64 pH units	6.5-9.5
22/12/2023 PH	7.05 pH units	6.5-9.5
04/01/2024 PH	7.03 pH units	6.5-9.5
05/01/2024 PH	7.58 pH units	6.5-9.5
09/01/2024 PH	7.05 pH units	6.5-9.5
19/01/2024 PH	7 pH units	6.5-9.5
23/01/2024 PH	7.12 pH units	6.5-9.5
01/02/2024 PH	7.2 pH units	6.5-9.5
08/02/2024 PH	7.09 pH units	6.5-9.5
22/02/2024 PH	7.33 pH units	6.5-9.5
23/02/2024 PH	7.96 pH units	6.5-9.5
07/03/2024 PH	6.98 pH units	6.5-9.5
12/03/2024 PH	7.21 pH units	6.5-9.5
13/03/2024 PH	7.19 pH units	6.5-9.5
22/03/2024 PH	7.13 pH units	6.5-9.5
04/04/2024 PH	6.96 pH units	6.5-9.5
11/04/2024 PH	7.12 pH units	6.5-9.5
19/04/2024 PH	7.11 pH units	6.5-9.5
23/04/2024 PH	7.22 pH units	6.5-9.5
09/05/2024 PH	7.39 pH units	6.5-9.5
15/05/2024 PH	7.22 pH units	6.5-9.5
21/05/2024 PH	7.22 pH units	6.5-9.5
28/05/2024 PH	7.23 pH units	6.5-9.5
11/06/2024 PH	7.25 pH units	6.5-9.5
18/06/2024 PH	7.24 pH units	6.5-9.5
26/06/2024 PH	7.17 pH units	6.5-9.5
28/06/2024 PH	7.24 pH units	6.5-9.5
02/07/2024 PH	7.29 pH units	6.5-9.5
08/07/2024 PH	7.68 pH units	6.5-9.5
17/07/2024 PH	7.1 pH units	6.5-9.5
19/07/2024 PH	7.71 pH units	6.5-9.5
22/07/2024 PH	7.02 pH units	6.5-9.5
31/07/2024 PH	7.12 pH units	6.5-9.5
07/08/2024 PH	6.87 pH units	6.5-9.5
13/08/2024 PH	7.08 pH units	6.5-9.5
27/08/2024 PH	7.22 pH units	6.5-9.5

28/08/2024 PH	7.5 pH units	6.5-9.5
03/09/2024 PH	7.28 pH units	6.5-9.5
04/09/2024 PH	7.34 pH units	6.5-9.5
17/09/2024 PH	7.16 pH units	6.5-9.5
26/09/2024 PH	7.1 pH units	6.5-9.5
09/10/2024 PH	7.22 pH units	6.5-9.5
10/10/2024 PH	7.26 pH units	6.5-9.5
14/10/2024 PH	7.41 pH units	6.5-9.5
16/10/2024 PH	7.03 pH units	6.5-9.5
25/10/2024 PH	7.34 pH units	6.5-9.5
29/10/2024 PH	7.13 pH units	6.5-9.5
07/11/2024 PH	7.11 pH units	6.5-9.5
19/11/2024 PH	7.14 pH units	6.5-9.5
20/11/2024 PH	7.21 pH units	6.5-9.5
21/11/2024 PH	7.36 pH units	6.5-9.5
22/11/2024 PH	7.53 pH units	6.5-9.5
03/12/2024 PH	7.23 pH units	6.5-9.5
04/12/2024 PH	7.23 pH units	6.5-9.5
02/01/2025 PH	7.24 pH units	6.5-9.5
10/01/2025 PH	7.41 pH units	6.5-9.5
21/01/2025 PH	7.41 pH units	6.5-9.5
30/01/2025 PH	7.15 pH units	6.5-9.5
04/02/2025 PH	7.12 pH units	6.5-9.5
14/02/2025 PH	7.11 pH units	6.5-9.5
24/02/2025 PH	6.8 pH units	6.5-9.5
27/02/2025 PH	7.01 pH units	6.5-9.5
07/03/2025 PH	7.11 pH units	6.5-9.5
13/03/2025 PH	6.97 pH units	6.5-9.5
29/03/2025 PH	7.17 pH units	6.5-9.5
10/04/2025 PH	7.06 pH units	6.5-9.5
11/04/2025 PH	7.15 pH units	6.5-9.5
22/04/2025 PH	7.16 pH units	6.5-9.5
01/05/2025 PH	7.24 pH units	6.5-9.5
06/05/2025 PH	7.34 pH units	6.5-9.5
07/05/2025 PH	7.6 pH units	6.5-9.5
13/05/2025 PH	7.61 pH units	6.5-9.5
16/05/2025 PH	7.28 pH units	6.5-9.5
21/05/2025 PH	7.36 pH units	6.5-9.5
28/05/2025 PH	7.42 pH units	6.5-9.5
13/06/2025 PH	7.53 pH units	6.5-9.5
17/06/2025 PH	7.53 pH units	6.5-9.5
19/06/2025 PH	7.41 pH units	6.5-9.5
20/06/2025 PH	7.46 pH units	6.5-9.5
26/06/2025 PH	7.33 pH units	6.5-9.5
04/07/2025 PH	7.28 pH units	6.5-9.5
08/07/2025 PH	7.5 pH units	6.5-9.5
15/07/2025 PH	7.4 pH units	6.5-9.5
21/07/2025 PH	7.38 pH units	6.5-9.5

29/07/2025	PH		7.38 pH units	6.5-9.5
05/09/2025	PH		7.13 pH units	6.5-9.5
10/09/2025	PH		7.32 pH units	6.5-9.5
12/09/2025	PH		7.26 pH units	6.5-9.5
17/09/2025	PH		7.79 pH units	6.5-9.5
29/09/2025	PH		7 pH units	6.5-9.5
03/10/2025	PH		7.17 pH units	6.5-9.5
05/10/2025	PH		7.18 pH units	6.5-9.5
18/10/2025	PH		7.32 pH units	6.5-9.5
20/10/2025	PH		7.33 pH units	6.5-9.5
27/10/2025	PH		7.17 pH units	6.5-9.5
28/10/2025	PH		7.08 pH units	6.5-9.5
31/10/2025	PH		7.12 pH units	6.5-9.5
08/11/2025	PH		7.08 pH units	6.5-9.5
10/11/2025	PH		7.11 pH units	6.5-9.5
19/11/2025	PH		7.2 pH units	6.5-9.5
20/11/2025	PH		7.07 pH units	6.5-9.5
21/11/2025	PH		7.24 pH units	6.5-9.5
27/11/2025	PH		7.02 pH units	6.5-9.5
05/12/2025	PH		7.13 pH units	6.5-9.5
11/12/2025	PH		7.03 pH units	6.5-9.5
18/12/2025	PH		7 pH units	6.5-9.5
19/12/2025	PH		7.28 pH units	6.5-9.5
08/01/2026	PH		8.03 pH units	6.5-9.5
15/01/2026	PH		7.16 pH units	6.5-9.5
19/01/2026	PH		6.89 pH units	6.5-9.5
20/01/2026	PH		7.21 pH units	6.5-9.5
10/02/2026	PH		6.93 pH units	6.5-9.5
11/02/2026	PH		7.06 pH units	6.5-9.5
17/02/2026	PH		7.09 pH units	6.5-9.5
26/03/2021	SELENIUM	<	0.2 µg/l	10
07/04/2021	SELENIUM	<	0.2 µg/l	10
08/07/2021	SELENIUM	<	0.2 µg/l	10
12/07/2021	SELENIUM	<	0.2 µg/l	10
14/07/2021	SELENIUM	<	0.2 µg/l	10
01/10/2021	SELENIUM	<	0.2 µg/l	10
14/12/2021	SELENIUM	<	0.2 µg/l	10
22/12/2021	SELENIUM	<	0.99 µg/l	10
07/01/2022	SELENIUM	<	0.99 µg/l	10
04/03/2022	SELENIUM	<	0.85 µg/l	10
08/04/2022	SELENIUM	<	0.85 µg/l	10
04/05/2022	SELENIUM	<	0.85 µg/l	10
28/06/2022	SELENIUM	<	0.85 µg/l	10
10/08/2022	SELENIUM	<	0.85 µg/l	10
07/09/2022	SELENIUM	<	0.85 µg/l	10
10/11/2022	SELENIUM	<	0.85 µg/l	10
27/01/2023	SELENIUM	<	0.85 µg/l	10
24/02/2023	SELENIUM	<	0.85 µg/l	10

10/05/2023	SELENIUM	<	0.85 µg/l	10
30/05/2023	SELENIUM	<	0.85 µg/l	10
14/07/2023	SELENIUM	<	0.85 µg/l	10
31/10/2023	SELENIUM	<	0.85 µg/l	10
16/11/2023	SELENIUM	<	0.85 µg/l	10
23/11/2023	SELENIUM	<	0.85 µg/l	10
05/01/2024	SELENIUM	<	0.85 µg/l	10
06/02/2024	SELENIUM	<	0.85 µg/l	10
26/03/2024	SELENIUM	<	0.85 µg/l	10
15/05/2024	SELENIUM	<	0.85 µg/l	10
07/08/2024	SELENIUM	<	0.85 µg/l	10
26/09/2024	SELENIUM	<	0.85 µg/l	10
09/10/2024	SELENIUM	<	0.85 µg/l	10
21/11/2024	SELENIUM	<	0.85 µg/l	10
12/02/2025	SELENIUM	<	0.85 µg/l	10
21/03/2025	SELENIUM	<	0.85 µg/l	10
07/05/2025	SELENIUM	<	0.85 µg/l	10
09/06/2025	SELENIUM	<	0.85 µg/l	10
29/09/2025	SELENIUM	<	0.85 µg/l	10
22/10/2025	SELENIUM	<	0.85 µg/l	10
24/11/2025	SELENIUM	<	0.85 µg/l	10
22/12/2025	SELENIUM	<	0.85 µg/l	10
28/01/2026	SELENIUM	<	0.85 µg/l	10
21/05/2021	SODIUM		14.1 mg/l	200
14/06/2021	SODIUM		13.1 mg/l	200
02/07/2021	SODIUM		12.4 mg/l	200
06/07/2021	SODIUM		11.8 mg/l	200
27/08/2021	SODIUM		10.8 mg/l	200
07/10/2021	SODIUM		13 mg/l	200
19/11/2021	SODIUM		12.5 mg/l	200
13/12/2021	SODIUM		13.8 mg/l	200
05/01/2022	SODIUM		13.1 mg/l	200
22/03/2022	SODIUM		13.3 mg/l	200
30/03/2022	SODIUM		12.7 mg/l	200
14/04/2022	SODIUM		13.5 mg/l	200
13/06/2022	SODIUM		12.3 mg/l	200
09/08/2022	SODIUM		11.8 mg/l	200
06/12/2022	SODIUM		13.6 mg/l	200
14/12/2022	SODIUM		13.1 mg/l	200
16/12/2022	SODIUM		12.8 mg/l	200
24/01/2023	SODIUM		11.9 mg/l	200
14/03/2023	SODIUM		11.8 mg/l	200
11/04/2023	SODIUM		11.1 mg/l	200
11/07/2023	SODIUM		11.8 mg/l	200
10/08/2023	SODIUM		12 mg/l	200
22/09/2023	SODIUM		11.9 mg/l	200
14/11/2023	SODIUM		6.02 mg/l	200
16/11/2023	SODIUM		12.5 mg/l	200

19/12/2023	SODIUM		10.3 mg/l	200
01/02/2024	SODIUM		11.5 mg/l	200
15/03/2024	SODIUM		11.3 mg/l	200
04/04/2024	SODIUM		11.7 mg/l	200
28/05/2024	SODIUM		13.7 mg/l	200
17/07/2024	SODIUM		14.8 mg/l	200
03/09/2024	SODIUM		13 mg/l	200
07/11/2024	SODIUM		13.5 mg/l	200
28/11/2024	SODIUM		5.58 mg/l	200
14/05/2025	SODIUM		13.4 mg/l	200
17/05/2025	SODIUM		11 mg/l	200
20/06/2025	SODIUM		14 mg/l	200
10/07/2025	SODIUM		16.5 mg/l	200
12/09/2025	SODIUM		10.9 mg/l	200
06/10/2025	SODIUM		17.8 mg/l	200
23/10/2025	SODIUM		15.5 mg/l	200
03/12/2025	SODIUM		13.9 mg/l	200
11/02/2026	SODIUM		12.4 mg/l	200
11/03/2021	TURBIDITY	<	0.24 NTU	4
19/03/2021	TURBIDITY	<	0.24 NTU	4
25/03/2021	TURBIDITY	<	0.24 NTU	4
29/03/2021	TURBIDITY	<	0.24 NTU	4
30/03/2021	TURBIDITY	<	0.16 NTU	4
07/04/2021	TURBIDITY	<	0.24 NTU	4
18/04/2021	TURBIDITY	<	0.24 NTU	4
23/04/2021	TURBIDITY	<	0.24 NTU	4
08/05/2021	TURBIDITY	<	0.24 NTU	4
11/05/2021	TURBIDITY	<	0.24 NTU	4
20/05/2021	TURBIDITY	<	0.24 NTU	4
27/05/2021	TURBIDITY	<	0.24 NTU	4
29/05/2021	TURBIDITY	<	0.24 NTU	4
02/06/2021	TURBIDITY	<	0.24 NTU	4
08/06/2021	TURBIDITY	<	0.16 NTU	4
14/06/2021	TURBIDITY	<	0.16 NTU	4
15/06/2021	TURBIDITY	<	0.16 NTU	4
29/06/2021	TURBIDITY	<	0.16 NTU	4
01/07/2021	TURBIDITY	<	0.16 NTU	4
06/07/2021	TURBIDITY	<	0.16 NTU	4
22/07/2021	TURBIDITY	<	0.16 NTU	4
23/07/2021	TURBIDITY	<	0.16 NTU	4
03/08/2021	TURBIDITY	<	0.16 NTU	4
08/08/2021	TURBIDITY	<	0.24 NTU	4
09/08/2021	TURBIDITY	<	0.16 NTU	4
01/09/2021	TURBIDITY	<	0.16 NTU	4
06/09/2021	TURBIDITY	<	0.16 NTU	4
24/09/2021	TURBIDITY	<	0.24 NTU	4
01/10/2021	TURBIDITY	<	0.24 NTU	4
13/10/2021	TURBIDITY	<	0.24 NTU	4

20/10/2021	TURBIDITY	<	0.24 NTU	4
22/10/2021	TURBIDITY	<	0.16 NTU	4
29/10/2021	TURBIDITY	<	0.24 NTU	4
05/11/2021	TURBIDITY	<	0.16 NTU	4
10/11/2021	TURBIDITY	<	0.16 NTU	4
13/11/2021	TURBIDITY	<	0.24 NTU	4
16/11/2021	TURBIDITY	<	0.24 NTU	4
19/11/2021	TURBIDITY	<	0.24 NTU	4
25/11/2021	TURBIDITY	<	0.24 NTU	4
30/11/2021	TURBIDITY	<	0.16 NTU	4
02/12/2021	TURBIDITY	<	0.16 NTU	4
06/12/2021	TURBIDITY	<	0.16 NTU	4
07/12/2021	TURBIDITY	<	0.24 NTU	4
08/12/2021	TURBIDITY	<	0.24 NTU	4
09/12/2021	TURBIDITY	<	0.16 NTU	4
09/12/2021	TURBIDITY	<	0.16 NTU	4
13/12/2021	TURBIDITY	<	0.16 NTU	4
15/12/2021	TURBIDITY	<	0.16 NTU	4
16/12/2021	TURBIDITY	<	0.16 NTU	4
17/12/2021	TURBIDITY	<	0.24 NTU	4
18/12/2021	TURBIDITY	<	0.24 NTU	4
20/12/2021	TURBIDITY	<	0.24 NTU	4
22/12/2021	TURBIDITY	<	0.16 NTU	4
05/01/2022	TURBIDITY	<	0.16 NTU	4
12/01/2022	TURBIDITY	<	0.24 NTU	4
24/01/2022	TURBIDITY	<	0.24 NTU	4
01/02/2022	TURBIDITY	<	0.16 NTU	4
07/02/2022	TURBIDITY	<	0.24 NTU	4
08/02/2022	TURBIDITY	<	0.24 NTU	4
16/02/2022	TURBIDITY	<	0.24 NTU	4
26/02/2022	TURBIDITY	<	0.24 NTU	4
01/03/2022	TURBIDITY	<	0.24 NTU	4
01/03/2022	TURBIDITY	<	0.24 NTU	4
16/03/2022	TURBIDITY	<	0.24 NTU	4
21/03/2022	TURBIDITY	<	0.24 NTU	4
07/04/2022	TURBIDITY	<	0.2 NTU	4
11/04/2022	TURBIDITY	<	0.24 NTU	4
14/04/2022	TURBIDITY	<	0.16 NTU	4
21/04/2022	TURBIDITY		0.2 NTU	4
05/05/2022	TURBIDITY	<	0.24 NTU	4
09/05/2022	TURBIDITY	<	0.24 NTU	4
10/05/2022	TURBIDITY	<	0.24 NTU	4
18/05/2022	TURBIDITY	<	0.24 NTU	4
19/05/2022	TURBIDITY	<	0.16 NTU	4
23/05/2022	TURBIDITY	<	0.16 NTU	4
24/05/2022	TURBIDITY	<	0.2 NTU	4
27/05/2022	TURBIDITY	<	0.16 NTU	4
04/06/2022	TURBIDITY	<	0.2 NTU	4

05/06/2022	TURBIDITY	<	0.2 NTU	4
07/06/2022	TURBIDITY	<	0.16 NTU	4
16/06/2022	TURBIDITY	<	0.2 NTU	4
17/06/2022	TURBIDITY	<	0.16 NTU	4
20/06/2022	TURBIDITY	<	0.24 NTU	4
28/06/2022	TURBIDITY	<	0.16 NTU	4
07/07/2022	TURBIDITY	<	0.24 NTU	4
20/07/2022	TURBIDITY	<	0.24 NTU	4
29/07/2022	TURBIDITY	<	0.2 NTU	4
10/08/2022	TURBIDITY	<	0.24 NTU	4
15/08/2022	TURBIDITY	<	0.16 NTU	4
23/08/2022	TURBIDITY	<	0.16 NTU	4
27/08/2022	TURBIDITY	<	0.16 NTU	4
08/09/2022	TURBIDITY	<	0.16 NTU	4
28/09/2022	TURBIDITY	<	0.16 NTU	4
05/10/2022	TURBIDITY	<	0.16 NTU	4
17/10/2022	TURBIDITY	<	0.24 NTU	4
20/10/2022	TURBIDITY	<	0.24 NTU	4
26/10/2022	TURBIDITY	<	0.24 NTU	4
01/11/2022	TURBIDITY	<	0.24 NTU	4
07/11/2022	TURBIDITY	<	0.16 NTU	4
15/11/2022	TURBIDITY	<	0.2 NTU	4
19/11/2022	TURBIDITY	<	0.2 NTU	4
22/11/2022	TURBIDITY	<	0.2 NTU	4
29/11/2022	TURBIDITY	<	0.2 NTU	4
30/11/2022	TURBIDITY	<	0.24 NTU	4
07/12/2022	TURBIDITY	<	0.2 NTU	4
16/12/2022	TURBIDITY	<	0.16 NTU	4
10/01/2023	TURBIDITY	<	0.2 NTU	4
27/01/2023	TURBIDITY	<	0.16 NTU	4
02/02/2023	TURBIDITY	<	0.24 NTU	4
07/02/2023	TURBIDITY	<	0.2 NTU	4
11/02/2023	TURBIDITY	<	0.16 NTU	4
01/03/2023	TURBIDITY	<	0.24 NTU	4
02/03/2023	TURBIDITY	<	0.24 NTU	4
14/03/2023	TURBIDITY	<	0.2 NTU	4
24/03/2023	TURBIDITY	<	0.24 NTU	4
29/03/2023	TURBIDITY	<	0.16 NTU	4
05/04/2023	TURBIDITY	<	0.24 NTU	4
06/04/2023	TURBIDITY	<	0.16 NTU	4
19/04/2023	TURBIDITY	<	0.16 NTU	4
26/04/2023	TURBIDITY	<	0.24 NTU	4
05/05/2023	TURBIDITY	<	0.24 NTU	4
09/05/2023	TURBIDITY	<	0.24 NTU	4
19/05/2023	TURBIDITY	<	0.2 NTU	4
24/05/2023	TURBIDITY	<	0.24 NTU	4
01/06/2023	TURBIDITY	<	0.24 NTU	4
06/06/2023	TURBIDITY	<	0.16 NTU	4

08/06/2023	TURBIDITY	<	0.16 NTU	4
09/06/2023	TURBIDITY	<	0.16 NTU	4
12/06/2023	TURBIDITY	<	0.16 NTU	4
28/06/2023	TURBIDITY	<	0.16 NTU	4
30/06/2023	TURBIDITY	<	0.16 NTU	4
04/07/2023	TURBIDITY	<	0.24 NTU	4
11/07/2023	TURBIDITY	<	0.24 NTU	4
12/07/2023	TURBIDITY	<	0.24 NTU	4
13/07/2023	TURBIDITY	<	0.24 NTU	4
18/07/2023	TURBIDITY	<	0.2 NTU	4
27/07/2023	TURBIDITY	<	0.16 NTU	4
28/07/2023	TURBIDITY	<	0.24 NTU	4
02/08/2023	TURBIDITY	<	0.2 NTU	4
05/08/2023	TURBIDITY	<	0.2 NTU	4
07/08/2023	TURBIDITY	<	0.24 NTU	4
24/08/2023	TURBIDITY	<	0.16 NTU	4
30/08/2023	TURBIDITY	<	0.16 NTU	4
22/09/2023	TURBIDITY	<	0.2 NTU	4
28/09/2023	TURBIDITY	<	0.24 NTU	4
04/10/2023	TURBIDITY	<	0.16 NTU	4
17/10/2023	TURBIDITY	<	0.16 NTU	4
27/10/2023	TURBIDITY	<	0.16 NTU	4
28/10/2023	TURBIDITY	<	0.24 NTU	4
31/10/2023	TURBIDITY	<	0.16 NTU	4
08/11/2023	TURBIDITY	<	0.24 NTU	4
14/11/2023	TURBIDITY	<	0.24 NTU	4
14/11/2023	TURBIDITY	<	0.16 NTU	4
23/11/2023	TURBIDITY	<	0.24 NTU	4
06/12/2023	TURBIDITY	<	0.24 NTU	4
13/12/2023	TURBIDITY	<	0.2 NTU	4
18/12/2023	TURBIDITY	<	0.24 NTU	4
19/12/2023	TURBIDITY	<	0.16 NTU	4
21/12/2023	TURBIDITY	<	0.2 NTU	4
22/12/2023	TURBIDITY	<	0.16 NTU	4
05/01/2024	TURBIDITY	<	0.24 NTU	4
06/01/2024	TURBIDITY	<	0.24 NTU	4
12/01/2024	TURBIDITY	<	0.2 NTU	4
17/01/2024	TURBIDITY	<	0.2 NTU	4
23/01/2024	TURBIDITY	<	0.24 NTU	4
01/02/2024	TURBIDITY	<	0.24 NTU	4
06/02/2024	TURBIDITY	<	0.16 NTU	4
22/02/2024	TURBIDITY	<	0.16 NTU	4
23/02/2024	TURBIDITY	<	0.16 NTU	4
28/02/2024	TURBIDITY	<	0.16 NTU	4
05/03/2024	TURBIDITY	<	0.24 NTU	4
15/03/2024	TURBIDITY	<	0.16 NTU	4
22/03/2024	TURBIDITY	<	0.16 NTU	4
26/03/2024	TURBIDITY	<	0.16 NTU	4

04/04/2024	TURBIDITY	<	0.24 NTU	4
10/04/2024	TURBIDITY	<	0.24 NTU	4
18/04/2024	TURBIDITY	<	0.24 NTU	4
23/04/2024	TURBIDITY	<	0.16 NTU	4
09/05/2024	TURBIDITY	<	0.16 NTU	4
15/05/2024	TURBIDITY	<	0.16 NTU	4
23/05/2024	TURBIDITY	<	0.2 NTU	4
24/05/2024	TURBIDITY	<	0.16 NTU	4
14/06/2024	TURBIDITY	<	0.2 NTU	4
20/06/2024	TURBIDITY	<	0.16 NTU	4
25/06/2024	TURBIDITY	<	0.2 NTU	4
26/06/2024	TURBIDITY	<	0.16 NTU	4
27/06/2024	TURBIDITY	<	0.16 NTU	4
02/07/2024	TURBIDITY	<	0.2 NTU	4
08/07/2024	TURBIDITY	<	0.16 NTU	4
17/07/2024	TURBIDITY	<	0.16 NTU	4
22/07/2024	TURBIDITY	<	0.16 NTU	4
08/08/2024	TURBIDITY	<	0.16 NTU	4
27/08/2024	TURBIDITY	<	0.16 NTU	4
28/08/2024	TURBIDITY		0.3 NTU	4
03/09/2024	TURBIDITY	<	0.16 NTU	4
04/09/2024	TURBIDITY	<	0.16 NTU	4
10/09/2024	TURBIDITY	<	0.16 NTU	4
24/09/2024	TURBIDITY	<	0.2 NTU	4
26/09/2024	TURBIDITY	<	0.16 NTU	4
04/10/2024	TURBIDITY	<	0.16 NTU	4
08/10/2024	TURBIDITY	<	0.2 NTU	4
09/10/2024	TURBIDITY	<	0.16 NTU	4
14/10/2024	TURBIDITY	<	0.16 NTU	4
16/10/2024	TURBIDITY	<	0.16 NTU	4
17/10/2024	TURBIDITY	<	0.16 NTU	4
31/10/2024	TURBIDITY	<	0.16 NTU	4
07/11/2024	TURBIDITY	<	0.2 NTU	4
18/11/2024	TURBIDITY	<	0.16 NTU	4
19/11/2024	TURBIDITY	<	0.2 NTU	4
21/11/2024	TURBIDITY	<	0.2 NTU	4
27/11/2024	TURBIDITY	<	0.2 NTU	4
06/12/2024	TURBIDITY	<	0.16 NTU	4
12/12/2024	TURBIDITY	<	0.16 NTU	4
02/01/2025	TURBIDITY	<	0.1 NTU	4
24/01/2025	TURBIDITY	<	0.1 NTU	4
29/01/2025	TURBIDITY	<	0.1 NTU	4
30/01/2025	TURBIDITY	<	0.1 NTU	4
07/02/2025	TURBIDITY	<	0.1 NTU	4
11/02/2025	TURBIDITY	<	0.1 NTU	4
24/02/2025	TURBIDITY	<	0.2 NTU	4
27/02/2025	TURBIDITY	<	0.1 NTU	4
13/03/2025	TURBIDITY	<	0.1 NTU	4

17/03/2025	TURBIDITY	<	0.1 NTU	4
21/03/2025	TURBIDITY	<	0.19 NTU	4
25/03/2025	TURBIDITY	<	0.19 NTU	4
03/04/2025	TURBIDITY	<	0.19 NTU	4
08/04/2025	TURBIDITY	<	0.19 NTU	4
16/04/2025	TURBIDITY	<	0.1 NTU	4
22/04/2025	TURBIDITY	<	0.19 NTU	4
07/05/2025	TURBIDITY	<	0.1 NTU	4
12/05/2025	TURBIDITY	<	0.1 NTU	4
13/05/2025	TURBIDITY	<	0.19 NTU	4
28/05/2025	TURBIDITY	<	0.19 NTU	4
05/06/2025	TURBIDITY	<	0.19 NTU	4
09/06/2025	TURBIDITY	<	0.2 NTU	4
11/06/2025	TURBIDITY	<	0.19 NTU	4
15/06/2025	TURBIDITY	<	0.19 NTU	4
16/06/2025	TURBIDITY	<	0.1 NTU	4
18/06/2025	TURBIDITY	<	0.1 NTU	4
19/06/2025	TURBIDITY	<	0.19 NTU	4
20/06/2025	TURBIDITY	<	0.1 NTU	4
01/07/2025	TURBIDITY	<	0.19 NTU	4
09/07/2025	TURBIDITY	<	0.19 NTU	4
21/07/2025	TURBIDITY	<	0.19 NTU	4
01/08/2025	TURBIDITY	<	0.19 NTU	4
07/08/2025	TURBIDITY	<	0.2 NTU	4
08/08/2025	TURBIDITY	<	0.19 NTU	4
03/09/2025	TURBIDITY	<	0.2 NTU	4
06/09/2025	TURBIDITY	<	0.19 NTU	4
10/09/2025	TURBIDITY	<	0.2 NTU	4
12/09/2025	TURBIDITY	<	0.19 NTU	4
30/09/2025	TURBIDITY	<	0.2 NTU	4
01/10/2025	TURBIDITY	<	0.19 NTU	4
08/10/2025	TURBIDITY	<	0.19 NTU	4
10/10/2025	TURBIDITY	<	0.1 NTU	4
14/10/2025	TURBIDITY	<	0.1 NTU	4
15/10/2025	TURBIDITY	<	0.19 NTU	4
18/10/2025	TURBIDITY	<	0.2 NTU	4
20/10/2025	TURBIDITY	<	0.1 NTU	4
22/10/2025	TURBIDITY	<	0.1 NTU	4
28/10/2025	TURBIDITY	<	0.2 NTU	4
08/11/2025	TURBIDITY	<	0.19 NTU	4
12/11/2025	TURBIDITY	<	0.1 NTU	4
19/11/2025	TURBIDITY	<	0.3 NTU	4
20/11/2025	TURBIDITY	<	0.1 NTU	4
26/11/2025	TURBIDITY	<	0.1 NTU	4
03/12/2025	TURBIDITY	<	0.1 NTU	4
11/12/2025	TURBIDITY	<	0.19 NTU	4
12/12/2025	TURBIDITY	<	0.1 NTU	4
08/01/2026	TURBIDITY	<	0.1 NTU	4

15/01/2026 TURBIDITY	<	0.1 NTU	4
19/01/2026 TURBIDITY	<	0.19 NTU	4
20/01/2026 TURBIDITY	<	0.1 NTU	4
27/01/2026 TURBIDITY	<	0.19 NTU	4
28/01/2026 TURBIDITY	<	0.1 NTU	4
05/02/2026 TURBIDITY	<	0.19 NTU	4
11/02/2026 TURBIDITY	<	0.19 NTU	4