United Utilities Water Limited
Haweswater House
Lingley Mere Business Park
Lingley Green Avenue
Great Sankey
Warrington WA5 3LP

Telephone: 01925 237000

unitedutilities.com

Our ref: EIR/ID407
Date: 18/06/2025
Email: EIRRequests@uuplc.co.uk

Dear [redacted]

EIR Reference: EIR/ID/407

Thank you for your request environmental information. We appreciate your interest, and we want to let you know that your request has been carefully considered in accordance with the Environmental Information Regulations (EIR).

As part of your role as sewerage undertaker, please can you provide details of:

- *recorded flooding incidents, flood events, and history of flooding*
- *any further information you think may be useful/relevant to the Site*

BNG coordinates (X,Y) = 391872, 406342

Postcode = OL1 2JH

In relation to the above, we have been in contact with our wastewater modelling team, who have advised that regarding coordinates x391872 y406342 (OL1 2JH) they have conducted analysis using the Combined Sewer Overflow data for discharge permit OLD0033 (View registration NW/01OLD0033/004) which is the CSO nearest to the hospital. Further information regarding storm overflow activations can be found our website here (Storm overflow performance | United Utilities).

As part of their searches, they found that there are no recorded flooding incidents for this location in our mapping system (GIS) and no flooding is predicted on the main 525mm sewer on Sheepfoot Lane. There is a predicted chance of flooding at the 300mm sewer. However, it is unclear if the hospital actually discharges to this sewer. Finally, the manhole (MH5402) has been flagged as surveyed and no issues found.

Does this cover what it is you needed, or is there more information you were hoping to see? If there is more you were expecting, please let us know so we can assist you further.

Kind regards